

Filed with the Public Utility Commission

Village of Orleans Electric Department

2019 Integrated Resource Plan



Executive Summary:

The Village of Orleans (OED) has operated an electric utility system since 1925 in the northern part of Vermont, located close to the Canadian border, and in the center of Vermont's Northeast Kingdom. OED's service territory encompasses the Village of Orleans, and adjacent portions of the towns of Barton, Brownington, Coventry, and Irasburg. OED remains guided by the Vermont Public Utility Commission ("PUC") rules as well as by the American Public Power Association's ("APPA") safety manual. As a small municipal utility OED is careful to balance maintaining reliability and reasonable cost levels with the need to deliver innovative programs to customers that provide practical value.

OED's distribution system serves a mix of residential, small commercial, and large commercial customers. Residential customers make up over 85% of the customer mix while accounting for close to a third of OED's retail kWh sales. One industrial customer makes up over 50% of retail usage with the remaining 16% of retail sales going to small commercial and public authority customers.

Consistent with regulatory requirements, every 3 years OED is required to prepare and implement a least cost integrated plan (also called an Integrated Resource Plan, or IRP) for provision of energy services to its Vermont customers. OED's Integrated Resource Plan (IRP) is intended to meet the public's need for energy services, after safety concerns are addressed, at the lowest present value life cycle cost, including environmental and economic costs, through a strategy combining investments and expenditures on energy supply, transmission and distribution capacity, transmission and distribution efficiency, and comprehensive energy efficiency programs.

ELECTRICITY DEMAND

OED is facing a period of relatively flat demand influenced by several competing factors, all of which carry some uncertainty. Continued adoption of solar net metering reduces demand although the pace at which net metering will grow in OED's territory is uncertain. As various incentives aimed at transitioning from fossil fuels to cleaner electricity are made available, increasing acceptance of cold climate heat pumps and similar appliances will likely increase demand, as will an expected increase in the use of electric vehicles.

While no significant change in the demand associated with OED's largest customers is currently anticipated, the potential does exist. With over 50% of OED's energy requirements

Village of Orleans - 2019 Integrated Resource Plan

and about two-thirds of its peak concentrated on one single industrial customer, Ethan Allen manufacturing, OED monitors the plans of this large customer in order to anticipate necessary changes to the existing resource plan and system infrastructure. In the case of a significant expansion by one or more customers, detailed engineering studies may be needed to identify necessary system upgrades.

ELECTRICITY SUPPLY

OED's current power supply portfolio includes entitlements in a mixture of baseload, firm and intermittent resources through ownership or contractual arrangements of varying duration, with most contracts carrying a fixed price feature. Designed to meet anticipated demand, as well as acting as a hedge against exposure to volatile ISO-New England spot prices, the portfolio is heavily weighted toward market contracts, hydro, and other renewable sources.

When considering future electricity demand, OED seeks to supplement its existing resources with market contracts as well as new demand-side and supply resources. OED believes that in addition to working with financially stable counterparties, it is important for new resource decisions to balance four important characteristics: new resources should be low cost, locally located, renewable and reliable. Market contracts have the advantage of being both scalable and customizable in terms of delivery at specific times and locations. OED anticipates regional availability of competitively priced renewable resources including solar, wind, and hydro. In addition to playing a role in meeting future electricity requirements, this category of resource contributes to meeting Renewable Energy Standard goals. Gas fired generation may have a role to play in the future portfolio for reliability purposes. As battery storage technology matures and proves economically feasible OED sees potential for storage to play an important load management role and to enhance the local impact of distributed generation.

RESOURCE PLANS

Looking ahead to evaluating major policy and resource acquisition decisions, OED employs an integrated financial model that incorporates impacts on load and subsequent effects on revenue and power supply costs, as well as effects of investment, financing and operating costs. Use of the integrated model allows for evaluation of uncertainty related to key variables, on the way to identifying anticipated rate impacts over time. While rate trajectory is the primary metric OED relies on to evaluate resource decisions on an individual or portfolio basis, there are other more subjective factors to consider, including resource diversity or exposure to major changes in market rules.

OED faces three major energy resource decisions over the 2020 - 2039 period covered by this Integrated Resource Plan (IRP).

The major resource decisions faced by OED occur in 2020 and 2024, respectively, which in total, will affect about 90% of OED's energy supply between 2020 and 2024. The first is the expiration of a contract at the end of 2022, which represents about 65% of OED's energy supply. The second is the expiration of a group of current market contracts in mid 2024, which represent about 25% of OED's energy supply.

Options being evaluated by OED to replace these two contracts include renegotiating the contract expiring in 2022 and extending its term, signing a PPA for an existing hydro plant to provide energy and Tier I RECs, signing a PPA for a solar plant to provide energy and Tier II RECs, or signing a PPA for market energy supplies.

The main sources of uncertainty expected to impact these decisions are the potential; loss of Ethan Allen's load, followed by the price of natural gas and pipeline transportation prices., load growth, the cost of regional transmission service and, to a lesser extent, REC prices. OED is largely hedged for the long run in the capacity market, reducing the impact of capacity prices.

Analysis of these major resource decisions also addresses two load-related questions: 1) what is the rate impact of losing Ethan Allen's load? 2) what is the rate impact of 1% compound annual load growth? While the loss of Ethan Allen's load is not expected at this time, an 80% reduction in Ethan Allen load has the potential to drive a 50 % rate increase. An additional 1% increase in compound annual growth, relative to the reference case, could reduce average rates by 7% by 2032.

RENEWABLE ENERGY STANDARD

OED is subject to the Vermont Renewable Energy Standard which imposes an obligation for OED to obtain a portion of its energy requirements from renewable resources. The RES obligation increases over time and is stratified into three categories, TIER I, TIER II and TIER III. OED's obligations under TIER I can be satisfied by owning or purchasing RECs from qualifying regional resources. TIER II obligations must be satisfied by owning or purchasing RECs from renewable resources located within Vermont. Satisfaction of OED's TIER III obligation involves energy transformation, or reduction of fossil fuel use within its territory. TIER III programs can consist of thermal efficiency measures, electrification of the transportation sector, and converting customers that rely on diesel generation to electric service, among other things. By providing incentive programs to encourage conversion of traditional fossil fuel applications OED receives credits toward its TIER III obligation. More information regarding OED's approach to meeting its TIER III obligation is available in Appendix B to this document.

ELECTRICITY TRANSMISSION AND DISTRIBUTION

OED has a compact service territory as a result of being a small, municipal-owned electric utility and has consistently pursued upgrade initiatives each year in order to maintain a reliable and efficient system. OED's distribution system consists of approximately 10 miles of distribution line operating at 13.2 kV, 30 miles operating at 2.4 kV, one jointly-owned substation, two wholly-owned substations, and is radially fed from a 5.5-mile 46kV transmission line jointly owned by OED, and Barton Village, Inc.

In addition to upgrading and routinely maintaining the system to ensure efficiency and reliability, OED is examining the need to modernize in order to support beneficial electrification and additional distributed generation on the system and to provide more customer oriented services, including load management programs that reduce costs for both OED and its customers. OED is currently engaged with VPPSA in a multi-phased process designed to assess its readiness for AMI, guide it through an RFP process culminating in vendor and equipment selection and ultimately resulting in implementation of an AMI system, provided the resulting cost estimates gained through the RFP process are not prohibitive. .

OED sees potential value to customers from utilizing rate design, direct load control or other incentive programs as tools to manage both system and customer peak loads in unison. Implementation of an AMI system is expected to enhance OED's ability to deliver these benefits and capture economic development/retention opportunities where possible.

Table of Contents

EXECUTIVE SUMMARY:	2
TABLE OF CONTENTS.....	6
INTRODUCTION:	1
I. ELECTRICITY DEMAND.....	7
II. ELECTRICITY SUPPLY.....	17
III. RESOURCE PLANS	25
IV. ELECTRICITY TRANSMISSION & DISTRIBUTION	40
V. FINANCIAL ANALYSIS	58
VI. ACTION PLAN.....	69
 <u>APPENDIX.....</u>	 71
APPENDIX A: NVDA REGIONAL ENERGY PLAN	72
APPENDIX B: 2019 TIER 3 ANNUAL PLAN	73
APPENDIX C: PRICING METHODOLOGY.....	74
APPENDIX D: PUC RULE 4.900 OUTAGE REPORTS	77
APPENDIX E: INVERTER SOURCE REQUIREMENTS.....	82
APPENDIX F: ONE-LINE DIAGRAMS.....	89
GLOSSARY	91

List of Tables

Table 1: OED's Retail Customer Counts	3
Table 2: OED's Retail Sales.....	3
Table 3: OED's Annual System Peak Demand (kW)	4
Table 4: Data Sources for Reconstituting RTLO	8
Table 5: Load Forecast Explanatory Variables	9

Village of Orleans - 2019 Integrated Resource Plan

Table 6: Adjusted Energy Forecast (MWh/Year).....	10
Table 7: Energy Forecast - High Case.....	11
Table 8: Energy Forecast - Low Case	11
Table 9: Peak Forecast (MW).....	12
Table 10: Peak Forecast - High Case.....	14
Table 11: Existing Power Supply Resources.....	19
Table 12: Energy Resource Decision Summary	28
Table 13: Pay for Performance Ranges for One Hour of Project 10 Operation	30
Table 14: RES Requirements (% of Retail Sales).....	31
Table 15: Alternative Compliance Payment (\$/MWH)	32
Table 16: OED Circuit Description	43
Table 17: OED Outage Statistics.....	44
Table 18: OED Vegetation Trimming Cycles.....	53
Table 19: OED Vegetation Management Costs	53
Table 20: OED Tree Related Outages.....	53
Table 21: OED Historic Construction Costs.....	54
Table 22: OED Projected Construction Costs	55
Table 23: Event / Decision Pathways.....	60

List of Figures

Figure 1: OED's Distribution Territory.....	1
Figure 2: Forecasting Process	7
Figure 3: Adjusted Energy Forecast (MWh/Year)	10
Figure 4: Adjusted Peak Forecast (MW).....	13
Figure 5: Average Wednesday Load With and Without Ethan Allen	15
Figure 6: Resource Criteria	19
Figure 7: Energy Supply & Demand by Fuel Type.....	27
Figure 8: Capacity Supply & Demand (Summer MW).....	29
Figure 9: Tier I - Demand & Supply (MWH)	33

Vermont Public Power Supply Authority


Village of Orleans - 2019 Integrated Resource Plan

Figure 10: Tier II - Demand & Supply (MWH).....	34
Figure 11: Energy Transformation Supplies	35
Figure 12: Portfolio Average Carbon Emissions Rate (lbs/MWH).....	36
Figure 13: Carbon Emissions (Tons/Year) and Costs (\$).....	37
Figure 14: OED'Ss Heath Substation.....	41
Figure 15: OED'S Rainbow Substation.....	42
Figure 16: OED'S Ethan Allen Manufacturing Substation.....	42
Figure 17: Primary Components of the Financial Analysis	58
Figure 18: Sensitivity Analysis of Key Variables - Pathway 1 (Reference Case).....	61
Figure 19: Scatter Plot of Financial Analysis Results (PV of Revenue Requirement).....	62
Figure 20: Sensitivity Analysis of Key Variables - Pathway 8 (Hedge Energy + Tier I & II)	63
Figure 21: Quadrant Analysis of Market Price & Energy Length Outcomes.....	64
Figure 21: Rate Impact: Loss of 80% Ethan Allen's Load (Pathway 1 Versus Pathway 5)	65
Figure 22: Rate Impact of 1% CAGR Load Growth	66
Figure 23: Henry Hub Natural Gas Price Forecast (Nominal \$/MMBtu).....	74
Figure 24: Electricity Price Forecast (Nominal \$/MWH)	75
Figure 25: Capacity Price Forecast (Nominal \$/kW-Month)	76
Figure 26: OED One-Line Diagram	89

Introduction:

Located in the Northeast Kingdom of Vermont, the Orleans Electric Department (OED) has operated an electric utility system since 1925. OED serves approximately 670 customers in the towns of Barton, Brownington, Coventry and Irasburg. The boundaries of OED's service territory can be seen on the map below. The service territory is small, covering 5 square miles, and walkable; the customer furthest out is a five-minute drive from the OED office. Like most of Vermont's smaller municipal utilities, many of its utility functions, such as office staffing, are carried out by employees who also have responsibilities in other aspects of village municipal operations. OED remains guided by the Vermont Public Utility Commission (PUC) rules as well as by the American Public Power Association's (APPA) safety manual. Well-established practices keep OED operating safely, efficiently, and reliably.

Figure 1: OED's Distribution Territory



Vermont Public Power Supply Authority:

The Vermont Public Power Supply Authority (VPPSA) is a joint action agency established by the Vermont General Assembly in 1979 under Title 30 VSA, Chapter 84. It provides its members with a broad spectrum of services including power aggregation, financial support, IT support, rate planning support and legislative and regulatory representation. VPPSA is focused on helping local public power utilities remain competitive and thrive in a rapidly changing electric utility environment.

OED is one of twelve member utilities of VPPSA, who is governed by a board of directors that consists of one appointed director from each member. This gives each municipality equal representation. VPPSA's membership includes:

- Village of Orleans
- Barton Village Inc.
- Village of Enosburg Falls Electric Light Department
- Hardwick Electric Department
- Village of Hyde Park
- Village of Jacksonville Electric Company
- Village of Johnson Electric Department
- Ludlow Electric Light Department
- Lyndonville Electric Department
- Morrisville Water & Light Department
- Northfield Electric Department
- Swanton Village Electric Department

OED and VPPSA are parties to a broad Master Supply Agreement (MSA). Under the MSA, VPPSA manages OED's electricity loads and power supply resources, which are pooled with the loads and resources of other VPPSA members under VPPSA's Independent System Operator - New England (ISO-NE) identification number. This enables VPPSA to administer OED's loads and power supply resources in the New England power markets.

System Overview

OED's distribution system serves a mix of residential and commercial customers, with over 85% of the customers being residential. The largest customer, and driver of load, is the Ethan Allen furniture manufacturing plant, spanning 85 acres and makes up approximately 50% of OED's total retail sales.

In 2018 OED's peak demand in the winter months was 3,305 kW and was 2,981 kW during the summer months, making OED a winter peaking utility. Annual retail energy sales for 2018 were 13,690,057 kWh and its annual load factor was 49%.

OED is connected to the Vermont Electric Power Company (VELCO) - Irasburg Substation and receives service at 46 kV. This line then runs to Barton where it feeds the distribution systems of both OED and Barton. The line that runs from the VELCO - Irasburg Substation to the Barton tap is jointly owned by the Barton Village Inc. (Barton), OED, and Vermont Electric Cooperative (VEC).

Table 1: OED's Retail Customer Counts

Data Element	2014	2015	2016	2017	2018
Residential (440)	585	585	583	578	580
Small C&I (442) 1000 kW or less	63	62	62	63	65
Large C&I (442) above 1,000 kW	1	1	1	1	1
Street Lighting (444)	3	3	3	3	3
Public Authorities (445)	16	19	20	20	20
Interdepartmental Sales (448)	0	0	0	0	0
Total	668	670	669	665	669

Table 2: OED's Retail Sales

Data Element	2014	2015	2016	2017	2018
Residential (440)	4,194,369	4,080,894	3,910,258	3,921,505	4,164,360
Small C&I (442) 1000 Kw or less	1,746,151	1,644,724	1,619,972	1,585,929	1,644,934
Large C&I (442) above 1,000 Kw	6,602,400	6,787,400	6,986,400	6,960,000	7,332,000
Street Lighting (444)	158,248	148,944	148,080	147,888	150,368

Village of Orleans - 2019 Integrated Resource Plan

Public Authorities (445)	395,518	388,073	396,396	380,790	398,395
Interdepartmental Sales (448)	0	0	0	0	0
Total	13,096,686	13,050,035	13,061,106	12,996,112	13,690,057
YOY	-1%	0%	0%	0%	5%

Table 3: OED's Annual System Peak Demand (kW)

Data Element	2014	2015	2016	2017	2018
Peak Demand kW	3,467	3,402	3,305	3,337	3,305
Peak Demand Date	1/23/2014	02/24/15	12/16/16	12/28/17	01/02/18
Peak Demand Hour	9	11	8	9	11

Finally, OED does not own or operate any generation plants. Instead, it supplies electricity to its customers with contractual entitlements to power plants and wholesale market contracts throughout the region.

Structure of Report

This report is organized into six major sections plus an appendix and a glossary.

I. Electricity Demand

This chapter describes how OED's electricity requirements were determined and discusses sources of uncertainty in the load forecast.

II. Electricity Supply

This chapter describes OED's electricity supply resources, and the options that are being considered to supply the electricity needs of OED's customers.

III. Resource Plans

This chapter compares OED's electricity demand to its supply and discusses how OED will comply with the Renewable Energy Standard.

IV. Electricity Transmission and Distribution

This chapter describes OED's distribution system and discusses how it is being maintained to provide reliable service to its customers.

V. Financial Analysis

This chapter presents a high-level forecast of OED's power supply costs and cost of service.

VI. Action Plan

This chapter outlines specific actions the OED expects to take as a result of this Integrated Resource Plan.

A. Appendix : Letters List

The appendix includes a series of supporting documents and reports, as listed in the Table of Contents.

B. Glossary


Electricity Demand

I. Electricity Demand

Energy Forecast Methodology: Regression with Adjustments

VPPSA uses Itron's Metrix ND software package and a pair of multiple regression equations to forecast OED's peak and energy requirements. Importantly, the peak and energy forecasts are based on the same underlying data sets and the same methodologies that are used to set OED's annual power budget. As a result, the forecasts are updated annually, and variances are evaluated monthly as actual loads become available. The forecast methodology follows a four-step process.

Figure 2: Forecasting Process



1. Reconstitute Load

In the past, metered load at the distribution system's tiepoints (boundaries) was used as the 'dependent' variable in the regression equations. However, the growing impact of the net metering and Standard Offer Programs has effectively obscured the historical trends in this data, and this would cause the accuracy of the regression equations to decrease. To preserve the accuracy of the regression forecast, VPPSA "reconstitutes" the Real-Time Load Obligation (RTLO) data by 1.) adding back generation from the net metering and Standard Offer Programs, and 2.) subtracting Vermont's transmission losses. This results in a data set that can be accurately modeled using multiple regression, and creates consistency with the historical data.

The resulting, reconstituted load is used as the dependent variable in the regression equations and forms a historical time series data that the regression equations use to predict future loads. The following table summarizes the data that is used to reconstitute the load.

Table 4: Data Sources for Reconstituting RTLO

Data Element	Source
RTLO	ISO-NE
- Vermont Transmission Losses	VELCO ¹
+ Net Metering Program Generation	VPPSA
+ Standard Offer Program Generation	VELCO
= Reconstituted Load	

¹ Vermont Electric Power Company

2. Forecast Load

The regression equations use a series of independent or “explanatory” variables to explain the trends in the reconstituted load data. The equations themselves consist of the explanatory variables that are listed in Table 5.

Table 5: Load Forecast Explanatory Variables

Data Category	Explanatory Variable	Source
Dummy Variables	These variables consist of zeros and ones that capture seasonal, holiday-related, and large, one-time changes in electricity demand.	Not applicable. Determined by the forecast analyst.
Economic Indicators	Unemployment Rate (%)	Vermont Department of Labor
	Eating and Drinking Sales (\$)	Woods and Poole
Energy Efficiency	Cumulative EE Savings Claims (kWh)	Efficiency Vermont Reports and Demand Resource Plan
Weather Variables	Temperature – 10-year average heating & cooling degree days.	National Oceanic and Atmospheric Administration (NOAA)

The forecast accuracy of the regression model is very good. Based on monthly data, it has an R-squared of 98%, and a Mean Absolute Percent Error (MAPE) of 1.47%.

3. Adjust Load

Once the regression models are complete and the forecast accuracy is maximized, the load forecast is adjusted to account for the impact (both historical and forward-looking) of cold climate heat pumps (CCHP), electric vehicles (EV), and net metering. As new electricity-using devices, CCHPs and EVs increase the load. However, by its nature, net metering decreases it².

Because the historical trends for these three items are still nascent, they cannot be effectively captured in the regression equations. In the case of net metering, VPPSA used the most recent three-year average to determine the rate of net metering growth in Orleans. For CCHPs and EVs, we used the same data (provided by Itron) that the Vermont System Planning Committee (VSPC) used in VELCO's 2018 Long Range Transmission Plan.

Notice that the adjusted load does not account for the presence of the Standard Offer Program. This is a deliberate choice that enables the resource planning model to treat the Standard Offer Program as a supply-side resource instead of a load-reducer.

4. Retail Sales

A forecast of retail sales is required to estimate compliance with the Renewable Energy Standard (RES), and is calculated by subtracting Vermont transmission and local distribution losses from the Adjusted Forecast.

² For more information on net-metering, please refer to <https://vppsa.com/energy/net-metering/>.

Energy Forecast Results


Table 6 shows the results of the Regression Forecast for energy, as well as the adjustments that are made to arrive at the Adjusted Forecast. The Compound Annual Growth Rates (CAGR) at the bottom of the table illustrate the trends in each of the columns. Notice that the Regression Forecast itself is declining by 0.1% per year. After making adjustments for CCHPs, EVs, and net metering, the Adjusted Forecast actually increases by 0.3% per year.

Table 6: Adjusted Energy Forecast (MWh/Year)

Year	Year #	Regression Fcst. (MWh)	CCHP Adjustment (MWh)	EV Adjustment (MWh)	Net Metering Adjustment (MWh)	Adjusted Fcst. (MWh)
2020	1	13,986	42	15	-49	13,995
2025	6	13,887	114	75	-92	13,984
2030	11	13,766	186	260	-136	14,075
2035	16	13,766	263	626	-180	14,474
2039	20	13,766	327	862	-215	14,740
CAGR		-0.1%	10.8%	22.5%	7.7%	0.3%

The Adjusted Forecast is the result of high CAGRs for CCHPs (10.8%) and EVs (22.5%). But during the first six years of the forecast, these two trends are mostly offset by the net metering program, which grows by the historical three-year average of 7.7% per year. By year 2027, the impact of CCHPs and EVs is greater than the impact of net metering, and the cross-over point can be seen in the yellow-highlighted circle in Figure 3.

Figure 3: Adjusted Energy Forecast (MWh/Year)



Village of Orleans - 2019 Integrated Resource Plan

All of the trends in these adjustments are highly uncertain. However, they do offset each other, and their collective impact on the forecast is small. Specifically, their individual and collective impact represents fractions of 1%, which falls well within the forecast error (1.47%).

Energy Forecast - High & Low Cases

To form a high case, we assumed that the CAGR for CCHPs over doubles to 25%, and the growth rate for EVs rises to 40%. Simultaneously, we assume that net metering penetration stops at today's levels. At these growth rates, energy demand rises by almost 200% over 2020 electricity use, a result that is driven by the 40% CAGR for EVs. CCHP's alone are responsible for a comparatively small 20% increase in energy demand by 2039. Because of the nature of compound growth, the increase in energy demand does not start to snowball until after 2030. As a result, there is ample opportunity to monitor these trends during the annual budget cycles and the tri-annual IRP cycles.

Table 7: Energy Forecast - High Case

Year	Year #	Regression Fcst. (MWh)	CCHP Adjustment (MWh)	EV Adjustment (MWh)	Net Metering Adjustment (MWh)	Adjusted Fcst. (MWh)
2020	1	13,986	42	15	-49	13,994
2025	6	13,887	128	81	-49	14,047
2030	11	13,766	391	434	-49	14,542
2035	16	13,766	1,194	2,334	-49	17,244
2039	20	13,766	2,914	8,964	-49	25,596
CAGR		-0.1%	23.6%	37.7%	0.0%	3.1%

To form a low case, we assumed that the CAGRs for CCHPs and EVs decreases by more than 50% from the base case. In addition, we assumed that the CAGR for net metering doubles. This combination of trends is a plausible worst-case scenario, and results in a forecast that decreases by 0.3% per year. Like the base case, this rate of change is well within the forecast error.

Table 8: Energy Forecast - Low Case

Year	Year #	Regression Fcst. (MWh)	CCHP Adjustment (MWh)	EV Adjustment (MWh)	Net Metering Adjustment (MWh)	Adjusted Fcst. (MWh)
2020	1	13,986	42	15	-49	13,994
2025	6	13,887	54	24	-99	13,866
2030	11	13,766	68	39	-198	13,675
2035	16	13,766	87	63	-399	13,517
2039	20	13,766	106	92	-697	13,267
CAGR		-0.1%	4.7%	9.5%	14.2%	-0.3%

Peak Forecast Methodology: The Peak & Average Method

The peak forecast regression model forecasts the load during the peak hour each day. Because utility loads are strongly influenced by temperature, this peak usually occurs during an hour of relatively extreme temperatures. In winter, this is during a very cold hour, and in summer it is during a very hot hour.

Unlike the energy forecast model, using average weather in the peak forecast model is not appropriate. Why? By definition, the coldest day and hour is always colder than average, and the hottest day and hour is always hotter than average. As a result, using average weather in the peak forecast model would result in a forecast that is biased and too low. In this context, the key question is, "How can historical weather data be used to develop an accurate representation of future weather, while still maintaining the extremes?"

The answer is the rank-and-average method, which is widely accepted³ and effectively represents the random, real-life extremes in average historical weather. This method assigns a temperature to each day of the year that is representative of the average of the coldest (or hottest) days. It is important to highlight that the rank and average method produces a "50/50" forecast. While one may expect this to be a method for forecasting extreme weather conditions, in reality extreme weather *is* normal.

Finally, the accuracy of the peak forecast regression model is good. Based on daily data, it has an R-squared of 77%, and a MAPE of 4.54%.

Peak Forecast Results

Table 9 shows the results of the Regression Forecast of peak loads, as well as the adjustments that are made to arrive at the Adjusted Forecast. The CAGR at the bottom of the table illustrate the trends in each of the columns. Notice that the Regression Forecast itself is flat. After making adjustments for CCHPs, EVs, and net metering, the Adjusted Forecast actually increases by 0.1% per year. Finally, the table shows that the timing of OEM's peak load is forecast to stay in the winter months (December and January) between hour 0800 and 0900.

Table 9: Peak Forecast (MW)


MMM-YY	Peak Hour	Regression Forecast	EV Adjustment	CCHP Adjustment	Net Metering Adjustment	Adjusted Forecast
Dec-20	0800	3.4	0	0	0	3.4
Dec-25	0800	3.4	0	0	0	3.4
Jan30	0900	3.4	0.01	0.1	0	3.5
Jan-35	0900	3.4	0.01	0.1	0	3.5
Jan-39	0900	3.4	0.01	0.1	0	3.5
CAGR		0%	N/A	12.2%	N/A	0.1%

³ For a more in-depth discussion of the method, please refer to Itron's white paper on the topic. <https://www1.itron.com/PublishedContent/Defining%20Normal%20Weather%20for%20Energy%20and%20Peak%20Normalization.pdf>

Village of Orleans - 2019 Integrated Resource Plan

The Adjusted Forecast exceeds the Regression Forecast starting in 2020 due to high CAGRs for CCHPs (12.2%). The net metering program is too small to offset the impacts of EVs and CCHPs because solar panels are just beginning to produce energy at the peak month and hour in this forecast. Notice that the size of the adjustments are small (measured in tenths and hundreds of a MW), and that the peak load forecast starts at 3.4 MW and ends at 3.5 MW. This can be seen in Figure 4, which shows the peak forecast net of adjustments.

Figure 4: Adjusted Peak Forecast (MW)⁴



⁴ A close inspection of this Figure shows that between 2036-2038, the impact of heat pumps and EVs spikes and then returns to the long-term trend line in 2039. This is a result of the peak month shifting from December to January and back to December during those years of the forecast.

Peak Forecast - High & Low Cases

To form a high-case, we assume that neither load controls nor Time-of-Use (TOU) rates are implemented, and then we adopt the same CAGR assumptions from the high case as in the energy forecast. Even under these assumptions, peak load growth does not start to materially impact the system until after 2030. Absent a step change in consumer adoption of CCHPs and EVs, electrification is not likely to produce any peak load growth for the next ten years. However, we will continue to monitor these trends annually during our budget forecasting process.

Table 10: Peak Forecast - High Case

MMM-YY	Peak Hour	Regression Forecast	CCHP Adjustment (MW)	EV Adjustment (MW)	Net Metering Adjustment (MW)	Adjusted Fcst. (MW)
Dec-20	0800	3.4	0.00	0.00	0.00	3.4
Dec-25	0800	3.4	0.00	0.00	0.00	3.4
Jan-30	0900	3.4	0.01	0.10	0.00	3.5
Jan-35	0900	3.4	0.05	0.31	0.00	3.8
Jan-39	0900	3.4	0.21	0.75	0.00	4.4
CAGR		0.0%	24.1%	15.4%		1.2%

A plausible low case for the peak forecast would involve applying TOU electric rates and load control devices on all of the major end uses, especially CCHPs and EVs. In theory, this strategy could completely offset any peak load growth resulting from CCHPs and EVs. As a result, it is not necessary to quantify a low case scenario. Peak loads would simply match the Regression Forecast without any adjustments.

Forecast Uncertainties & Considerations

Despite strong growth in CCHPs and EVs, OED's electricity demand is expected to be quite flat over the forecast period. However, several uncertainties do exist.

Net Metering

OED presently has seven residential scale (< 15 kW) net metered customers with a total installed capacity of about 50 kW. However, as solar net metering costs continue to decline, the cost of net metered solar could reach parity with the price of grid power. If state policy continues to be supportive of net metering in this event, it could lead to a step change in the adoption rate of net metering, and a quicker erosion of retail sales and revenues for the utility.

However, the low case indicates that the adoption rate for net metering would have to increase twofold (from 7.7% per year to 15% per year) before it would negate the sales-increasing impact of CCHPs and EVs. Given the small size of the customer base and the nascent trends involved, net-metering represents a key uncertainty for OED to monitor, especially if larger net metered projects are proposed.


Village of Orleans - 2019 Integrated Resource Plan

For example, a 100 kW net metered solar projects built in 2020 would triple the base of installed, net metered capacity on the system. In this event, the impact would be captured in interconnection and annual power budgeting processes, and managed accordingly.

Ethan Allen

As OED's largest customer, Ethan Allen Furniture is responsible for about 50% of all of OED's load (MWH), and two-thirds of its peak. As a result, it represents a major uncertainty to the load forecast. This can be seen in Figure 5. Ethan Allen's average weekday loads peak near 2 MW most of the year, while OED's load peaks between 2.5 and 3.0 MW. Without Ethan Allen (the yellow dotted line), OED's loads would only reach 1 MW during the winter months.

Figure 5: Average Wednesday Load With and Without Ethan Allen⁵



Because Ethan Allen represents such a large load, we explicitly estimate the impact of its departure in the Resource and Financial Analysis chapters.

⁵ These loads are 3 ½ year averages, from January 2016 to July 2019.

Electricity Supply

II. Electricity Supply

OED's power supply portfolio is made up of generation resources, long-term contracts, and short-term contracts. The portfolio acts as a diversified, financial hedge that buffers OED and its customers from the cost and volatility of buying electricity from ISO New England on the spot market at the Vermont Zone. The following sections describe each of the 8 power supply resources in OED's portfolio.

Existing Power Supply Resources

1. NextEra 2018-2022

OED has a PPA with VPPSA to purchase firm, fixed price energy with NextEra, which provides energy from Seabrook Station, a nuclear facility in Seabrook, New Hampshire. OED has an 8.3% (1.4 MW) share of the on-peak energy and a 7.7% (0.9 MW) share of the off-peak energy, which expires on December 31, 2022. While this resource is not qualified under any state RPS, it is tracked separately due to its carbon-free emission profile. Finally, it represents almost two-thirds of OED's energy supplies in 2020.

2. New York Power Authority (NYPA) - Niagara

NYPA provides power to utilities in Vermont under two contracts: Niagara and St. Lawrence. OED's share of the Niagara facility is 76 kW, and ends on September 1, 2025. We assume that the contract is renewed through 2039. Finally, the Niagara contract energy qualifies as a Vermont RES Tier 1 resource though the resource does not generate marketable RECs at this time.

3. New York Power Authority (NYPA) - St. Lawrence

OED's share of the St. Lawrence facility 6 kW. The contract ends on April 30, 2032 but we assume that the contract is renewed through the rest of the forecast period.

4. Project 10

OED has an agreement with VPPSA to purchase a portion of the power produced by Project 10, an oil-fired peaking generator located in Swanton, VT. OED's share of Project 10's benefits and costs is 7.1%, and we assume that Project 10 is available throughout the forecast period.

5. Public Utilities Commission (PUC) Rule 4.100

OED is required to purchase power from small power producers through Vermont Electric Power Producers, Inc. (VEPP Inc.), in accordance with PUC Rule 4.100. OED's share of VEPP power in 2018 was 0.24%, and the current contracts between VEPP Inc. and its power producers will expire in 2020. We assume that there are no new participants in the 4.100 program for the rest of the forecast period. This is consistent with the relatively recent changes to Rule 4.100 that returned PURPA purchasing obligations to the host utility.

6. Public Utilities Commission (PUC) Rule 4.300

OED is required to purchase power from small power producers through the Vermont Standard Offer Program, in accordance with PUC Rule 4.300. Some of the Standard Offer resources are configured as load-reducers and are not settled in the wholesale markets, resulting in lower reported loads. OED's share of Standard Offer power in 2018 was 0.26%.

7. Ryegate Facility

OED receives power from the Ryegate biomass facility, a 20.5 MW generator in East Ryegate, Vermont. In 2018 OED received 0.256% of the energy from the plant. Under Vermont statutes, Ryegate is the only plant eligible to meet 30 V.S.A. § 8009, and at this time, we have assumed that there may be a renewal of the current contract upon expiration. As a result, we assume that the generator is available throughout the forecast period. Currently OED is entitled to a portion of the RECs produced by the facility.

8. Market Contracts

OED meets the remainder of its load obligations through ISO New England's day-ahead and real-time energy markets, and through contracts (physical and financial) that are less than five years in duration. Market purchases range in size, duration, and counterparty, and are designed to balance OED's supply resources with its load obligations in ISO New England's markets.

Table 11 summarizes the resources in the portfolio based on a series of important attributes. First the megawatt hours (MWH) and megawatts (MW) are shown to show the relative size of each resource. The delivery pattern indicates what time of the day and week the resource delivers energy, and the price pattern indicates how the resource is priced. Notice that most of the resources are fixed-price. This feature provides the hedge against spot market prices. If the resource produces Renewable Energy Credits⁶ (RECs), that is indicated in the seventh column, followed by the resource's expiration date and whether we assumed that it would be renewed until 2039.


⁶ Note that RECs are defined broadly in this table, and that the "emissions attributes" from non-renewable (but also non-carbon emitting) resources such as nuclear are included in this table.

Table 11: Existing Power Supply Resources

Resource	2020 MWH	% of MWH	2020 MW	Delivery Pattern	Price Pattern	REC	Expiration Date	Renewal to 2039
1. NextEra 2018-22	10,119	87%	0.000	Firm	Fixed	✓	12/31/22	No
2. NYPA - Niagara	533	5%	0.092	Baseload	Fixed	✓	09/01/25	Yes
3. NYPA - St. Law.	64	1%	0.004	Baseload	Fixed	✓	04/30/32	Yes
4. Project 10	42	0%	2.744	Dispatchable	Variable		Life of unit.	Yes
5. PUC Rule 4.100	69	1%	0.009	Intermittent	Fixed		2020	No
6. PUC Rule 4.300	392	3%	0.003	Intermittent	Fixed	✓	Varies	No
7. Ryegate Facility	417	4%	0.049	Baseload	Fixed	✓	10/31/21	Yes
8. Market Contracts	3,935	0%	0.000	Firm	Fixed		< 5 years.	N/A
Total MWH	15,570	100%	2.902					

Future Resources

OED will seek out future resources that meet as many of the following criteria as possible. Ideally, future resources will meet four criteria by being low-cost, local, renewable and reliable.

Figure 6: Resource Criteria

- ✓ **Low-Cost** resources reduce and stabilize electric rates.
- ✓ **Local** resources are located within the Northeastern Vermont Development Association (NVDA) area or within Vermont.
- ✓ **Renewable** resources meet or exceed RES requirements
- ✓ **Reliable** resources not only provide operational reliability, but are also owned and operated by financially strong and experienced companies.

These criteria enable OED to focus on subset of generation technologies, and to exclude coal, geothermal and solar thermal generation which do not meet them. Resources that OED may consider fall into three categories: 1.) Existing resources in Table 11, 2.) Demand-side resources, and 3.) New resources.

Category 1: Extensions of Existing Resources

This plan assumes that three existing resources are extended past their current expiration date. These include NYPA, Project 10, and Ryegate. The most crucial of these is Project 10, which supplies over 95% of OED's capacity. Where resource needs remain, market contracts will be used to supply them.

1.1 Market Contracts

Market contracts are expected to be the most readily available source of electric supply for energy, capacity, ancillary services and renewable attributes (RECs). By conducting competitive solicitations through VPPSA, OED can not only get access to competitive prices (low-cost), but it also can structure the contracts to reduce volatility (stable rates) and potentially include contracts for RECs for RES compliance. Market contracts are also scalable and can be right-sized to match OED's incremental electric demands by month, season and year. In many cases, the delivery point for market contracts can be set to the Vermont Zone reducing potential price differential risks between loads and resources. Finally, the financial strength of the suppliers in the solicitation can be predetermined. The combination of these attributes makes market contracts a good fit for procuring future resources.

Category 2: Demand-Side Resources

The lowest cost, most local source of energy is often energy that is conserved or never consumed. As a result, OED will continue to welcome the work of the Efficiency Vermont (EVT) in its service territory. OED will also continue to work with its customers, both large and small, to uncover demand response opportunities. This includes best practices for demand management as OED continues to implement its energy transformation programs under RES.

Category 3: New Resources

VPPSA regularly meets with developers throughout New England, and through VPPSA staff, OED will continue to monitor and evaluate new generation resources in the New England region.

3.1 Wind Generation (On and Off-Shore)

On-shore wind projects continue to be developed in New England, and entitlements to such projects can often be negotiated at competitive prices. RECs are often bundled into the PPA, making this resource a good fit for the low-cost and renewable criteria. Off-shore wind projects are in development, but the costs remain substantially higher than for on-shore wind. As a result, OED would approach such projects with more reserve.

3.2 Gas-Fired Generation

As Project 10 approaches an investment in a major overhaul and the requirements for reserves, voltage support and other ancillary services shift, OED will investigate simple and combined cycle (CC) generation. This includes entitlements to new or existing plants in New England, and to traditional peaking generation which continues to provide reliable peak-day service to the New England region. It should be noted that as a participant in ISO New England's markets, the marginal cost of supply is set by these same resources, and that the benefit of owning an entitlement in one is primarily to reduce heat rate risk.

3.3 Solar Generation

Solar development is increasingly common and cost-effective, particularly at utility scales. Plus, it can be deployed locally. Furthermore, solar is expected to be the primary technology that is employed to meet its Distributed Renewable Energy (Tier II) requirements under RES. For these reasons, solar is likely to be a leading resource option, and OED will continue to investigate solar developments both within its service territory and outside of it.

3.31 Net Metering

While net metering participation rates are presently modest and are forecast to grow modestly, OED will monitor the participation rate closely as solar costs approach grid parity. Should grid parity occur, not only would net metered solar penetration be expected to take off but the costs of the existing program would likely cause upward rate pressure⁷. As a result, net metered solar is an inferior option when compared to lower-cost and utility scale solar projects.

3.4 Hydroelectric Generation

Hydroelectric generation is widely available in the New England region, and can be purchased within the region or imported from New York and Quebec. Furthermore, it

⁷ An excellent discussion of net metering and rate-design policy issues by Dr. Ahmad Faruqui can be found in the October 2018 issue of Public Utilities Fortnightly.

<https://www.fortnightly.com/fortnightly/2018/10/net-metering-faq>

can be sourced from either small or large facilities. Like all existing resources, price negotiations begin at or near prevailing market prices. As a result, existing hydro generation could be both low-cost (or at least at market) and renewable.

3.5 Battery Storage

Any discussion of future resources would be remis without including battery storage. While still in its initial phase of commercialization, there are six use cases where storage is being installed. According to a recent analysis by Lazard⁸, use cases fall into two categories:

1. In-Front-of-the-Meter

- a. Wholesale (Used as a replacement for peaking generation.)
- b. Transmission and Distribution (Used to defer or replace traditional T&D investments.)
- c. Utility-Scale (Solar + Storage)

2. Behind-the-Meter

- a. Commercial & Industrial (Used as a standalone way to reduce demand charges.)
- b. Commercial & Industrial (Solar + Storage)
- c. Residential (Solar + Storage)

All of the In-Front-of-the-Meter use cases are large-scale, and small public power utilities like OED may be best served by participating in such projects as a joint owner or entitlement holder, not the lead participant. However, where local T&D constraints are present or when utility-scale solar plus storage sites are being developed, OED will work through VPPSA to quantify the business case. Similarly, the business case for Behind-the-Meter applications will be quantified as those opportunities are identified.

⁸ For a current analysis and list of use cases, please refer to the "Levelized Cost of Storage Analysis - Version 4.0", Lazard, November 2018. <https://www.lazard.com/perspective/levelized-cost-of-energy-and-levelized-cost-of-storage-2018/>

Regional Energy Planning (Act 174)

As part of the Northern Vermont Development Association (NVDA), OED is part of a Regional Energy Plan⁹ that was certified by the Department of Public Service on June 26, 2018.

According to NVDA's Energy Plan, the aim is "to guide the region's energy development for the next eight years in 24 support of Vermont's 2016 Comprehensive Energy Plan (CEP), which contains the following goals:

- Reduce total energy consumption per capita by 15% by 2025, and by more than one third by 26 2050.
- Meet 25% of the remaining energy need from renewable sources by 2025, 40% by 2035, and 28 90% by 2050.
- Achieve three renewable end-use sector goals for 2025: 10% transportation, 30% buildings, 30 and 67% electric power."¹⁰

The full plan is included in the appendix, and all future resource decisions will be made with this plan in mind. Specifically, OED will consult with the NVDA on resource decisions that involve potential siting of new resource in Vermont.

⁹ The full plan can be found at <http://www.nvda.net/regional-plan.php>.

¹⁰ NEK Regional Plan, Chapter 2: Energy, NVDA 2018, Page 2

Resource Plan

III. Resource Plans

Decision Framework

OED will generally evaluate major policy decisions, such as resource acquisitions, using the integrated financial model developed in this IRP. The primary quantitative evaluation metric will be the impact that a decision has on OED's retail cost of service per kWh over time. (i.e the effect on the rate trajectory)

When evaluating significant decisions, OED will identify the key variables whose potential range of possible outcomes (due to uncertainty) has the largest impact on the retail costs of service per kWh. OED will consider the impacts on potential decisions of changes from the base case assumptions to assist in evaluating the risks associated with the decision. This analysis could include evaluating ranges of potential values for the key variables either via simple replacement of the base assumptions in either the power supply or the integrated financial model as appropriate. Another potential (and similar) evaluation would be to review the decision under extreme (but improbable values) to consider how sensitive the decision is to unexpected outcomes.

Some decisions, such as a simple or short-term resource acquisitions, may not have integrated effects. In such cases, the impact of the resource decision on power costs may be used as a proxy for the relative impact on overall retail costs per kWh.

For example, a simple choice between two resources could be evaluated in this streamlined manner. (Assuming that the resources do not impact non-power supply costs, retail sales volumes, or are not needed under all load forecast cases.) Decisions with small relative impacts may not warrant detailed evaluation at all. It is important to scale the effort spent evaluating a decision, to its potential impact on the utility. Larger decisions that impact power supply costs, as well as non-power-supply costs and/or sales volumes would generally require the use of the full financial model to evaluate.

Any quantified potential impact on rates, determined either through the power supply or integrated financial model, will be considered in conjunction with other metrics that are less easily converted to numerical values in the final decision-making process. Such factors might include resource diversity, risk of fundamental changes in market rules, and other factors.

Major Decisions

As the following sections will explain, OED faces a series of potential risks and accompanying resource decisions that can prudently fulfill its energy, capacity and RES obligations in the coming years. These include:

1. **Extend the NextEra Contract:** The expiration of the NextEra contract on 12/31/2022 not only represents over 80% of OED's energy supply, but also its largest source of emissions free electricity. As a result, the analysis quantifies the cost of a long-term (2023-2039) PPA at the same volumes, but at leveled market prices.
2. **Long-Term Hydro and REC PPA:** The following analysis will illustrate how a 2 MW hydro PPA with Tier I eligible RECs could reduce market price risk and cost.
3. **Long-Term PV and REC PPA:** The following analysis will illustrate how a 0.5 MW PV PPA with Tier II eligible RECs could reduce market price risk.

Energy Resource Plan


Figure 7 compares OED's energy supply resources to its adjusted load. There are two major resource decisions that, in total, will affect about 90% of OED's energy supply between 2020 and 2024. The first is the expiration of the NextEra contract on 12/31/2022, which represents about 65% of OED's energy supply. The second is the expiration of the current market contracts on 6/30/2024, which represent about 25% of OED's energy supply.

Because the continued presence of the Ethan Allen plant's load is a perennial concern, OED does not plan to procure long term resources to hedge it. As a result, these two contracts are likely to be replaced with resources whose term is less than five years in duration. This imparts a great deal of flexibility to choose the type of resource to procure, but also comes with a greater degree of price uncertainty.

Leading options to replace these two contracts include:

- **NextEra:** Renegotiate the NextEra contract and extend its term,
- **Solar:** Sign a PPA for a solar plant to provide energy and Tier II RECs,
- **Existing Hydro:** Signing a PPA for an existing 2+ MW hydro plant to provide energy and Tier I RECs, and
- **Market Contracts:** Signing a PPA for market energy supplies.

Figure 7: Energy Supply & Demand by Fuel Type



Village of Orleans - 2019 Integrated Resource Plan

The impact of these two resource expirations on the portfolio is summarized in Table 12. Because the price of the NextEra contract is presently above the market price forecast, its expiration could potentially reduce rate pressure. It will have no impact on RES compliance, but because it includes emissions free nuclear attributes, it will increase OED's emissions rate if it is not replaced with another emissions free resource. The impact of the market contracts' expiration is not expected to impact rates because they are priced very close to today's market price forecast.


Table 12: Energy Resource Decision Summary

Resource	Years Impacted	% of MWH	Rate Impact	RES Impact
1. NextEra 2018-2022	2023+	65%	Beneficial	None
2. Market Contracts	2024+	25%	Neutral	None

Capacity Resource Plan

Figure 8 compares OED's capacity supply to its demand. Project 10 provides practically all of OED's capacity, with minor contributions from NYPA, Ryegate and the PUC 4.300 program.

Figure 8: Capacity Supply & Demand (Summer MW)



No capacity resource decisions are necessary unless the reliability of Project 10 drops for an extended period of time. As a result, maintaining the reliability of Project 10 will be the key to minimizing OED's capacity costs, as explained in the next section.

ISO New England's Pay for Performance Program

Because OED is part of ISO New England, its capacity requirements are pooled with all of the other utilities in the region. As a result, if Project 10 is not available, OED will be provided with (energy and) capacity by ISO New England. However, ISO New England's Pay for Performance¹¹ (PFP) program creates financial payments (and potential penalties) for generators to perform when the grid is experiencing a scarcity event.

The following table illustrates the range of performance payments that OED's 7% share of Project 10 creates in ISO New England's PFP Program. Depending on ISO-NE's load at the time of the scarcity event and Project 10's performance level, OED could receive up to a \$2,000 payment or pay up to a \$2,000 penalty during a one-hour scarcity event. This represents a range of plus or minus 12% of OED's monthly capacity budget. However, such events are not expected to occur more than a few times a year (if at all), and frequently last less than one hour.

Table 13: Pay for Performance Ranges for One Hour of Project 10 Operation¹²

ISO-NE Load	Performance Payment Rate	0% Performance	50% Performance	100% Performance
10,000	\$2,000/MWH	-\$1,000	\$1,000	\$2,000
15,000	\$2,000/MWH	-\$1,000	\$0	\$2,000
20,000	\$2,000/MWH	-\$2,000	\$0	\$1,000
25,000	\$2,000/MWH	-\$2,000	-\$1,000	\$1,000

¹¹ For an overview of the PFP program, please visit <https://www.iso-ne.com/participate/support/customer-readiness-outlook/fcm-pfp-project>.

¹² Please refer to the following presentation from ISO-NE for the details of how the performance payments are calculated. <https://www.iso-ne.com/static-assets/documents/2018/06/2018-06-14-egoc-a4.0-iso-ne-fcm-pay-for-performance.pdf>

Renewable Energy Standard Requirements

OED's obligations under the Renewable Energy Standard¹³ (RES) are shown in Table 14. Under RES, OED must purchase increasing amounts of electricity from renewable sources. Specifically, its Total Renewable Energy (Tier I) requirements rise from 59% in 2020 to 75% in 2032, and the Distributed Renewable Energy¹⁴ (Tier II) requirement rises from 2.8% in 2020 to 9.4% in 2032. Note that this IRP assumes that both the TIER I and TIER II requirements are maintained at their 2032 levels throughout the rest of the study period.

Table 14: RES Requirements (% of Retail Sales)

Year	Tier I (A)	Tier II (B)	Net Tier I (A) - (B)	Tier III
2020	59%	2.80%	56.20%	2.67%
2021	59%	3.40%	55.60%	3.33%
2022	59%	4.00%	55.00%	4.00%
2023	63%	4.60%	58.40%	4.67%
2024	63%	5.20%	57.80%	5.34%
2025	63%	5.80%	57.20%	6.00%
2026	67%	6.40%	60.60%	6.67%
2027	67%	7.00%	60.00%	7.34%
2028	67%	7.60%	59.40%	8.00%
2029	71%	8.20%	62.80%	8.67%
2030	71%	8.80%	62.20%	9.34%
2031	71%	9.40%	61.60%	10.00%
2032	75%	10.00%	65.00%	10.67%
2033-2039	75%	10.00%	65.00%	0.00%

Under RES, Tier II is a subset of Tier I. As a result, we subtract the Tier II percentage from the Tier I percentage to get the Net Tier I requirement in the fourth column. Notice that the net Tier I requirement declines every 2nd and 3rd year until the Tier I requirement increases. When these percentages are multiplied by the forecast of retail sales, the result is a seesaw effect where the Net Tier I requirement declines every 2nd and 3rd year. This can be seen more clearly in Figure 9 in the next section.

The final column shows the Energy Transformation (Tier III) requirement. Because it is designed to reduce fossil fuel use, the Tier III requirement is fundamentally different from Tier I and Tier II requirements. And unlike the Tier I & II requirements...which count only electricity that is produced and consumed in an individual year¹⁵...Tier III programs account for the "lifetime" the fossil fuel savings. For example, if a Tier III program installs a CCHP in 2020, the fossil fuel savings from that CCHP are counted such that the full ten-years of the CCHP's expected useful life accrue to the 2020 Tier III requirement. For this reason, we do not carry the 2032 requirement into the 2033-2039 period.

¹³ For more information on the RES program, please visit <https://vppsa.com/energy/renewable-energy-standard/>.

¹⁴ Distributed Renewable Energy must come from projects that are located in Vermont, are less than five MW in size, and are built after June 30th, 2015.

¹⁵ For simplicity, we assume that no banking occurs in this example. In practice, banking excess TIER I and TIER II credits for use in future years is permitted under RES.

Table 15: Alternative Compliance Payment¹⁶ (\$/MWH)

Year	Tier I	Tier II & III
2020	\$10.00	\$60.00
2021	\$10.22	\$61.32
2022	\$10.44	\$62.67
2023	\$10.67	\$64.05
2024	\$10.91	\$65.46
2025	\$11.15	\$66.90
2026	\$11.39	\$68.37
2027	\$11.65	\$69.87
2028	\$11.90	\$71.41
2029	\$12.16	\$72.98
2030	\$12.43	\$74.59
2031	\$12.70	\$76.23
2032	\$12.98	\$77.90

The RES statute provides a second way to comply with its requirements, the Alternative Compliance Payment (ACP). In the event that a utility has not achieved the requisite amount of Tier I, II or III credits in a particular year, then any deficit is multiplied by the ACP, and the funds are remitted to the Clean Energy Development Fund (CEDF).


Finally, utilities with a RES deficit may also petition the Public Utilities Commission (PUC) for relief from the ACP. Alternatively, utilities may petition PUC to roll the deficit into subsequent compliance years. As a result, there are multiple ways to comply with RES requirements.

¹⁶ Please note that these are estimates, and grow at inflation.

Tier I - Total Renewable Energy Plan

Between 2020 and 2024, OED's Net Tier I requirement is about 7,200 MWH per year. The only resource that contributes to meeting it is NYPA, and the (minuscule) remainder of PUC's 4.100 program. NYPA represents about 600 MWH per year or 8% of OED's Net Tier I requirement. Through 2024, the Net Tier I deficit is about 6,600 MWH per year.

Figure 9: Tier I - Demand & Supply (MWH)



In the early years of the 2020s, OED is likely to meet its Net Tier I requirements by purchasing Maine Class II (ME II) Renewable Energy Credits (RECs). These are presently the lowest cost source of Tier I compliant RECs in the region, and their price has ranged from a low of \$1.00 to a high of \$2.50 per MWH over the past four years. At the current price of \$1/MWH, the cost of complying with Net Tier I in the 2020 to 2024 period would be about \$10,000 per year.


As mentioned in the Energy Resource Plan, the expiration of the NextEra 2018-2022 PPA creates an opportunity to purchase a resource that provides both energy and RECs. The 6,600 MWH per year deficit is equivalent to a 2.2 MW hydro facility¹⁷, and if the output from a hydro resource of this size and capacity factor was purchased (including RECs), the Net Tier I deficit between 2020 and 2024 would be erased. To fulfill the entire Net Tier I requirement through 2032, a 2.5 MW hydro facility (7,200 MWH per year) would be necessary. This size hydro resource would almost maintain 65% Net Tier I after 2032, and coincidentally, it is also the largest resource that OED could procure on a long-term basis without assuming Ethan Allen's continued operation. As a result, this resource choice is one of the major resource decisions that is analyzed in this IRP.

¹⁷ We have assumed a 33% capacity factor, which results in roughly 6,600 MWH per year.

Tier II - Distributed Renewable Energy Plan

The dashed line in Figure 10 shows OED's Distributed Renewable Energy¹⁸ (Tier II) requirement, which rises steadily from 350 MWH in 2020 to 1,300 MWH in 2032. Between 2020 and 2024, the net metering program (plus a small contribution from PUC's 4.300 Program) is expected to fulfill 14% of OED's Tier II requirement. As a result, another Vermont-based renewable resource(s) will be required¹⁹.

Figure 10: Tier II - Demand & Supply (MWH)



The size of the solar resource that is required to fulfill Tier II starts at 200 kW in 2020 and rises to about 700 kW in 2032. As part of a partnership between VPPSA and Encore Renewable Energy²⁰, OED is planning to enter into a PPA for a share of a 1 MW solar project that is being developed in Jacksonville, VT. In the event that this project is built, OED plans to have enough RECs to fulfill its Tier II requirement in the early 2020s, plus a surplus that can be used toward its Energy Transformation requirement.

A second solar project will be required during the second half of the decade, but we will leave this resource assessment to a subsequent IRP.

In the event that the Jacksonville solar project is not built, then OED will most likely work with other VPPSA members to develop a solar project elsewhere in Vermont. In any years where there is a deficit, OED plans to purchase qualifying RECs to meet its TIER II requirement. In recent years, the cost of these RECs has been 60% to 90% lower than the ACP.

¹⁸ The TIER II requirement is also known as "Tier 2".


¹⁹ We assume that any surplus MWH are not banked, and are instead applied to OED's Energy Transformation requirement.

²⁰ <https://encorerenewableenergy.com/vermont-public-power-supply-authority-and-encore-renewable-energy-partner-to-increase-solar-generation-for-member-communities/>

Tier III - Energy Transformation Plan

The dashed line in Figure 11 shows OED's Tier III requirements, which rise from about 225 MWH in 2020 to about 925 MWH in 2032. Energy Transformation programs are presently budgeted to fulfill about a third of the requirement, and are shown in the gray-shaded area of Figure 11. These programs²¹ cover a range of qualifying technologies including EVs, CCHPs, and HPWHs. For perspective, the Tier III requirement is equivalent to installing 20-50 CCHP²² per year between 2020 and 2025.

Figure 11: Energy Transformation Supplies



OED is expected to have a substantial deficit which is illustrated in Figure 11. This deficit is equivalent to 15 - 30 CCHP's per year or 100 - 300 kW of solar PV.

Alternatively, the deficit could be fulfilled by a custom Tier III project, several of which are already at the discussion stage with OED's largest customer, Ethan Allen.

Yet another source of Tier III MWH is to retrofit 10-20 gasoline golf carts with electric equivalents. According to the Act 56 Tier III Planning Tool, each electric golf cart equates to 2.6 MWH of lifetime savings. Therefore this opportunity represents 26-52 MWH of savings.

Whatever the deficit or surplus position, OED will follow a four-part strategy to fulfill its Tier III requirements.

1. Identify and deliver *prescriptive* Energy Transformation ("Base Program") programs, and/or
2. Identify and deliver *custom* Energy Transformation ("Custom Program") programs, and/or
3. Develop and complete the Jacksonville Solar or a comparable, Vermont-based solar project, and/or
4. Purchase a surplus of Tier II qualifying renewable energy credits.

²¹ More detail on these programs can be found in Appendix B (VPPSA's 2019 Tier 3 Annual Plan) and on VPPSA's website.


²² This estimate is based on 15 MWH/CCHP of net lifetime savings, which is an average of all listed single-zone CCHP measures in the 'Act 56 Tier III Planning Tool FINAL PY2019.xls' spreadsheet.

Carbon Emissions and Costs

Figure 12 shows an estimate of OED's carbon emissions rate compared to the 2018 system average emissions rate in the New England region²³. The emissions rate between 2020 and 2022 is negative, which simply means that OED has more emissions free supply than it needs. This situation arises because Tier I requires OED to be 55% renewable at the same time that the NextEra 2018-2022 contract (which comprises over 80% of OED's energy supplies through 2022) is also delivering emissions-free, nuclear energy from Seabrook Station. The total of the Tier I requirements and the NextEra contract volumes is greater than OED's load.

After this contract expires, carbon emissions increase to 1,233 lbs/MWH because the NextEra MWHs are being supplied by fossil fuels. We assume that the carbon emissions rate of these MWH will be equal to the 2018 NEPOOL Residual Mix which is a proxy for the fossil fuel emissions rate in the region.²⁴

Figure 12: Portfolio Average Carbon Emissions Rate (lbs/MWH)



²³ The source of this data is the NEPOOL GIS. <https://www1.nepoolgis.com/>

²⁴ For the current value of the NEPOOL Residual Mix, please visit <https://www.nepoolgis.com/public-reports/>.


Village of Orleans - 2019 Integrated Resource Plan

The carbon emissions rate starts to decline in 2024 as a result of increasing RES requirements and drops below the system average by 2028. This decline continues until 2032, when the RES requirements end. After 2032, the emissions rate remains stable because this plan assumes that the RES requirements will be maintained.

These emissions rates were multiplied by the Adjusted Load Forecast from Section I. Electricity Demand to arrive at an estimate of carbon emissions in tons per year. The following figure shows that carbon emissions range from zero tons/year in 2020 up to 9,000 tons/year in 2023, and then decline as the RES requirement increase through 2032. Thereafter emissions remain stable, and only rise with load growth.

The costs of these emissions were calculated using two sources, the 2019 Regional Greenhouse Initiative Auction²⁵ (RGGI) results (\$5.45/ton) and the 2018 Avoided Cost of Energy Supply²⁶ (AESC) study (\$100/ton). Using RGGI prices (plus inflation), the cost of carbon emissions in 2023 is \$50,000/year and about \$45,000/year in 2032. Using AESC prices, the range is \$920,000/year in 2023 up to almost \$830,000/year in 2032.

Figure 13: Carbon Emissions (Tons/Year) and Costs (\$)



²⁵ <https://www.rggi.org/auctions/auction-results/prices-volumes>

²⁶ <https://www.synapse-energy.com/sites/default/files/AESC-2018-17-080.pdf>

Conclusions

There are three decisions facing OED that the financial analysis will quantify.

1. Extension of the NextEra PPA

Q1: What are the costs and benefits of extending NextEra volumes through 2039 at leveled market prices?

2. New Long-Term Hydro PPA

Q2: What are the costs and benefits of a 2 MW Hydro PPA at leveled market prices?

3. New Long-Term Solar PPA

Q3: What are the costs and benefits of a 500 kW Solar PPA?

In addition, we quantify two load related questions.

4. Ethan Allen

Q4: What is the rate impact of losing the Ethan Allen load?

5. 1% CAGR

Q5: What is the rate impact of 1% compound annual load growth?

Transmission & Distribution

IV. Electricity Transmission & Distribution

Transmission and Distribution System Description:

Transmission System Description:

Orleans Electric Department (OED), Barton, and VEC jointly-own the transmission line running from the VELCO- Irasburg Substation south to the Barton tap. This line is 336 ACSR and feeds a 5.5-mile line to the Heath Substation located in the Town of Barton on Baird Road. This 5.5-mile 46 kV line feeds both the OED and Barton utilities.

Both utilities, OED and Barton, have secured easements and reconstructed the 46 kV line from Route 16 to Baird Road. This upgrade included a new 46 kV SCADA controlled switch. This line is a radial feed and therefore is an important facility to both utilities. OED started investing in this project in 2008. The initial transmission line was put into service in 2014 and is now fully energized. There were only two outages during the whole construction process. The conductor sizing was done based on the recommendations of the previous T&D study. This was a massive investment for both municipalities and actual costs were significantly under budget.

About 70% of the 46 kV system from Irasburg to Route 16 (H16) (poles anchors, crossarms but not conductor) has been upgraded over the last few years.

Distribution System Description:

The OED distribution system includes 10 miles of line operating at 13.2 kV and 30 miles operating at 2.4 kV. OED continues to work on upgrading the remaining 2.4 kV portions of the distribution system. In some sections the poles and wires have been set in preparation for completing the voltage upgrade. Finalized in 2006, OED completely upgraded its main feeder line from the Heath Substation to the Rainbow Substation.

OED monitors its load balances at a minimum of once a year and sometimes twice a year. This is heavily dependent on Ethan Allen Manufacturing. In recent years OED has upgraded all the infrastructure beyond the Ethan Allen Substation including a voltage upgrade from 2.4 kV to 13.2 kV.

OED-owned Internal Generation:

OED does not own or operate any generation plants within its service territory.

OED Substations:

OED owns and operates three substation facilities. Each substation is briefly described below.

Heath Substation:

Heath Substation is jointly owned with the Barton Electric Department. It has a 10 MVA transformer with a primary voltage of 46 kV and a secondary voltage of 13.2 kV. OED has one feeder line leaving this substation going to OED. A brand-new transformer has been installed and last year grounding grid was installed in the substation. Recently Barton and OED added new regulators and replaced some beams. OED is planning to install oil containment in this substation.

Figure 14: OED's Heath Substation



Rainbow Substation:

Rainbow Substation is located in the OED territory behind the Rainbow Apartments on Church Street. This substation currently has three 333 kVA units feeding the village of Orleans at 2.4 kV. The second bank of transformers feeds the easterly side of the village of Orleans and Maple Street in Orleans. Much of the load has been taken off these transformers through upgrades. Also, in this substation is a bank of 432 kVA regulators on the Ethan Allen circuit. OED upgraded transformers by installing three brand-new 333 kVA units, as the older ones were gassing and therefore needed to be replaced. OED is upgrading voltage outside of the village limits for voltage stability reasons. Currently, there are no voltage stability issues in the village, therefore OED is keeping the 2,400-volt system at this time.

Figure 15: OED'S Rainbow Substation



Ethan Allen Manufacturing Substation:

As the name suggests, the Ethan Allen Manufacturing Substation is the main substation for Ethan Allen Manufacturing. It consists of a 13.2 kV line feeding the substation with primary metering. One bank of 500 kVA transformers feeds the rough mill at 480 volts. A second set of 500 kVA transformers feeds the finish mill. A third set of 500 kVA transformers feeds the maintenance bus and 1,000 amp 480 volt bus next to the rough mill. This substation has had all of the equipment replaced in it over the past ten years and recently OED has been replacing parts of the pole structure in this substation on an annual basis. The pole structure is now fully reconstructed and completed. During Ethan Allen's scheduled annual shutdown in July, OED uses this time to do any necessary, substantial work on this substation. Ethan Allen is the only customer impacted by the shutdown. OED also has a backup transformer in the substation should it ever need one. This substation is fed from the Rainbow substation and the voltage is 13.2 kV with 336 MCM conductor. The distance between both subs is approximately ¼ mile.

Figure 16: OED'S Ethan Allen Manufacturing Substation



Circuit Description:

Table 16: OED Circuit Description

Circuit Name	Description	Length ²⁷ (Miles)	# of Customers by Circuit	Outages by Circuit 2018
Brownington	2/0 circuit protected by line fuses	19	305	1
West Orleans + Irasburg out of town	1/0 circuit protected by line fuses	12	234	3
East Orleans	1/0 circuit protected by line fuses	8	129	3
Ethan Allen	336 circuit with regulators and oil recloser	1	1	1

T&D System Evaluation:

System reliability is important to OED and its customers. OED has a number of initiatives underway to improve reliability. Each of these initiatives is summarized below.

²⁷ Estimated from circuit maps

Outage Statistics

OED tracks all outage statistics as part of its Service Quality Reliability Plan (SQRP). These outage statistics allow us to examine causes by circuit and develop plans for the most cost-effective reliability improvements. The following table summarizes SAIFI and CAIDI results for the past 5 years. OED'S Vermont Public Utility Commission Rule 4.900 Electricity Outage Reports, reflecting the last five years (2014-2018) in their entirety, can be found at the end of this document.

When OED has a planned outage, it notifies its customers at least five days in advance by means of the local newspapers in its service territory: The Chronicle, The Newport Daily Express, and The Caledonia Record. Additionally, OED makes phone calls to businesses, farmers, the Rainbow Apartments, and residential customers on oxygen in order to inform them of the planned outage so that they can arrange for backup.

Table 17: OED Outage Statistics

	Goals	2014 ²⁸	2015	2016	2017	2018
SAIFI²⁹	1.00	0.0	0.0	0.0	0.0	0.0
CAIDI³⁰	1.50	2.4	8.0	2.3	2.4	1.6

Reliability

OED is now putting arrestors after the transformer cut-outs, instead of ahead of them. The method has been proving to be more protective than the old practice of putting arrestors before the transformer cut-outs. The placement of the arrestors has contributed to OED'S system reliability.

Animal Guards

After a few animal contact events each year, OED implemented its policy to install animal guards on all new construction and line rebuilds. In addition, while changing out a number of porcelain cutouts, OED took the opportunity to install animal guards at the same time. OED believes that animal guards are a cost-effective means of reducing animal contact and the associated service interruptions.

²⁸ SAIFI and CAIDI statistics shown are net of major storm outages

²⁹ System Average Interruption Frequency Index

³⁰ Customer Average Interruption Duration Index

Fault Indicators

OED uses fault locators on the 46 kV transmission line to isolate faults and reduce outage time. Fault indicators are not necessary on the distribution system, as these lines are too short.

Power Factor Measurement and Correction

OED'S power factor has historically been approximately 100%. This is due to a capacitor bank that monitors the system's power factor and switches in and out when necessary. It is located at the Ethan Allen Substation. The GE phase 3 meter monitors the power factor as well. The current power factor is near 100%.

Distribution Circuit Configuration

Voltage upgrades

OED'S plan for improving system efficiency is simple: completing voltage upgrades in order to reduce system losses. OED'S long-term strategy is to improve system efficiency by converting the 2.4 kV portion of its system to 13.2 kV. The effort was initiated in 2004 and has continued to this day. The longest distribution lines have been targeted first with the distribution lines in the village being the last.

Phase balancing / Feeder back-ups

Feeder/phase balancing is performed annually on the main line feeding the utility. The three distribution lines feeding Orleans, Maple Street and Brownington are evaluated and tested every two years.

System Protection Practices and Methodologies;

Protection Philosophy

OED'S system protection includes transmission, substation and distribution protection. Each is discussed briefly below.

OED uses station class arrestors in the substations and on the transmission line. It also uses distribution arrestors on equipment in the field. The makeup of these devices is now polymer, not porcelain, for safety concerns. All equipment is also protected with fusing on the high side. OED is now putting arrestors after the transformer cut-outs, instead of ahead of them. The method has been proving to be more protective than the old practice of putting arrestors before the transformer cut-outs.

OED has reclosers at the Heath Substation watching the main line. There is also a recloser at the Ethan Allen Substation that monitors Ethan Allen Manufacturing's load. There are sideline fuses on most lines unless there is a single customer located in a non-wooded area a short distance from the main line. If it's a one-pole spur line, OED does not fuse.

OED reviews fuse coordination and updates configuration on an ongoing, case by case basis, whenever and wherever a change is made to the system. This approach reduces the frequency of full system fuse coordination studies.

Inventory protection:

OED houses all of its wire and transformers at a secured facility.

Voltage Testing:

The existing electric distribution system is performing well. The system's voltage profile to its load center reflects a voltage of 120 volts on a base of 120 volts at peak under current conditions.

OED participates annually in the ISO-NE's voltage reduction tests.

Smart Grid Initiatives

Existing Smart Grid

OED has installed SCADA to its new 46 kV switch and fiber to its 46 kV metering package.

Planned Smart Grid

Beginning in 2018, OED began participating in a multi-phased, VPPSA joint-action project intended to (1) assess individual member readiness for AMI, (2) guide participating members through an RFP process culminating in vendor and equipment selection and (3) guide members through the implementation phase. At the end of the initial assessment phase individual members will make the choice to go forward with the RFP process, or not. Upon completion of the RFP phase of the project, individual members will have the information needed to examine the business case and make a decision to commit to implementation of an AMI system, or not.

At this time OED is participating in the initial readiness assessment phase of the project, gaining information pertaining to its initial readiness, potential required

Vermont Public Power Supply Authority

Village of Orleans - 2019 Integrated Resource Plan

changes to staffing and operating processes, as well as potential benefits to municipal electric, water and wastewater systems. As the assessment phase wraps up later in 2019, OED will decide whether to proceed to the RFP phase of the process.

OED is mindful of the many facets of the evolving grid and their impact on the value of implementing AMI. Advanced metering may play a key role in taking advantage of more sophisticated rate design and load management/retention opportunities as we see continued expansion of net metering, heat pump installations, and adoption of electric vehicles.

OED recognizes the potential value of utilizing rate design, direct load control or other incentive programs as tools to manage both system and customer peak loads in unison to create value for both the utility and the customer. In the absence of an AMI system, or pending development and implementation of an AMI system, OED will explore the use of pilot programs or tariffs that may be implemented using currently available technology. Initial efforts in this area will focus on larger customers with the greatest opportunity to manage loads in a way that will reduce both system and customer costs, capture economic development/retention opportunities and reduce carbon footprint where possible.

Working with VPPSA, Efficiency Vermont, and other stakeholders, OED stays abreast of these developments and the strategies needed to maintain a safe, reliable, and economically viable distribution system.

OED is also mindful of the increasing importance of cybersecurity concerns, and the relationship of those concerns to technology selection and protection. While OED is not presently required to undertake NERC or NPCC registration, VPPSA is a registered entity, and OED'S membership in VPPSA provides OED with knowledge and insight regarding ongoing cybersecurity developments and risks. On a more local level, OED endeavors to purchase and protect its IT systems (with assistance from VPPSA as needed), in a manner intended to minimize security risks to the system and its ratepayers. OED remains mindful of the balance between the levels of cyber security risk protection and the associated costs to its ratepayers.

Other System Maintenance and Operation:

Reconductoring for Loss Reduction

Village of Orleans - 2019 Integrated Resource Plan

OED has been gradually replacing small conductor over the last twenty years and plans to continue to replace small, aged conductors. Most conductor being used now is 1/0 aluminum AAAC.

When evaluating when to replace conductor, OED takes into account the condition of the facilities, system reliability, and the economic cost-effectiveness for the upgrade for ratepayers. The age of the conductor is a proxy for condition and is only part of this analysis.

Transformer Acquisition

For transformers that are equal to or greater than 250 kVA, OED does the analysis that looks at high load losses, low load losses, twenty-five to thirty-year lifecycle in dollars. For transformers that are less than 250 kVA, OED buys second-hand at minimal cost. Many of the municipal utilities sell transforms to each other. This collaborative approach has worked well for OED. While not a formal written village bidding process, when OED goes out to bid, it places at least three bids with GE, ABB, Cooper, and ERMCO. OED uses the Department of Public Service's spreadsheet for determining life-cycle cost of transformers.

Conservation Voltage Regulation

OED does not have conservation voltage regulation. OED'S voltage setting is done with voltage regulators in substations only; voltage is set between 120 and 121.5 volts to provide proper voltage to the first and last customers. OED does not have voltage regulators outside the substations due to the short distance to last customers.

OED also participates in the spring and fall voltage reduction tests.

Distribution Transformer Load Management (DTLM)

OED does not have a formal DTLM program. The biggest concern is that transformers are not overloaded and operating too hot.

Substations within the 100- and 500-YEAR Flood Plains

All three substations are located outside of the 500-year flood plain. None of the substations were affected by the floods of Tropical Storm Irene.

The Utility Underground Damage Prevention Plan (DPP)

As the quantity of OED'S underground lines increase, OED will become increasingly more involved with the Damage Prevention Plan. OED only has approximately 1,500 feet of underground lines. OED has collaborated with the Department of Public Service and VPPSA to develop a draft Damage Prevention Plan and filed it with the Department of Public Service in April 2018.

Selecting Transmission and Distribution Equipment

OED purchases standard certified transmission and distribution equipment from established, trusted vendors. The majority of the equipment is purchased from Wesco. OED prioritizes quality equipment and following utility standards over low purchase prices. Larger equipment, such as transformers, regulators, and trucks, is subject to a bid process.

Maintaining Optimal T&D Efficiency

Substation Maintenance

OED uses infrared analyzers annually to identify hot connections and prioritize maintenance. Additionally, OED utilizes a contractor for oil analysis every other year.

Pole Inspection

OED has first class linemen inspect its entire system once a year. Part of this examination is a pole inspection. This entails a visual inspection for general condition, cracks, shell rot, setting depth, hollow spots and even burnt spots. The age of the pole is also considered. After all of these things have been considered it is then determined which poles in the system need to be upgraded. The targeted pole upgrades typically take place in the nearest construction season. The pole inspection cycle is only one year in length therefore tracking the progress of inspections would be onerous to OED if it were done in a spreadsheet or database. OED inspects the poles on a line-by-line basis and keeps track by flagging the poles. OED also keeps track from an accounting perspective by looking at upgrades that have been put into service. By observing the birth mark, age, and the physical characteristics of the pole, OED determines if and when the pole needs to be replaced.

Equipment

OED annually scans all of its equipment and distribution lines with infrared. The infrared inspection has been enormously valuable to OED in forwarding its goal to provide safe reliable power. OED also performs gas testing regularly on all of its larger transformers and regulators. OED currently relies on an outside service (TCI) to handle all of its cleaning or replacing of PCB equipment.

Actual System Losses

OED is currently replacing its transmission line. Losses were reduced dramatically by eliminating the existing conductor #2A copper clad with new 336 ACSR. OED rebuilt the main line coming into OED and was able to reduce transmission losses through conductor sizing. PLM Engineering performed the loss analysis.

System Maintenance

OED'S system maintenance includes a very active vegetation management plan as well as a scheduled annual system upgrade. OED is a small municipal with one very large industrial customer and resources can be limited at times. OED continues to invest in plant upgrades.

Tracking Transfer of Utilities and Dual pole Removal (NJUNS)

OED does not currently participate in the NJUNS database but will investigate and consider this resource in the future. OED can easily reach Comcast and Consolidated when necessary and vice versa. This system has not proved to be problematic.

Relocating cross-country lines to road-side

OED takes every opportunity during line rebuilds to relocate cross-country lines to roadside. This obviously reduces outages and maintenance costs. Should OED lose its main line it could receive service from a future connection on Route 5 where service territories of Barton and OED meet. The main line is well maintained, and a large amount of vegetative management is performed on it.

Distributed Generation Impact:

Currently, OED has only 7 solar net metering customers, with a combined total installed capacity of 50 kW. This number has been growing very slowly at about 1 customer per year.

Interconnection of Distributed Generation

OED recognizes the unique challenges brought on by increasing penetration levels of distributed generation. OED adheres to the procedures set forth in Rule 5.500 for the interconnection of new generation. Per rule 5.500, a fast track screening process is utilized to expedite the installation of smaller generators which are less likely to result in issues that affect existing distribution customers. If a proposed installation fails the screening criteria, a Feasibility Study and/or System Impact Study is performed to fully identify and address any adverse effects that are a direct result of the proposed interconnection. These studies, performed by OED or their representatives, typically include a review of the following issues that may arise as a result of a new generator interconnection:

- Steady state voltage (per ANSI C84.1)
- Flicker (per IEEE 1453)
- Temporary overvoltage due to load rejection and/or neutral shift
- Effective grounding (per IEEE 1547 & IEEE C62.91.1)
- Overcurrent coordination
- Equipment short circuit ratings
- Effect of distributed generation on reverse power and directional overcurrent relays
- Voltage regulator and load tap changer control settings (bi-directional operation)
- Unintentional Islanding
- Thermal loading of utility equipment
- Power factor and reactive compensation strategy
- Impact to underfrequency load shed
- Increased incident energy exposure (arc flash)

In addition, recognizing that the aggregate of many smaller installations which individually pass Rule 5.500 screening criteria can present problems that would otherwise go unnoticed, OED will maintain detailed records of installed generation including location, type, and generating capacity. This information will allow OED to periodically review how much generating capacity is installed on a particular feeder or substation transformer and identify any concerns as penetration increases over time.

For example, one issue of growing concern is the aggregate of smaller distributed generators being large enough to require voltage sensing on the primary side of substation power transformers for ground fault overvoltage protection. If a transmission (or sub-transmission) ground fault occurs and the remote terminals operate to clear the fault, an overvoltage due to neutral shift can occur when the ratio of generation to load in the islanded portion of the system is greater than 66% (presumes a standard delta primary, grounded-wye secondary substation power transformer). OED continues to monitor trends for interconnection protection for abnormal conditions. Supplementing the process outlined in Rule 5.500 with detailed recordkeeping and periodic reviews of how much distributed generation is installed by feeder will help member utilities identify these types of issues before they occur.

As distributed generation penetration increases within OED'S service territory, OED may consider performing a system-wide hosting capacity study and/or providing hosting capacity maps as a tool to steer development of future medium to large-scale distributed generation to the most suitable locations. This type of hosting study can result in significant up-front costs that must be borne by OED. As a reasonable compromise, OED may suggest that potential developers locate facilities within reasonable proximity to an existing substation and within portions of the system with low penetration levels of existing distributed generation, both of which should increase the likelihood that the facility will be able to successfully interconnect.

Inverter requirements

Consistent with ISO New England requirements related to inverter "ride-through" settings, OED now requires owners/developers of all new DER installations to self-certify installation of inverters compliant with the Inverter Source Requirement Document (SRD) of ISO New England, with settings consistent with IEEE 1547-2018 and UL 1741 SA. This document is included as Appendix E at the end of this document. OED recognizes the need to standardize efforts aimed at certifying inverter compliance with the ISO SRD and will work with VPPSA and the PSD to achieve use of common forms and process in this regard.

Vegetative Management/Tree Trimming:

OED has a very active tree trimming program. It is performed in the springtime as well as in the fall. Line clearing is rotational and typically has a timeline of four to five years. Due to the short length of miles to trimmed and diligent trimming, the growth never gets ahead of OED. OED performs all of the trimming labor itself. OED trains in-house labor and provides safety

Village of Orleans - 2019 Integrated Resource Plan

measures and equipment to workers. OED does not use herbicides in its trimming program and does not plan to change this policy in the near future. About forty percent of OED'S lines need to be trimmed and that number is declining as lines are being moved out to roadside and brush hogs are replacing chainsaws and brush cutters in certain areas. The annual cost of vegetation management is in the range of approximately \$15,000 - \$25,000. OED spent more than budgeted in recent years due to the high number of danger tree needing to be removed and the large amount of cross-country trimming needing to be done. All lines are trimmed to the edge of the legal right-of-way. The trimming width on either side of the line is twenty-five feet.

In addition to its vegetative and brush management program, OED has a program to identify danger trees. Danger trees are identified by all of our utility personnel while patrolling the lines or inspecting the system. Once a danger tree is identified, it is promptly removed if it is within OED'S right-of-way. For danger trees outside of the right-of-way, OED contacts the property owner, explains the hazard, and with the owner's permission removes them. Where permission is not granted, OED will periodically follow up with the property owner to attempt to obtain permission.

The majority of tree species in OED'S service territory are conifers, ash, white birch and maple. The emerald ash borer has very recently become an active issue in Orleans County. OED is monitoring developments and coordinating efforts with VPPSA and VELCO and will make use of any guidance that becomes available as a result. If and when the emerald ash borer does surface in OED'S territory, affected trees will be cut down, chipped and properly disposed of.

Table 18: OED Vegetation Trimming Cycles

	Total Miles	Miles Needing Trimming	Trimming Cycle
Sub-Transmission	Approximately 20 miles	1	7-year average cycle
Distribution	Approximately 37-40 miles	15	5-year average cycle

Table 19: OED Vegetation Management Costs

	2016	2017	2018	2019	2020	2021
Amount Budgeted	\$10,000	\$6,000	\$25,000	\$25,000	\$25,000	\$25,000
Amount Spent (FY)	\$40,000	\$15,000	\$19,500	Deliberately left blank	Deliberately left blank	Deliberately left blank
Miles Trimmed	3	3	3	3 miles to be trimmed	3 miles to be trimmed	3 miles to be trimmed

Table 20: OED Tree Related Outages

	2014	2015	2016	2017	2018
Tree Related Outages	1	0	1	0	1
Total Outages	6	5	7	7	8
Tree-related outages as % of total outages	17%	0%	14%	0%	13%

Storm/Emergency Procedures:

OED believes it is beneficial to inform the Department of Public Service if it is experiencing these types of outages. OED participates in www.vtoutages.com. Having compact utility territories has encouraged a strong collaborative mutual aid system between OED, Barton, and VEC. OED has access to local contractors, such as Bemis Line Construction, Energized Line Construction, and Charles Curtis to rely on if a big storm is forecast to hit OED'S service territory.

Previous and Planned T&D Studies:

Fuse Coordination Study

OED is so small that a fuse coordination study is not warranted and certainly would not demonstrate least cost.

System Planning and Efficiency Studies

OED has implemented many of the goals and recommendations in the transmission and distribution evaluation. The last T&D study was done in 2001 by Robert Arnold, P.E.

There are no more studies planned at this time.

Capital Spending:

Construction Cost (2016-2018):

Table 21: OED Historic Construction Costs

Village of Orleans - 2019 Integrated Resource Plan

<u>Village of Orleans</u>		<u>Historic Construction</u>		
<u>Historic Construction</u>		2016	2017	2018
Line Upgrades -Chandler Ave	Dist	6,695		
Line Upgrade -EA LPD Substation south to end of EA property	Dist	9,085		
Regulator project	Dist	34,006		
Line Upgrade -Royers Farm to Guyette Rd	Dist	18,150		
Line Upgrades-off Church Street	Dist	1,931		
Line upgrade	Dist	1,773		
Line Upgrade-Willoughby Ave	Dist	394		
Misc. plant	Dist	5,306		
46 KV Transmission Line Upgrade-Rt 14-Rt 58 in Irasburg	Trans	56,738		
Digger truck service	Gen		13,445	
Line Upgrade- Thibaults Market	Dist		820	
Line Upgrades-Irasburg	Dist		6,666	
Line Upgrade-Ethan Allen-transformers	Dist		15,031	
Line Upgrades -Brownington	Dist		672	
Line Upgrades -Old Cemetery Lane, Brownington	Dist		3,946	
Line Upgrades -Hinman Setter Rd, Brownington	Dist		12,018	
Line Upgrade-at Elementary School	Dist		1,082	
Line Upgrade-outside of Rainbow sub	Dist		4,015	
Line Upgrade-main pump station & Muni bldng-transformers	Dist		6,146	
Line Upgrade-at joint-sub on Baird Rd.	Dist		2,420	
Line Upgrade-leaving Rainbow sub on distribution	Dist		4,679	
Misc. plant	Dist		509	
46 KV Transmission Line Upgrade-VELCO Irasburg Sub to Rt14	Trans		33,570	
Bucket Truck	Gen			254,736
Upgrade-new line feeding Ethan Allen Warehouse	Dist			10,991
Line Upgrades-Irasburg	Dist			6,593
Line Upgrade- transformers	Dist			29,308
Misc. plant				216
46 KV Transmission Line Upgrade-Barton Hill in Irasburg	Trans			21,329
	Trans			
Total Construction		\$ 134,078	\$ 105,017	\$ 323,173
Functional Summary:				
Production		-	-	-
General		-	13,445	254,736
Distribution		77,340	58,003	47,108
Transmission		56,738	33,570	21,329
Total Construction		134,078	105,017	323,173

Projected Construction Cost (2020-2022):

Table 22: OED Projected Construction Costs

Village of Orleans - 2019 Integrated Resource Plan

<u>Village of Orleans</u>		<u>Projected Construction</u>		
<u>Projected Construction</u>		2020	2021	2022
Upgrade section of line going to Brownington	Dist	20,000		
Change buss in Ethan Allen main Substation	Dist	5,000		
Rainbow Substation upgrade	Dist	5,000		
Jointly-owned 46 kV transmission line	Trans	120,000		
Upgrade more line in Brownington	Dist		20,000	
Jointly-owned 46 kV transmission line	Trans		40,000	
Upgrade more line in Brownington	Dist			20,000
Voltage conversion in Orleans	Dist			50,000
Recloser upgrade in joint substation	Dist			35,000
Total Construction		\$ 150,000	\$ 60,000	\$ 105,000
Functional Summary:				
Production		-	-	-
General		-	-	-
Distribution		30,000	20,000	105,000
Transmission		120,000	40,000	-
Total Construction		150,000	60,000	105,000


Financial Analysis

V. Financial Analysis

Components

The financial analysis represents an integrated analysis of OED's power supply costs and its revenue requirements. The results include the present value of OED's revenue requirements (a proxy for least cost) and the annual change in retail rates. The following figure illustrates the primary components of the analysis.

Figure 17: Primary Components of the Financial Analysis



The power supply cost models consist of four primary spreadsheets that estimate the cost of energy, capacity, transmission, and the costs of complying with the Renewable Energy Standard. The power supply models are monthly, and roll up to annual numbers for integration with the revenue requirements model. The revenue requirements model contains annual estimates of OED's load, revenue, plant accounting activity (including capital expenditures and depreciation), O&M costs, and ultimately, a profit and loss statement. Its outputs are annual revenue requirements, average rates, and the annual change in rates.

Importantly, the power cost spreadsheets are the same models that are used to create OED's annual power cost budget, and are formatted to be consistent with the spreadsheets that are used for monthly budget to actual analysis. As a result, they are operational as well as planning tools.

Methodology

The financial analysis estimates the costs and benefits of three major decisions that were identified in Section III. Resource Plans, and two load-related uncertainties. These include:

Decisions

1. Extension of the NextEra PPA

Q1: What are the costs and benefits of extending NextEra volumes through 2039 at leveled market prices?

2. New Long-Term Hydro PPA

Q2: What are the costs and benefits of a 2 MW Hydro PPA at leveled market prices?

3. New Long-Term Solar PPA

Q3: What are the costs and benefits of a 500 kW Solar PPA?

These decisions all use long-term contracts to hedge OED's energy, Tier I and Tier II/III requirements. This represents a significant departure from the status quo because hedging activity has been limited to five years due to the uncertainty surrounding Ethan Allen's load.

Load Uncertainties

4. Ethan Allen

Q4: What is the rate impact of losing the Ethan Allen load?

5. 1% CAGR

Q5: What is the rate impact of 1% compound annual load growth?

The major event that OED is most concerned with is the loss of Ethan Allen's load, which creates the next question that this section will quantify. This event is quantified in the reference case pathway, but is also quantified in the context of the long-term contracts from above. As a result, this IRP represents a fulsome analysis of the costs and benefits of hedging, both with and without Ethan Allen's load.

Village of Orleans - 2019 Integrated Resource Plan

There are eight possible combinations of the three decisions, as shown in Table 23.

- Pathway 1 is the reference case.
- Pathways 2-4 show the costs and benefits of using long-term contracts to hedge OED's short position in RECs.
- Pathways 5-8 show the cost and benefits of using long-term contracts to hedge OED's short position in RECs and energy.

Importantly, all of these pathways quantify the costs and benefits of long-term hedging, even in the event that Ethan Allen's load drops by 80%.


Table 23: Event / Decision Pathways

Pathway	Name	Extend NextEra PPA to 2039	2 MW Hydro PPA in 2021	500 kW Solar PPA in 2021
1	Reference Case			
2	Hedge Tier I		✓	
3	Hedge Tier II			✓
4	Hedge Tier I & II		✓	✓
5	Hedge Energy	✓		
6	Hedge Energy + Tier I	✓	✓	
7	Hedge Energy + Tier II	✓		✓
8	Hedge Energy + Tier I & II	✓	✓	✓

Village of Orleans - 2019 Integrated Resource Plan

The financial analysis estimates the cost of each of these pathways, and then runs sensitivity analysis on 13 different variables that are known to have a material impact on OED's revenue requirements. Low, base and high ranges were set up using historical data for each of these variables, as shown in Figure 18.

Figure 18: Sensitivity Analysis of Key Variables - Pathway 1 (Reference Case)



Over the 20-year time horizon of the financial analysis, the loss of Ethan Allen's load is expected to be the greatest uncertainty that OED faces, followed by the price of natural gas and pipeline transportation prices. This is expected because most of OED's energy resources are less than 5 years in duration and natural gas prices set the price of electricity in New England.


Load growth is the fourth most important variable, followed by the cost of transmission (aka RNS rate inflation), and the peak coincidence factor. While REC prices do impact the analysis, they are a distant second to the aforementioned variables. Finally, capacity prices are not a major variable in the analysis because Project 10 effectively hedges OED's capacity costs.

Revenue Requirement Results

The high-level results of the financial analysis appear in Figure 19. The first four pathways show the range of results when the NextEra MWH are allowed to expire in 2023.

- **Pathway 1:** This range of outcomes is the reference case and it shows how much variability OED can expect from changes in market conditions over time.
- **Pathway 2:** Both overall cost and the range of costs drop in Pathway 2 because the long-term hydro PPA effectively hedges OED from both energy and REC price risk. While this is a preferred pathway, the outcomes are dependent on negotiating a PPA whose price is at or lower than the leveledized cost of energy plus Tier I RECs in the price forecast.
- **Pathway 3:** The range of Pathway 3 is only slightly narrower than Pathway 1, and it is marginally more costly. This indicates that the 500kW solar PPA does comparatively little to reduce price risk and does not reduce costs.
- **Pathway 4:** Finally, the magnitude of the savings and risk reduction in this pathway is similar to, but slightly higher than Pathway 2.

Figure 19: Scatter Plot of Financial Analysis Results (PV of Revenue Requirement)




Village of Orleans - 2019 Integrated Resource Plan

The lowest cost outcomes, across all pathways, occur when Ethan Allen's load drops by 80%. These outcomes are all in the \$21 million PVRR range and, due to scale, do not appear in Figure 19. Because the size of the hydro and solar PPA's are smaller than OED's loads --- even without Ethan Allen --- the pattern of outcomes in Pathways 5-8 closely reflects the pattern in Pathways 1-4. Namely, the hydro PPA reduces both cost and risk, while the solar PPA does comparatively little to impact the financial results. As a result, these two decisions can be pursued without great concern over Ethan Allen.


Pathways 6 and 8 are particularly interesting. When the NextEra volumes are extended and the Tier I and/or Tier I and Tier II PPA decisions are made in conjunction with the NextEra extension, the range of financial outcomes narrows from the reference case, but the risks that OED faces change as shown in Figure 20. The price of natural gas remains the second largest risk to OED, but its impact on OED's costs is reversed. Higher gas prices lead to lower costs, because OED's energy portfolio becomes net long instead of net short.

Figure 20: Sensitivity Analysis of Key Variables - Pathway 8 (Hedge Energy + Tier I & II)



This impact is summarized in the following figure. Any time the supply of energy is less than the demand, lower market prices also lower OED's cost of service. Conversely, any time the supply is greater than the demand, higher market prices lower OED's cost of service. As a result, the financial impact of supply-demand mismatches are indeterminant, and depend on the market price of energy.

Figure 21: Quadrant Analysis of Market Price & Energy Length Outcomes



Preferred Pathway = Pathway 2 - Hedge Tier I Only


The lowest cost and least risk pathway appears to be Pathway 2 - Hedge Tier I Only. This pathway lowers costs with a long-term hydro PPA that hedges both energy and Tier I risks at the same time. However, the outcome of this strategy depends on OED's ability to negotiate energy, capacity and REC prices that are similar to or less than those that were assumed in this analysis. Similar outcomes can be had by purchasing these products separately, but it is rare to be able to sign long-term contracts for unbundled REC and capacity.

Importantly, similar outcomes can be found in Pathways 4, 6 and 8. Pathway 4 is attractive because it hedges Tier II risk as well as Tier I, and it represents the same set of risks as Pathway 2. Although Pathways 6 and 8 offer similar outcomes, the risks are reversed, and higher energy prices result in lower costs. Given that today's energy prices are near decade lows, these paths may make sense if today's market price environment can be locked in for the longer term.

Ethan Allen's Rate Impact

As Figure 21 shows, the rate impact of losing 80% of Ethan Allen's load is substantial. In the first year after the loss of Ethan Allen, rates would likely have to rise by about 50%. This would raise the average retail rate from about \$0.14/kWh to about \$0.21/kWh. While it does not offset the magnitude of the initial increase in rates, it is worth noting that rates are expected to drop in 2023 after the expiration of the NextEra PPA, whose prices are presently higher than the market price forecast. Thereafter, rate increases are generally inflationary in size.


Figure 22: Rate Impact: Loss of 80% Ethan Allen's Load (Pathway 1 Versus Pathway 5)



Impact of 1% Compound Annual Load Growth (CAGR)

Promoting energy-efficient load growth is an implied goal of the RES's Energy Transformation (Tier III) requirements. This section quantifies the impact that a 1% increase in annual load growth would have on retail rates. As Figure 22 shows, the impact is uniformly to lower rates except in 2023 when the NextEra PPA expires. This is intuitive but is an important outcome to quantify. If this level of load growth were to occur between 2020 and 2032, for example, the 1% compound annual load growth could reduce rates by about 7% in 2032 as compared to the reference case.

Figure 23: Rate Impact of 1% CAGR Load Growth



Summary and Conclusions

The answers to the questions that were posed at the beginning of this chapter are now evident.

Decisions

1. Extension of the NextEra PPA

Q1: What are the costs and benefits of extending NextEra volumes through 2039 at leveled market prices?

A1: Extending the NextEra volumes at leveled market prices does reduce risk and stabilize costs even if Ethan Allen's load declines by 80%.

2. New Long-Term Hydro PPA

Q2: What are the costs and benefits of a 2 MW Hydro PPA at leveled market prices?

A2: The long-term hydro PPA could significantly reduce costs and risks, but only if the leveled costs of energy, capacity and RECs from this PPA are lower than the market price forecast.

3. New Long-Term Solar PPA

Q3: What are the costs and benefits of a 500 kW Solar PPA?

A3: The long-term solar PPA does relatively little to lower risk and costs overall but does hedge Tier II and III requirements.

Load Uncertainties

4. Ethan Allen

Q4: What is the rate impact of losing the Ethan Allen load?

A4: The loss of 80% of Ethan Allen's load could cause a 50% rate increase.

5. 1% CAGR

Q5: What is the rate impact of 1% compound annual load growth?

A5: The impact of 1% CAGR in loads would be to decrease the rate impact in 2032 by about 7% compared to the reference case.

These and other conclusions are carried into the Action Plan in the following section.

Action Plan

VI. Action Plan

Based on the foregoing analysis, we envision taking the following actions.

1. Ethan Allen

- Continue to work with Ethan Allen to reduce their energy costs through energy efficiency and Tier III projects.
- Continue to hedge energy requirements after the NextEra PPA expires, and consider terms longer than 5 years in today's low-priced market environment.

2. Automated Metering Infrastructure (AMI)

- OED will participate in an evaluation of AMI readiness which, if results are positive, will lead to preparation of an RFP leading to vendor and equipment selection and ultimately to implementation of an AMI system. Upon completion of the RFP phase of the project, OED will have the information needed to examine the business case and make a decision to commit to implementation of an AMI system, or not. OED recognizes that cost reduction, while desirable, is but one of many factors that must be weighed in making the decision to go forward with AMI. OED sees the potential for a number of future benefits that, while difficult to quantify in cost/benefit terms, will clearly be desirable to various stakeholders. These benefits include (but may not be limited to) improved system control/optimization, ability to deliver/administer more creative customer and load management initiatives, and ability to accommodate emerging initiatives such as EV charging. OED also notes that unanticipated initiatives may emerge over time that positively impact the perceived value of having an AMI system in place. OED is considering the potential benefit of a staged implementation that would initially focus on limited areas of high load or customer concentration.

3. Energy Resource Actions

- Manage year to year energy market requirements using fixed-price, market contracts that are less than five-years in duration.
- Consider a 2+ MW hydro entitlement that includes bundled energy, capacity, and renewable energy credits to reduce both energy and Tier I costs and risks.

4. Capacity Resource Actions

- Manage and monitor the reliability of Project 10 to minimize Pay-for-Performance (PFP) risk and maximize capacity, reserves, and PFP benefits.

5. Tier I Requirements

- Consider a 2+ MW hydro entitlement that includes bundled energy, capacity, and renewable energy credits to reduce both energy and Tier I costs and risks.
- Make forward purchases of qualifying RECs on the regional market to manage REC price and ACP risk.

6. Tier II Requirements

- Develop and complete the Jacksonville Solar or other comparable, Vermont-based solar projects.
- Make forward purchases of qualifying RECs on the Vermont market to manage REC price and ACP risk.

Vermont Public Power Supply Authority

- Investigate adding battery storage to upcoming solar projects to increase their value and decrease overall project costs.

7. Tier III Requirements

- Identify and deliver prescriptive and/or custom Energy Transformation programs, and/or
- Develop and complete the Jacksonville Solar or other comparable, Vermont-based solar projects, and/or
- Purchase a surplus of Tier II qualifying renewable energy credits.

8. Active Load Control Pilot Program

- Investigate options for engaging customers in active load control programs and tariffs, including end-uses such as electric thermal storage, CCHPs, and HPWHs.

9. Peak Load Management Pilot Program

- Explore ways to align reductions in customer demand charges with utility coincident peak costs through use of a pilot tariff.

10. Net Metering

- Monitor the penetration rate and cost of solar net metering for future grid parity, and advocate for appropriate policies to mitigate potential upward rate pressure.

11. Storage

- Monitor cost trends and potential use cases, and
- Identify Behind-the-Meter use cases and sites, and
- Develop project-specific cost-benefit analysis.

Appendix

Appendix A: NVDA Regional Energy Plan

This appendix is provided separately in a file named:

Appendix A - NVDA Regional Energy Plan.pdf

Appendix B: 2019 Tier 3 Annual Plan

This appendix is provided separately in a file named:


Appendix B - VPPSA Tier 3 2019 Annual Plan.pdf

Appendix C: Pricing Methodology

Energy Pricing

Energy prices are forecast using a three-step method. First, a natural gas price forecast is formed by combining a 3-month average of NYMEX Henry Hub futures prices for the period 2020 to 2021 with the Energy Information Administration (EIA) Annual Energy Outlook (AEO) Henry Hub forecast for the period 2022 to 2039. The forecast of Henry Hub Natural Gas prices can be seen in Figure 23.

Figure 24: Henry Hub Natural Gas Price Forecast (Nominal \$/MMBtu)




Second, we use NYMEX futures prices (between 2020-2021) to find 1.) the cost of transportation (basis) to the Algonquin Hub and 2.) the cost of on and off-peak energy at the Massachusetts Hub (MA Hub). These prices are used to calculate an implied heat rate (MMBtu/MWH) and a spread between on and off-peak electricity prices. These values (sometimes called shapes) are used for the remainder of the forecast period.

Third and finally, we multiply the natural gas price forecast by the implied heat rate to get the on-peak electricity price. From this value, we subtract the spread between the on and off-peak prices to get the off-peak price. The results can be seen in Figure 24.

Village of Orleans - 2019 Integrated Resource Plan

Figure 25: Electricity Price Forecast (Nominal \$/MWH)




Finally, and in keeping with the function of ISO-NE's Standard Market Design, we use a five-year average basis between LMP nodes to adjust the price forecast at the MA Hub to the location of OED'Ss load and resources.

Capacity Pricing

The capacity price forecast is an average of the last three years of actual auction results plus inflation, and it grows from \$4.68 per kW-month in 2023 to \$6.77 per kW-month in 2039. Significant upside price risk does exist, as shown by the Maximum line in Figure 25. This line represents the Forward Capacity Auction Starting Price plus inflation.

Figure 26: Capacity Price Forecast (Nominal \$/kW-Month)



Appendix D: PUC Rule 4.900 Outage Reports

Orleans Electric Department

2014

This report is pursuant to PSB Rule 4.903B. It is to be submitted to the Public Service Board and the Department of Public Service no later than 30 days after the end of the calendar year.

Electricity Outage Report -- PSB Rule 4.900

Name of company	Orleans Electric Department
Calendar year report covers	2014
Contact person	John Morley III
Phone number	802-754-8584
Number of customers	675

System average interruption frequency index (SAIFI) =	0.0
Customers Out / Customers Served	

Customer average interruption duration index (CAIDI) =	2.4
Customer Hours Out / Customers Out	

Outage cause	Number of Outages	Total customer hours out	Note: Per PSB Rule 4.903(B)(3), this report must be accompanied by an overall assessment of system reliability that addresses the areas where most outages occur and the causes underlying most outages. Based on this assessment, the utility should describe, for both the long and the short terms, appropriate and necessary activities, action plans, and implementation schedules for correcting any problems identified in the above assessment.
1 Trees	1	4	
2 Weather	0	0	
3 Company initiated outage	3	18	
4 Equipment failure	0	0	
5 Operator error	0	0	
6 Accidents	0	0	
7 Animals	0	0	
8 Power supplier	0	0	
9 Non-utility power supplier	0	0	
10 Other	0	0	
11 Unknown	2	6	
Total	6	29	

Orleans Electric Department**2015**

This report is pursuant to PSB Rule 4.903B. It is to be submitted to the Public Service Board and the Department of Public Service no later than 30 days after the end of the calendar year.

Electricity Outage Report -- PSB Rule 4.900

Name of company	Orleans Electric Department
Calendar year report covers	2015
Contact person	John Morley III
Phone number	802-754-8584
Number of customers	665

System average interruption frequency index (SAIFI) =	0.0
Customers Out / Customers Served	

Customer average interruption duration index (CAIDI) =	8.0
Customer Hours Out / Customers Out	

	Outage cause	Number of Outages	Total customer hours out	Note: Per PSB Rule 4.903(B)(3), this report must be accompanied by an overall assessment of system reliability that addresses the areas where most outages occur and the causes underlying most outages. Based on this assessment, the utility should describe, for both the long and the short terms, appropriate and necessary activities, action plans, and implementation schedules for correcting any problems identified in the above assessment.
1	Trees	0	0	
2	Weather	0	0	
3	Company initiated outage	4	216	
4	Equipment failure	1	1	
5	Operator error	0	0	
6	Accidents	0	0	
7	Animals	0	0	
8	Power supplier	0	0	
9	Non-utility power supplier	0	0	
10	Other	0	0	
11	Unknown	0	0	
Total		5	217	

Village of Orleans - 2019 Integrated Resource Plan

Orleans Electric Department

2016

This report is pursuant to PSB Rule 4.903B. It is to be submitted to the Public Service Board and the Department of Public Service no later than 30 days after the end of the calendar year.

Electricity Outage Report -- PSB Rule 4.900

Name of company	Orleans Electric Department
Calendar year report covers	2016
Contact person	John Morley III
Phone number	802-754-8584
Number of customers	668

System average interruption frequency index (SAIFI) =	0.0
Customers Out / Customers Served	
Customer average interruption duration index (CAIDI) =	2.3
Customer Hours Out / Customers Out	

	Outage cause	Number of Outages	Total customer hours out	Note: Per PSB Rule 4.903(B)(3), this report must be accompanied by an overall assessment of system reliability that addresses the areas where most outages occur and the causes underlying most outages. Based on this assessment, the utility should describe, for both the long and the short terms, appropriate and necessary activities, action plans, and implementation schedules for correcting any problems identified in the above assessment.
1	Trees	1	11	
2	Weather	0	0	
3	Company initiated outage	4	29	
4	Equipment failure	1	1	
5	Operator error	0	0	
6	Accidents	0	0	
7	Animals	0	0	
8	Power supplier	0	0	
9	Non-utility power supplier	0	0	
10	Other	0	0	
11	Unknown	1	18	
	Total	7	59	

Orleans Electric Department

2017

This report is pursuant to PSB Rule 4.903B. It is to be submitted to the Public Service Board and the Department of Public Service no later than 30 days after the end of the calendar year.

Electricity Outage Report -- PSB Rule 4.900

Name of company	Orleans Electric Department
Calendar year report covers	2017
Contact person	John Morley III
Phone number	802-754-8584
Number of customers	662

System average interruption frequency index (SAIFI) =	0.0
Customers Out / Customers Served	

Customer average interruption duration index (CAIDI) =	2.4
Customer Hours Out / Customers Out	

	Outage cause	Number of Outages	Total customer hours out	Note: Per PSB Rule 4.903(B)(3), this report must be accompanied by an overall assessment of system reliability that addresses the areas where most outages occur and the causes underlying most outages. Based on this assessment, the utility should describe, for both the long and the short terms, appropriate and necessary activities, action plans, and implementation schedules for correcting any problems identified in the above assessment.
1	Trees	0	0	
2	Weather	0	0	
3	Company initiated outage	4	31	
4	Equipment failure	2	10	
5	Operator error	0	0	
6	Accidents	0	0	
7	Animals	0	0	
8	Power supplier	0	0	
9	Non-utility power supplier	0	0	
10	Other	0	0	
11	Unknown	1	0	
Total		7	42	

Orleans Electric Department**2018**

This report is pursuant to PSB Rule 4.903B. It is to be submitted to the Public Service Board and the Department of Public Service no later than 30 days after the end of the calendar year.

Electricity Outage Report -- PSB Rule 4.900

Name of company	Orleans Electric Department
Calendar year report covers	2018
Contact person	John Morley III
Phone number	802-754-8584
Number of customers	667

System average interruption frequency index (SAIFI) =	0.0
Customers Out / Customers Served	

Customer average interruption duration index (CAIDI) =	1.6
Customer Hours Out / Customers Out	

	Outage cause	Number of Outages	Total customer hours out
1	Trees	1	1
2	Weather	2	4
3	Company initiated outage	2	15
4	Equipment failure	2	6
5	Operator error	0	0
6	Accidents	0	0
7	Animals	1	2
8	Power supplier	0	0
9	Non-utility power supplier	0	0
10	Other	0	0
11	Unknown	0	0
	Total	8	28

Note: Per PSB Rule 4.903(B)(3), this report must be accompanied by an overall assessment of system reliability that addresses the areas where most outages occur and the causes underlying most outages. Based on this assessment, the utility should describe, for both the long and the short terms, appropriate and necessary activities, action plans, and implementation schedules for correcting any problems identified in the above assessment.

Appendix E: Inverter Source Requirements

Inverter Source Requirement Document of ISO New England (ISO-NE)

This Source Requirement Document applies to inverters associated with specific types of generation for projects that have applied for interconnection after specific dates. These details will be described in separate document(s). This document was developed with the help of the Massachusetts Technical Standards Review Group and is consistent with the pending revision of the IEEE 1547 Standard for Interconnection and Interoperability of Distributed Resources with Associated Electrical Power Systems Interfaces. All applicable inverter-based applications shall:

- be certified per the requirements of UL 1741 SA as a grid support utility interactive inverter
- have the voltage and frequency trip settings
- have the abnormal performance capabilities (ride-through)
- comply with other grid support utility interactive inverter functions statuses

These specifications are detailed below and are consistent with the amended IEEE Std 1547a-2014.

1. Certification per UL 1741 SA as grid support utility interactive inverters

In the interim period while IEEE P1547.1 is not yet revised and published, certification of all inverter- based applications:

- a. shall be compliant with only those parts of Clause 6 (Response to Area EPS abnormal conditions) of IEEE Std 1547-2018 (2nd ed.)¹ that can be certified per the type test requirements of
UL 1741 SA (September 2016). IEEE Std 1547-2018 (2nd ed.) in combination with this document replaces other Source Requirements Documents (SRDs), as applicable;
- b. may be sufficiently achieved by certifying inverters as grid support utility interactive inverters per the requirements of UL 1741 SA (September 2016) with either CA Rule 21 or Hawai’ian Rule 14H as the SRD. Such inverters are deemed capable of meeting the requirements of this document.

2. Voltage and frequency trip settings for inverter based applications

Applications shall have the voltage and frequency trip points specified in Tables I and II below.

3. Abnormal performance capability (ride-through) requirements for inverter based applications

The inverters shall have the ride-through capability per abnormal performance category II of IEEE Std 1547-2018 (2nd ed.) as quoted in Tables III and IV.

The following additional performance requirements shall apply for all inverters:

- a. In the Permissive Operation region above 0.5 p.u., inverters shall ride-through in Mandatory Operation mode, and
- b. In the Permissive Operation region below 0.5 p.u., inverters shall ride-through in Momentary Cessation mode.

1

7.3 as a proxy, subject to minor

editorial changes.

Consistent with IEEE Std 1547-2018 (2nd ed.) the following shall apply:

- a. DER tripping requirements specified in this SRD shall take precedence over the abnormal performance capability (ride-through) requirements in this section, subject to the following:
 1. Where the prescribed trip duration settings for the respective voltage or frequency magnitude are set at least 160 ms or 1% of the prescribed tripping time, whichever is greater, beyond the prescribed ride-through duration, the DER shall comply with the ride-through requirements specified in this section prior to tripping.
 2. In all other cases, the ride-through requirements shall apply until 160 ms or 1% of the prescribed tripping time, whichever is greater, prior to the prescribed tripping time.
- b. DER ride-through requirements specified in this section shall take precedence over all other requirements within this SRD with the exception of tripping requirements listed in item a. above. Ride-through may be terminated by the detection of an unintentional island. However, false detection of an unintentional island that does not actually exist shall not justify non-compliance with ride-through requirements. Conversely, ride-through requirements specified in this section shall not inhibit the islanding detection performance where a valid unintentional islanding condition exists.

4. Other grid support utility interactive inverter functions statuses

Other functions required by UL 1741 SA shall comply with the requirements specified in Table V. For functions not activated by default, the inverter is compliant if tested to the manufacturers stated capability.

5. Definitions

The following definitions which are consistent with IEEE Std 1547-2018 (2nd ed.) and UL 1741 SA shall apply:

cease to energize: Cessation of active power delivery under steady state and transient conditions and limitation of reactive power exchange. This may lead to momentary cessation or trip.

clearing time: The time between the start of an abnormal condition and the DER ceasing to energize the utility's distribution circuit(s) to which it is connected. It is the sum of the detection time, any adjustable time delay, the operating time plus arcing time for any interposing devices (if used), and the operating time plus arcing time for the interrupting device (used to interconnect the DER with the utility's distribution circuit).

continuous operation: Exchange of current between the DER and an EPS within prescribed behavior while connected to the utility's distribution system and while the applicable voltage and the system frequency is within specified parameters.

mandatory operation: Required continuance of active current and reactive current exchange of DER with utility's distribution system as prescribed, notwithstanding disturbances of the utility's distribution system voltage or frequency having magnitude and duration severity within defined limits.

February 6, 2018

Page 2

ISO-NE PUBLIC

momentary cessation: Temporarily cease to energize the utility's distribution system while connected to the utility's distribution system, in response to a disturbance of the applicable voltages or the system frequency, with the capability of immediate restore

Village of Orleans - 2019 Integrated Resource Plan

output of operation when the applicable voltages and the system frequency return to within defined ranges.

permissive operation: operating mode where the DER performs ride-through either in mandatory operation or in momentary cessation, in response to a disturbance of the applicable voltages or the system frequency.

February 6, 2018

Page 3

ISO-NE PUBLIC **Table I: Inverters' Voltage Trip Settings**

Shall Trip – IEEE Std 1547-2018 (2nd ed.) Category II					
Shall Trip Function	Required Settings		Comparison to IEEE Std 1547-2018 (2nd ed.) default settings and ranges of allowable settings for Category II		
	Voltage (p.u. of nominal voltage)	Clearing Time(s)	Voltage	Clearing Time(s)	Within ranges of allowable settings?
OV2	1.20	0.16	Identical	Identical	Yes
OV1	1.10	2.0	Identical	Identical	Yes
UV1	0.88	2.0	Higher (default is 0.70 p.u.)	Much shorter (default is 10 s)	Yes
UV2	0.50	1.1	Slightly higher (default is 0.45 p.u.)	Much longer (default is 0.16 s)	Yes

Table II: Inverters' Frequency Trip Settings

Shall Trip Function	Required Settings		Comparison to IEEE Std 1547-2018 (2nd ed.)		
	Frequency (Hz)	Clearing Time(s)	Frequency	Clearing Time(s)	Within ranges of allowable settings?
OF2	62.0	0.16	Identical	Identical	Yes
OF1	61.2	300.0	Identical	Identical	Yes
UF1	58.5	300.0	Identical	Identical	Yes
UF2	56.5	0.16	Identical	Identical	Yes

Table III: Inverters' Voltage Ride-through Capability and Operational Requirements

Voltage Range (p.u.)	Operating Mode/Response	Minimum Ride-through Time(s) (design criteria)	Maximum Response Time(s) (design criteria)	Comparison to IEEE Std 1547-2018
V > 1.20	Cease to Energize	N/A	0.16	Identical
1.175 < V ≤ 1.20	Permissive Operation	0.2	N/A	Identical
1.15 < V ≤ 1.175	Permissive Operation	0.5	N/A	Identical
1.10 < V ≤ 1.15	Permissive Operation	1	N/A	Identical
0.88 ≤ V ≤ 1.10	Continuous Operation	infinite	N/A	Identical
0.65 ≤ V < 0.88	Mandatory Operation	Linear slope of 8.7 s/1 p.u. voltage starting at 3 s @ 0.65 p.u.: $T = 3 \text{ s} + 8.7 \text{ s} (V - 0.65)$	N/A	Identical
0.45 ≤ V < 0.65	Permissive Operation a,b	0.32	N/A	See footnotes a & b
0.30 ≤ V < 0.45	Permissive Operation b	0.16	N/A	See footnote b
V < 0.30	Cease to Energize	N/A	0.16	Identical

The following additional operational requirements shall apply for all inverters:

- a. In the Permissive Operation region above 0.5 p.u., inverters shall ride-through in Mandatory Operation mode, and
- b. In the Permissive Operation region below 0.5 p.u., inverters shall ride-through in Momentary Cessation mode with a maximum response time of 0.083 seconds.

February 6, 2018

Page 4

ISO-NE PUBLIC February 6, 2018

Page 5

ISO-NE PUBLIC

Table IV: Inverters' Frequency Ride-through Capability

Frequency Range (Hz)	Operating Mode	Minimum Time(s) (design criteria)	Comparison to IEEE Std 1547-2018 (2nd ed.)
$f > 62.0$	No ride-through requirements apply to this range		Identical
$61.2 < f \leq 61.8$	Mandatory Operation	299	Identical
$58.8 \leq f \leq 61.2$	Continuous Operation	Infinite	Identical
$57.0 \leq f < 58.8$	Mandatory Operation	299	Identical
$f < 57.0$	No ride-through requirements apply to this range		Identical

Table V: Grid Support Utility Interactive Inverter Functions Status


Function	Default Activation State
SPF, Specified Power Factor	OFF²
Q(V), Volt-Var Function with Watt	OFF
SS, Soft-Start Ramp Rate	ON
Default value: 2% of maximum current	
FW, Freq-Watt Function OFF	OFF

2

with unity PF.

Appendix F: One-Line Diagrams

Figure 27: OED One-Line Diagram



Glossary

Glossary

ACP	Alternative Compliance Payment
ACSR	Aluminum conductor steel-reinforced
APPA	American Public Power Association
Barton	Barton Village Inc.
CAGR	Compound Annual Growth Rate
CAIDI	Customer Average Interruption Duration Index
CC	Combined Cycle (Power Plant)
CCHP	Cold Climate Heat Pump
CEDF	Clean Energy Development Fund
CEP	Comprehensive Energy Plan
DPS	Department of Public Service or "Department"
EIA	Energy Information Administration
ET	Energy Transformation (Tier III)
EV	Electric Vehicle
EVT	Efficiency Vermont
HPWH	Heat Pump Water Heater
IRP	Integrated Resource Plan
ISO-NE	ISO New England (New England's Independent System Operator)
kV	Kilovolt
kVA	Kilovolt Amperes
MAPE	Mean Absolute Percent Error
ME II	Maine Class II (RECs)
MVA	Megavolt Ampere
MW	Megawatt
MWH	Megawatt-hour
NVDA	Northeastern Vermont Development Association
NYPA	New York Power Authority
OED	Orleans Electric Department
PFP	Pay for Performance
PUC	Public Utility Commission
PPA	Power Purchase Agreement
R^2	R-squared
RES	Renewable Energy Standard
RTLO	Real-Time Load Obligation
SAIFI	System Average Interruption Frequency Index
SCADA	Supervisory Control and Data Acquisition
TIER I	Total Renewable Energy (Tier I)
TIER II	Distributed Renewable Energy (Tier II)
TIER III	Energy Transformation (Tier III)
TOU	Time-Of-Use (Rate)
VEC	Vermont Electric Cooperative
VELCO	Vermont Electric Power Company
VEPPI	Vermont Electric Power Producers, Inc.
VFD	Variable Frequency Drive
VSPC	Vermont System Planning Committee

1 Chapter Two: Energy

2 I. INTRODUCTION

3 Traditionally, Northeastern Vermont Development Association has approached energy planning
4 from a strictly “supply-and-demand” perspective, and this has generally supported the traditional
5 systems that have continued to meet our regional energy needs. The energy trends of the past decade,
6 however, have presented NVDA with the challenge of addressing a much broader perspective, one
7 that transcends current energy production and usage. During this time, several factors created a
8 contentious climate for the future planning of our energy systems. The region has had to
9 contemplate the effect of utility-scale wind development on our mountains; identify ways to ensure
10 forest sustainability as wood-fuels grow in popularity; and seek means to secure long-term
11 affordability of our energy resources for the general public and business communities. In response,
12 NVDA expanded its approach to energy planning and its role in regional energy policy with the
13 intent of seeking a stronger voice in formulating energy policy for NVDA and its member
14 municipalities.

15 NVDA’s statutory role in energy planning is outlined in V.S.A. Title 24, Chp.117 §4348a (3), which
16 stipulates that a regional plan include:

17 “... an analysis of energy resources, needs, scarcities, costs and problems within
18 the region across all energy sectors, including electric, thermal, and transportation;
19 a statement of policy on the conservation and efficient use of energy, and the
20 development of renewable energy resources; a statement of policy on patterns and
21 densities of land use likely to result in conservation of energy; and an
22 identification of potential areas for the development and siting of renewable
23 energy resources and areas that are unsuitable for siting those resources or
24 particular categories or sizes of those resources.”

25 The approval process for siting energy generation projects is largely under the jurisdiction of Section
26 248 of Title 30. The Vermont Supreme Court has expressly exempted projects subject to Section 248
27 from local permitting. At this time municipalities have only the power to regulate “off-grid”
28 renewables – and must do so in accordance with Vermont Statute.

29 In accordance with Section 248, energy developers must obtain a Certificate of Public Good (CPG)
30 from the Public Utility Commission (PUC) before beginning site preparation or construction of
31 electric transmission facilities, electric generation facilities, and certain gas pipelines within Vermont¹.
32 Prior to issuance, the PUC takes into account the environmental, economic, and social impacts of a
33 proposed facility. Municipalities and other groups are allowed to participate in the Section 248 review
34 process, but many find doing so to be difficult and expensive. Moreover, the PUC is only obligated
35 to give “due consideration” to the recommendations of the municipal and regional planning
36 commission in determining if the project “will not unduly interfere with the orderly development of
37 the region.”² The process has also been complicated by the fact that Vermont statute does not define
38 “due consideration”, nor does it indicate whether the courts or the PUC should be the ultimate
39 arbiter.

40 Previous versions of this plan have been prepared in anticipation of receiving “due consideration” in
41 the Section 248 process. To support the PUC’s consideration, NVDA has defined what constitutes a
42 ‘substantial regional impact’ with regards to development (24 V.S.A. Chp.117 §4345a (17)). This

¹ Vermont Public Service Board. “Citizens’ Guide to the Vermont Public Service Board’s Section 248 Process.

² City of S. Burlington, 133 Vt. at 447, 344 A.2d at 25

1 definition is provided within Land Use section of the *Proposed Regional Plan for the Northeast Kingdom*
2 2018 (Chp.1, pg. 24).

3 [Act 174 of 2016](#) establishes a new set of municipal and regional energy planning standards. If these
4 standards are met, regional and municipal plans may carry greater weight – “substantial deference” –
5 in the Section 248 process. Unlike “due consideration,” “substantial deference” is codified in statute
6 to mean:

7 “...that a land conservation measure or specific policy shall be applied in accordance
8 with its terms unless there is a clear and convincing demonstration that other factors
9 affecting the general good of the State outweigh the application of the measure of
10 policy.”

11 This regional plan has been revised to meet substantial deference under Act 174. It is important to
12 note, however, that substantial deference does not carry the weight of zoning. Projects that fall under
13 the jurisdiction of Section 248 are still exempt from local zoning and permitting. Nevertheless, this
14 plan reflects our attempt to have a greater say in where energy projects should – and should not – be
15 sited, and it is structured as a resource who municipalities who also wish to seek substantial deference
16 for their local plans. Substantial deference is voluntary for municipalities. Duly adopted local plans
17 that do not meet the enhanced energy planning standards of Act 174 but otherwise meet all the
18 requirements of Chapter 117 will continue to receive due consideration from the PUC in the Section
19 248 review process. Whether or not a municipality chooses to pursue substantial deference, it is hoped
20 that this regional plan will help our municipalities to think comprehensively about energy use,
21 resulting in strategies that conserve existing resources and reduce our reliance on fossil fuels.

22 **Strategy Outline**

23 NVDA’s Energy Plan aims to guide the region’s energy development for the next eight years in
24 support of [Vermont’s 2016 Comprehensive Energy Plan](#) (CEP), which contains the following goals:

- 25 • Reduce total energy consumption per capita by 15% by 2025, and by more than one third by
26 2050.
- 27 • Meet 25% of the remaining energy need from renewable sources by 2025, 40% by 2035, and
28 90% by 2050.
- 29 • Achieve three renewable end-use sector goals for 2025: 10% transportation, 30% buildings,
30 and 67% electric power.

31 The basic components of the Energy Strategy are organized into five main sections:

32 **State and Regional Overview**

33 This section provides an estimate of local consumption across the transportation, thermal, and
34 electrical energy sectors.

35 **Generation and Distribution**

36 This section analyzes the existing framework by which our utilities generate and distribute power, as
37 well as legislation and incentives that will impact future generation.

38 **Future Energy Use and 2050 Projections**

39 This section analyzes the ambitious 2050 goals for Vermont’s CEP and how it may impact future
40 energy use in the Northeast Kingdom. Efficiency and conservation are also addressed in support of
41 meeting statewide energy goals.

1 Energy Resource Analysis and Recommendations

2 In this section resources are analyzed for their current and future potential as part of the overall
3 energy portfolio in support of 2050 goals. This section includes a region-wide GIS-based analysis,
4 which identifies potential areas for the development and siting of renewable energy resources, areas
5 that are unsuitable for siting those resources or particular categories or sizes of those resources, and
6 potential generation from siting areas.

7 Regional Goals & Strategies

8 This section identifies the primary regional challenges for meeting 2050 goals and identifies pathways
9 for meeting them.

10 II. STATE AND REGIONAL OVERVIEW

11 Statewide Energy Use

12 Vermont's total energy consumption is the lowest in the nation
13 and has traditionally ranked among the lowest per capita. As of
14 2014, Vermont ranks 43rd in per capita consumption (about 223
15 MM BTUs). However, the state ranks 13th in total energy
16 expenditures per capita (at \$5,225). Throughout the U.S., energy
17 prices are rising due to the stress on traditional resources and
18 increasing consumption levels. To address rising energy costs,
19 Vermonters are turning more and more towards supplemental
20 fuels, renewables, co-generation facilities, and
21 efficiency/conservation efforts.

22 Energy consumption has grown steadily since the 1960s.
23 Historically, leaps in consumption are associated with major
24 economic growth, low energy prices, population growth, and an
25 overall increase in the number of vehicle miles driven. Vermont
26 has limited generation capacity and has relied on Quebec to fulfill
27 part of its energy needs since the early 1980s. With the permanent
28 closure of the Vermont Yankee Nuclear Plant at the end of 2014,
29 the state lost 55% of its generation capacity and now produces less
30 than one-third of the energy it consumes. In addition to Canada,
31 the state relies on the ISO-NE grid for power from neighboring states. Energy use is dominated by
32 transportation and by heating in the frigid winters. About three-fifths of the energy consumed in
33 Vermont are petroleum-based products, which are transported into the state by rail or truck from
34 neighboring states and Canada. The state has limited access to natural gas. There is a natural gas
35 pipeline in the Northeast Kingdom (which is shown on the regional energy maps), but we lack
36 infrastructure to access it. Vermont is the second smallest natural gas consumer per capita, among
37 the states. In 2015, nearly all of Vermont's in-state net electricity generation was produced by
38 renewable energy, including hydroelectric, biomass, wind, and solar resources.³

39 Table 2.1 represents the total primary energy consumption in the state from 2009 to 2014. Petroleum
40 products are by far the leading source of fuel in the state, most of which is used in the transportation
41 and residential heating sectors.

42 What is a BTU?

BTU stands for **British Thermal Unit**, and it is defined by US Energy Information Administration as the measurement of the quantity of heat required to raise the temperature of one pound of liquid water by 1° F at the temperature that water has its greatest density (approximately 39 °F).

Fuels come in a variety of measurements – by cord, by gallon, by kilowatt – so this plan converts units of measurement into BTUs in order to compare their energy output consistently.

One BTU is a minuscule amount, so BTUs are often measured in the thousands, millions (MM BTUs), or even trillions.

Table 2.1: Primary Energy Consumption Estimates, 2009-2014 (Trillions of BTUs)


	2009	2010	2011	2012	2013	2014
--	------	------	------	------	------	------

³ US Energy Information Administration: Vermont State Energy Profile and Estimates

Coal	0.0	0.0	0.0	0.0	0.0	0.0
Natural Gas	8.7	8.5	8.7	8.3	9.7	10.8
Total Petroleum	84.6	81.8	80.2	75.9	79.4	79.5
Distillate Fuel Oil	27.8	26.6	27.7	24.4	25.3	26.5
Jet Fuel	2.9	1.3	1.3	1.3	1.3	1.2
LPG	9.3	9.0	8.3	9.2	10.4	10.1
Motor Gasoline, excluding fuel ethanol	38.0	37.6	36.2	35.1	35.7	35.3
Residual Fuel Oil	1.2	1.0	0.9	0.6	0.8	0.5
Other	5.4	6.3	5.7	5.4	5.9	8.5
Nuclear Electric Power	56.1	50.0	51.4	52.3	50.6	52.9
Hydroelectric Power	14.5	13.1	13.8	10.6	12.3	11.2
Biomass	19.4	19.0	17.2	16.1	20.8	20.3
Solar/PV	0.1	0.2	0.3	0.5	0.7	0.9
Wind	0.1	0.1	0.3	1.0	2.3	3.0
Net Interstate Flow of Electricity	-35.5	-27.4	-30.0	-73.4	-78.3	-76.9
Net Electricity Imports	8.7	8.3	8.6	39.2	40.1	38.1

Source: U.S. Energy Information Administration, State Energy Consumption Estimates, 1960-2014, released June 2016

Figure 2.1 outlines Vermont's energy use by sector between 1960 and 2014. While transportation energy use has grown at a faster pace than any other energy sector since 1960, it has dropped by more than 10% since 2000, most likely a result of an increase in fuel efficiency and conservation efforts. Residential sector consumption has grown by nearly 15% since 1990. Residential fluctuations are considered to be normal - resulting from general population growth, an increase in the average house size, and additional modern conveniences. While the drop from 2005 levels may be attributed in part to the great recession, it may also reflect more efficient building practices, such as more efficient heating equipment and better insulated building shells. According to the Energy Information Administration's 2013 Residential Energy Consumption Survey, U.S. homes built in 2000 and later consume only 2% more energy on average than homes built prior to 2000, despite being on average 30% larger.




- 1 Source: U.S. Energy Information Administration, State Energy Consumption Estimates, 1960-2014
- 2 The industrial sector has seen the most significant decrease in consumption since 2010; however, it is
3 unclear as to how much of this reduction is attributed to new energy efficiency measures employed
4 by manufacturers, reduced production levels, or plant closings in Vermont.

5 Regional Energy Use by Sector

6 Note: The following regional estimates were developed using multiple sources, including the Department of Public
7 Service, American Community Survey, Vermont Department of Labor. For more information about how these
8 estimates were developed, please see Appendix A.

9 According to NVDA
10 estimates, residential and
11 commercial thermal use
12 (heating space and water)
13 is the largest energy use at
14 46%. Transportation⁴ is
15 the second largest energy
16 use in the Northeast
17 Kingdom, accounting for
18 38% of total usage
19 measured in MM BTUs,,
20 followed by electricity at
21 16%. (Figure 2.2)



22 Residential Thermal

23 On average, a Vermont
24 residence uses 110 MM
25 BTUs annually for
26 heating space and water.⁵

27 Annual usage, however, can vary from as low as 70 MM BTUs to 150 MM BTUs, depending on a
28 number of factors such as total square footage, seasonal use, and age of structure. The age of the
29 Northeast Kingdom's housing stock is likely the most significant contributor to the overall usage.
30 According to most recent American Community Survey Five-Year Estimates (ACS), nearly one-third
31 of owner occupied housing units and nearly one-half of renter-occupied housing units were built
32 prior to 1940.⁶ Older homes are likely to be poorly insulated and leakier, driving up consumption
33 and costs.

34 There are 26,133 occupied and heated households in the Northeast Kingdom, which collectively
35 account for more than 3.2 billion BTUs and \$40 million in various heating fuels. (Table 2.2)

Table 2.2: Residential Heating Fuels Used in the Northeast Kingdom						
Fuel Type: Space Heating	Number of Households	Avg. Use (Annual)		Percent of Use: (All HHs)	Percent of Use: Owner	Percent of Use: Renter
Tank/LP/etc. Gas	3,782	3,713,828	Gallons	14.4%	12.4%	21.1%

⁴ Transportation data only includes light-duty vehicles, and commercial transportation data is not available.

⁵ Vermont Department of Public Service. "Guidance for Regional Enhanced Energy Planning Standards" March 2, 2017

⁶ The American Community Survey (ACS) data differs from Census data in that it utilizes annual survey figures, from a smaller cross-section of the population, across a rolling 5-year timeframe to provide data estimates for a given year. The estimates used for this update were from 2011-2015.

Electricity	454	11	GWh	1.7%	0.8%	4.7%	4.0%
Fuel Oil	13,997	9,252,413	Gallons	53.4%	50.6%	62.5%	51.4%
Wood	7,441	36,446	Cords	28.4%	34.1%	10.2%	20.6%
Coal/Coke	115	529	tons	0.4%	0.4%	0.6%	0.5%
Other	344	-		1.3%	1.6%	0.4%	0.0%


Source: NVDA (See Appendix A)

1
2 The region lacks natural gas distribution infrastructure, so oil is the most widely consumed residential
3 heating fuel. Propane -- which is cleaner burning and less expensive than oil but tends to produce
4 less heat per gallon -- is the second most used heating fuel for rental stock.

5 Another contributor to residential thermal usage patterns in the Northeast Kingdom is the high
6 concentration of seasonal homes. According to the 2010 Census, more than one of every five
7 housing units in the NEK is a vacant housing unit intended for "seasonal, recreational, or occasional
8 use". The Vermont Department of Public Service has estimated that "summer" seasonal housing
9 stock -- i.e. lake cottages -- may use as little as 5% of a year-round residential structure, while "winter"
10 seasonal housing -- like in Burke and Jay -- could use as much as 10%. In reality, the seasonal usage
11 lines are blurred, as many communities have seasonal populations that visit throughout the year.
12 NVDA estimates that the region's approximately 8,800 seasonal units accounts for about 45,398 MM
13 BTUs annually in thermal energy.

14 Wood is used by more than one-third of owner occupied homes, but only about one-tenth of renter-
15 occupied homes. Two affordable housing developments in the region use wood pellets -- Maple
16 Street Senior Housing in Hardwick with 16 units, and Mathewson Block in Lyndonville with 6 units.
17 The region's homeowners maintain a strong tradition of burning wood and do so at a much higher
18 rate than the rest of the state. (Figure 2.3). In the late 2000s, instability of fuel prices compelled more
19 homeowners to install wood-pellet stoves and furnaces, as well as outdoor wood boilers for heating
20 water in recent years. Despite a recent drop in fuel oil prices in recent years, combined with a
21 significant shortage of wood pellets during the 2014-2015 heating season, homeowners remain
22 committed to wood. In many cases, fuel oil is actually used as a back-up source to wood.

Figure 2.3: Wood Use in the NEK and Vermont, 2011-2015



23
24 Source: American Community Survey
25
26

Table 2.3: Cost of Fuels, 2011-2016

Types of Energy	BTU/Unit	November 2011			November 2016				High Efficiency \$/MM BTU
		Adj. Effic.	\$/Unit	\$/MM BTU	Typical Effic.	\$/Unit	\$/MM BTU	High Effic. *	
Fuel Oil, gallon	138,200	80%	\$4.08	\$36.89	80%	\$2.23	\$20.14	95%	\$16.96
Kerosene, gallon	136,600	80%	\$4.45	\$40.71	80%	\$2.80	\$25.65		
Propane, gallon	91,600	80%	\$3.37	\$46.05	80%	\$2.54	\$34.64	95%	\$29.17
Natural gas, Ccf	100,000	80%	\$1.78	\$22.22	80%	\$1.41	\$17.67	95%	\$14.88
Electricity, kWh (resistive)	3,412	100%	\$0.16	\$46.37	100%	\$0.15	\$43.46		
Electricity, kWh (heat pump)**	n/a					\$0.15	n/a*	240%	\$18.32
Wood (cord-green)	22,000,000	60%	\$192.03	\$14.55	60%	\$227.00	\$17.21		
Pellets (ton)	16,400,000	80%	\$263.51	\$20.09	80%	\$275.00	\$20.96		

Source: Department of Public Service, Vermont Fuel Price Report (2011 figures are adjusted for Inflation)

* n/a because heat pumps can only burn in one mode.

1
2 Table 2.3 demonstrates the change in heating fuel prices in the last few years. Only the least used fuel
3 – resistance type electricity – has remained stable. Meanwhile the cost of fossil fuels has dropped,
4 while the cost of wood has risen slightly. When oil prices were high, many NEK residents turned to
5 alternative fuels, especially wood pellets, which are cleaner burning, more efficient than cord wood,
6 and relatively easy to use. Stoves and furnaces can be controlled by a thermostat. Their prices have
7 remained relatively stable, although there have been some shortages in recent heating seasons. Wood
8 pellet stoves and furnaces may be a significant investment for most homeowners, so they have
9 continued to use pellets even after the price of heating oil dropped.

10 In 2015 the Vermont Fuel Price report was amended to account for “High Efficiency” ratings of
11 furnaces, which are manufactured to meet higher efficiency standards can result in savings on energy
12 for the customer.

13 Heat Pump Technologies:

14 The Fuel Price Report now includes information on electric-powered heat pump systems, which can
15 deliver up to three times more heat energy than the energy required to operate them. This high return
16 rate – called a coefficient of performance (COP) – offsets the increased electricity usage. All air –
17 even frigid Vermont winter air – contains a significant amount of heat energy. The air source heat
18 pump captures the heat energy from the outside, compresses it, and circulates it into the house at a
19 high temperature. (In hot summer months, the technology operates in reverse, acting as an air
20 conditioner.) Because a heat pump *transfers* heat rather than *generates* it, it requires significantly less
21 energy to operate than a traditional electric, propane, or oil system.

22 Geothermal or “ground source heat pump systems” operate on the same principle: They extract
23 natural low-temperature thermal energy from the ground during colder months for heating, and
24 transfer thermal energy from the building to the ground in warm months for cooling. A geothermal
25 system in Vermont can save roughly \$1,000 to \$2,000 annually in heating costs and have a “simple
26 payback time” of between 10-20 years. This technology operates much like a refrigerator, utilizing a
27 heat pump, heat exchanger, and refrigerant.

1 There are two main types of geothermal systems, open-loop and closed-loop. Open-loop systems
2 utilize a deep rock well or pond to draw water to the heat exchanger where heat flows from the water
3 into cold refrigerant. The refrigerant is then compressed, which greatly raises its temperature and
4 converts it to vapor. Refrigerant vapors then transfer heat to water in a second heat exchanger that is
5 then circulated to heat the building. The process operates in reverse for cooling. Closed-loop systems
6 are slightly different in that they utilize piping in the ground or a pond that can be placed closer to
7 the surface, but then require refrigerant or water with antifreeze to circulate in the piping.

8 Open-loop systems are more efficient than closed-loop systems and are often cheaper to install
9 because they require less excavation. Open-loop systems are also a good fit for Vermont, since
10 standing column wells can be constructed virtually everywhere. While existing well systems can have
11 geothermal systems installed, installation of this technology is often cheapest during construction of a
12 new building and development of a new well site. A geothermal well resource map is provided at the
13 end of the chapter and identifies existing wells with a high potential for geothermal heating and
14 cooling applications.

15 Traditionally, geothermal systems have been more efficient than air-sourced heat pumps (ones that
16 just utilize outside air), because the ground/well source systems can take advantage of relatively
17 constant temperatures below the frost line. In recent years, however manufacturers have developed
18 air-sourced “cold climate” pumps that operate more consistently over Vermont’s vast temperature
19 ranges. Unlike geothermal units, they do not require excavation or duct work and can be much less
20 expensive to install. Cold climate heat pumps have the capacity to heat about 50% to 70% of a
21 building, depending on the size and layout of the structure. Older homes with multiple ells or wings
22 may be difficult to heat with heat pumps alone, but the pumps may be effective for boosting colder
23 underserved zones. They also may be useful in outdoor workspaces. Despite recent improvements in
24 effectiveness on cold days, a backup heating source is usually required for sub-zero temperatures.

25 **Commercial/Industrial Thermal**

26 Most of the region’s commercial/industrial energy usage can be attributed to space heating and
27 process heating. Table 2.4 identifies average heating load per establishments and total MM BTUs
28 consumed annually⁷. Heating loads vary significantly and may be highly specific to type of industrial
29 processes. NVDA’s estimates were developed using assumptions about business patterns. For
30 example, types of businesses that tend to employ more workers per establishment can be expected to
31 be the larger consumers of heat energy – schools, hospitals and clinics, hotels and restaurants. On the
32 other hand, businesses that have few on-site employees – like real estate agencies – use significantly
33 less.

34 To combat high heating costs,
35 RadianTec, a radiant-floor heating
36 manufacturing company in Lyndon,
37 utilizes solar hot water panels and passive
38 solar design to reduce their heat loads.
39 Other commercial operations and
40 institutions have turned to wood. Wood
41 chips - either bole chips or whole tree
42 chips - are well suited for combustion to
43 supply heat, hot water, or steam in
44 institutional, commercial, and industrial
45 settings. The Vermont Fuels for School
46 Program has been very successful

Table 2.4: Commercial Thermal Energy Use			
	# of Commercial Establishments	Average Heating Load (MMBTUs)	Total MMBTUs
Caledonia	722	829	598,292
Essex	103	1,118	115,174
Orleans	631	833	525,708
TOTAL	1,456	851	1,239,174

Source: Department of Public Service, Vermont
Department of Labor

⁷ Vermont Department of Public Service. “Guidance for Regional Enhanced Energy Planning Standards”
March 2, 2017

1 implementing wood heating in schools. Six schools in the Northeast Kingdom currently heat with
2 wood: Burke Mountain Academy, Craftsbury Elementary, Danville School, Hazen Union School, and
3 Lyndon Town School currently heat their facilities with wood. Ryegate and Groton students attend
4 the Blue Mountain School in Wells River, which has been heated with wood chips since 1998.

5 Industrial and commercial enterprises in the state are also moving towards wood-based heating
6 systems, and in some cases co-generation. In the Northeast Kingdom, the North Country Hospital,
7 and Lyndon Furniture utilize wood-chip Combined Heat and Power (CHP) systems to meet partial
8 heat and power needs.

9 **Thermal Efficiency and Weatherization**

10 Regional thermal efficiency and weatherization efforts are spearheaded through four organizations:
11 **Efficiency Vermont, Northeast Employment and Training Organization (NETO), 3E**
12 **Thermal, and Heat Squad.**

13 Efficiency Vermont, the energy efficiency utility for the state, was established by the Vermont Public
14 Service Board in 1999. The utility is funded by an energy efficiency charge on consumer electric bills,
15 similar to a system benefits charge. Efficiency Vermont offers energy and money-saving programs to
16 consumers that allow them to install and use energy-efficient construction designs, products and
17 equipment. They also offer low-income energy assistance programs.

18 NETO was incorporated in 1978 as a 501(c)3 agency for the purpose of delivering weatherization
19 programs to low income residents of the Northeast Kingdom. NETO receives most of its funding
20 from the State of Vermont Weatherization Program and receives additional funding from the
21 Department of Energy. Residents who do not qualify for low-income weatherization assistance can
22 still contact NETO for energy audits.

23 3E Thermal (formerly known as Vermont Fuel Efficiency Partnership) is a statewide program that
24 provides consulting, technical support, and incentives to owners of affordable apartment housing.
25 Since 2010, 3E Thermal has collaborated on several multifamily energy-improvement projects
26 around the NEK, representing a total of more than 250 apartments, each saving more than 6,000
27 MMBTUs annually. 3E is funded by a thermal efficiency fund created by the legislature that uses
28 revenues from the regional Greenhouse Gas Initiative, a cape-and-trade system covering nine states
29 in the Northeast, and the forward-capacity market, where Efficiency Vermont sells future electric
30 savings through ISO-New England.

31 Heat Squad, an energy efficiency organization, founded by NeighborWorks of Western Vermont, is
32 actually based in the Rutland area. However, in August of 2017, Heat Squad received \$250,000 in
33 grant funding from the Northern Border Regional Commission to expand their services to the
34 Northeast Kingdom. The expansion is expected to result in 233 home energy retrofits over the next
35 three years.

36 According to Efficiency Vermont, 6,061 efficiency projects have reduced thermal energy
37 consumption in the Northeast Kingdom by more than 37,000 MM BTUS annually. (Table 2.5)

38 The Vermont Department
39 of Public Service seeks to
40 optimize thermal
41 performance on all new
42 residential and commercial
43 construction through the
44 enforcement of energy
45 codes. Although codes have

Table 2.5: Thermal Savings in the NEK (MM BTUs), 2014-2016				
	2014	2015	2016	Total
Residential	2,986	1,774	2,722	7,481
Commercial & Industrial	3,015	19,982	6,590	29,587
TOTAL	6,001	21,756	9,312	37,069

Source: Vermont Energy Investment Corporation

46 been in place since the late 1990s, they have not always been enforced consistently. In 2013, the
47 Vermont legislature passed Act 89, which ties documentation of compliance with energy codes to the

1 local zoning process. Zoning administrators are now required to provide all applicants with
2 Residential Building Energy Codes (RBES) and Commercial Building Energy Codes (CBES). If a
3 municipality issues a certificate of occupancy, the developer must produce certification of compliance
4 with the codes. Act 89 also authorizes the Department of Public Service to adopt “stretch” codes
5 that exceed baseline efficiency, and municipalities have the option to adopt these codes as they
6 become available. The Department of Public Service adopted a stretch code for RBES, and a stretch
7 code for CBES is in development. The Natural Resources Board presumes compliance with stretch
8 codes to meet the energy efficiency criterion of the Act 250 review.

9 **Transportation**

10 The EIA estimates that statewide, the transportation sector alone consumes about three-fifth of all
11 petroleum products, mainly because rural residents drive long distances to work and errands.
12 Regional estimates show transportation to be the second-largest overall energy use, and this estimate
13 does not even include commercial and industrial vehicles. While Vermont ranks 50th in carbon
14 dioxide emission, transportation accounts for more than half of all greenhouse gas emissions.

15 Energy use in
16 transportation is most
17 greatly influenced by the
18 development patterns of
19 the region. Given that the
20 Northeast Kingdom
21 consists of a rural
22 landscape with small
23 pockets of concentrated
24 development, there are
25 minimal avenues in which
26 energy consumption as
27 part of the transportation
28 sector can be effectively
29 reduced. Long commutes
30 and incidental trips require
31 NEK residents to drive an
32 average of 14,000 miles per
33 year, collectively
34 accounting for more than
35 693 million vehicle miles
36 travelled, which represents

37 nearly \$71 million in fuel costs. (Table 2.6) Nearly all of this energy is non-renewable. Ethanol
38 currently accounts for the vast majority of renewable transportation energy use – about 6.5% of total
39 BTUs – while electricity accounts for a mere .03%.

40 Plug-in electric vehicles (EVs) have the greatest potential to reduce Vermont’s statewide greenhouse
41 gas emissions. “Refueling,” which is as simple as plugging into an electric outlet, costs the equivalent
42 of about \$1.00 per gallon. According to Vermont Energy Investment Corporation, there are 1,595
43 EVs registered in Vermont as of April 2017, marking a 37% increase from the previous year.

44 There are two types of EVs:

- 45 • **All-Electric Vehicles (AEVs):** An AEV can range as far as 80 miles on a single charge, but
46 on very cold days, this range can be cut in half. AEVs are therefore best used as a second
47 car.

Table 2.6: Transportation Energy Use in the Northeast Kingdom

Total Light Duty Vehicles	49,676
Total Internal Combustion Engine (ICE) Vehicles	49,542
Average Miles per gallon for ICE	22
Average annual Vehicle miles travelled ICE	14,000
Total annual VMTs ICE	693,588,00
Total Gallons ICE	31,526,727
Trillion BTUs, Fossil fuel	3.5
MM BTUs, Ethanol	240,357
Trillion BTUs Total ICE	3.7
Total Electric vehicles (EVs) (as of Jan. 2017)	134
Average annual VMT for EVs	7,000
Total annual VMTs for EVs	938,000
Average fuel economy for kWh	3
Total kWh for EVs	312,667
MMBTUs for EVs	1,067

Sources: American Community Survey, Department of Public Service, and NVDA estimates.

- 1 • **Plug-in Hybrid EVs (PHEVs):** A PHEV generally does not range as far as an AEV, but it
 2 can switch over to gasoline when the battery charge runs low, making it a more likely choice
 3 for those with longer drives and greater distance from public charging stations. About 75%
 4 of EVs registered in Vermont are PHEVs.

5 Not surprisingly, Chittenden County has the highest concentration of EVs on the road – about one-
 6 third of all EVs in the state. Nevertheless, Northeast Kingdom residents are beginning to use them as
 7 well. As of January 2017, there were 134 EVs registered in the region. The highest use is found in the
 8 region’s population centers – St. Johnsbury, Lyndon, Hardwick, Derby, and Newport. There are
 9 three EV dealerships in the region – Lamoille Valley Ford in Hardwick, and Twin State Ford and
 10 Quality Mitsubishi, both in St. Johnsbury. A limited number of public charging stations have been
 11 established around the region (Table 2.7), and more will be needed to support expanded EV use,
 12 particularly if more drivers switch to AEVs. All but two of the existing public charging stations are
 13 level 2, which can be ideal when a driver can park for at least an hour for work, shopping, or dining.
 14 A level 2 is about six times faster than a level 1, which requires several hours of charge time. Only
 15 one location currently offers a DC fast charge, which can provide up to 80% battery charge in only
 16 20 minutes. Unfortunately, many hybrids are not equipped to connect to the DC fast charge.

Table 2.7: Public Charging Stations for EVs in the Northeast Kingdom

Town	Location	Charge Type
Barton	Barton Village Offices	Level 2
Danville	Marty's First Stop	Level 2 and DC fast
Derby Line	Derby Line Unitarian Universalist Church	Level 2
Hardwick	Lamoille Valley Ford	Level 2
St. Johnsbury	Twin State Ford	Levels 1 and 2
St. Johnsbury	Pearl Street Parking Lot	Level 2
St. Johnsbury	Northeastern Vermont Regional Hospital	Level 2

Source: US Department of Energy's Alternative Fuel Locator

Ethanol, currently the primary source of renewable fuels for light-duty transportation vehicles, can be blended up to 10% with gasoline to form E10. It can be

29 used in any engine that takes regular gasoline. Corn is the most common element used to produce
 30 ethanol, even though it can be produced from a variety of elements, including wood. Ethanol burns
 31 cleaner than gasoline and is very effective in lowering fuel emissions. Unfortunately, the fuel also has
 32 significant problems in cold-weather, which make it less useful for Vermont’s climate. While E10 is
 33 required in many urban areas that do not meet federal air emission guidelines, this is not the case in
 34 Vermont. Many of the blends available in this area are 9% ethanol.

35 One area in which Vermont is seeing growth in fossil fuel usage is via compressed natural gas. With a
 36 reduction in natural gas prices, compressed natural gas is now economical for large industrial
 37 applications (utilizing over 150,000 gallons fuel oil annually) and as a transportation fuel. Both the
 38 Burlington Department of Public Works and Vermont Gas maintain vehicle fleets fueled with
 39 compressed natural gas. Liquified petroleum gas (LPG) can also be used a transportation fuel and
 40 produces fewer CO2 tailpipe emissions than conventional gasoline-powered vehicles. The region has
 41 one LPG fueling station at the Pick and Shovel in Newport.

42 Price volatility of gasoline in the first half of the past decade helped to spur an interest in the
 43 development of biofuels. Biodiesel is commonly made from soybeans, rapeseed (canola), and
 44 sunflowers; all of which can be grown in Vermont. Biofuel can be blended with diesel up to 5% (B5)
 45 to be safely used for on-road vehicles. Higher blends, including pure biodiesel (B100) can be used in
 46 off-road equipment and farm vehicles, although farm equipment manufacturers have approached the
 47 use of biodiesel with caution. Black Bear Biodiesel, located just outside of the region in Plainfield, is a
 48 B100 fueling station.

1 Research has found that oilseed crops, when grown in rotation with other crops, can help to support
2 sustainable, diversified, and profitable agricultural enterprises. The Vermont Bioenergy Initiative, a
3 program of the Vermont Sustainable Jobs Fund, provides early-stage grant funding, technical
4 assistance, and loans to producers. Currently North Hardwick Dairy produces oilseed crops for use
5 as fuel and food-grade. Although the recent drop in fuel prices has reduced some incentive for
6 farmers to enter biofuel production, NVDA encourages further innovation and research into this
7 area as a long-range economic opportunity.

8 Commercial shipping is one of the highest consumers of transportation fuels and another area in
9 which the region can reduce consumption. As gas prices started to climb in the past decade area,
10 businesses looked for alternative shipping methods and inquiries into the region's rail infrastructure
11 grew. Railroad shipping is most desirable for non-perishable commodity goods. Upon further review
12 it was found that regional rail infrastructure has the potential for growth, with room for increased
13 traffic and a number of underutilized sidings. The Kingdom may also be able to attract additional rail
14 usage if rail beds are upgraded to meet the 286,000 lb. weight limit standard and bridge heights are
15 increased. Both improvements will allow rail cars to be filled to capacity and allow for the double
16 stacking of rail cars, which is now standard across the country. NVDA also supports the re-
17 establishment of the Twin State Line as a means to better connect the Kingdom with greater rail
18 markets in New England.

19 Development Patterns and Transportation Use

20 Understandably rural development patterns directly impact transportation energy usage, especially in
21 regards to individual behaviors. With limited transit infrastructure, the region is dominated by single-
22 occupancy light-duty vehicles. Residents typically commute to disparate labor market areas, reducing
23 opportunities for carpooling. VTrans offers grant assistance to municipalities who wish to establish
24 park and rides on municipal, state, or leased property on or near state highways. Mixed-use, higher
25 density neighborhoods encourage more pedestrian use. The following land use principles encourage
26 reduced transportation energy consumption⁸:

- 27 1. Encourage the location of new development in or near traditional village and city centers to
28 reduce both sprawl and the number of vehicle miles driven.
- 29 2. Support transit-oriented development that fosters the expansion of public transportation and
30 rail use.
- 31 3. Encourage the construction of Park and Ride facilities to support carpooling efforts.
- 32 4. Encourage the expansion of bicycle and pedestrian facilities such as sidewalks and bike lanes.

33 Additionally, improved telecommunications infrastructure in this region has the potential to reduce
34 annual VMTs by allowing more workers to telecommute.

35 Electricity Use

36 With respect to simply how much electricity is generated here relative to what is consumed, the
37 Northeast Kingdom is a net exporter of energy. This is a major shift from more than a decade ago,
38 when the region relied heavily on Canada, New Hampshire, and the rest of Vermont to meet its
39 electricity demand. In 2016, the total electric usage for the region was 436,355 MWHs, representing a
40 total of roughly 1.48 trillion BTUs. (Table 2.8). Despite the increase in customer counts in the C&I
41 sector since 2014, total usage dropped by .4% over the same period. The number of residential
42 customers increased slightly over the same period, but total residential usage decreased by a fraction

⁸ See the Transportation, Land-Use, and Housing Sections of the *Regional Plan for the Northeast Kingdom* for additional energy-related recommendations.

1 of a percentage point, as did the average residential usage. Similar data on average commercial and
2 industrial use is not available.

3 Although the commercial and
4 industrial sector only accounts
5 for about 15% of all electrical
6 utility customers, they
7 account for slightly more than
8 half of all usage. Electric costs
9 are a major factor in attracting
10 and retaining major
11 commercial/industrial
12 operations in the region. New
13 England retains the highest
14 electric costs in the lower 48
15 states for both sectors. In

Table 2.8: Annual Electricity Use in the NEK			
Usage by Sector (In MWhs)	2014	2015	2016
Commercial & Industrial	221,395	229,877	220,313
Residential	216,757	218,962	216,042
Total	438,152	448,840	436,355
Avg. Residential Use (in KWHs)	6,323	6,372	6,295

Count of Customer Premises (Customers)			
Sector	2014	2015	2016
Commercial & Industrial	5,808	5,871	5,977
Residential	34,279	34,363	34,317
Total	40,087	40,234	40,294

Source: Vermont Energy Investment Corporation

16 April 2017, the state's average electric retail price was 14.14 cents/kWh in the commercial sector and
17 10.12 cents/kWh in the industrial sector. These rates are the second lowest in the New England, but
18 still considerably higher than national rates of 10.38 cents/kWh and 6.63 cents/kWh respectively
19 (U.S. Energy Information Administration, Electric Power Monthly). When most large manufacturers
20 are speaking in terms of megawatt-hours (thousands of kilowatt-hours) for power consumption,
21 those price differences are considerable. The former Dirigo Paper Mill utilized on-site hydro and
22 waste steam for electrical generation. Ampersand Gilman Hydro continues to operate the site. Ethan
23 Allen has studied the feasibility of a combined heat-and-power plant with Orleans and Barton
24 Electric for their Orleans facility; and Lyndon Furniture in St. Johnsbury has employed a diesel-
25 fueled electric generator to stabilize their electric costs for several years.

26 According to Efficiency Vermont, 6,061 efficiency projects have achieved savings electrical use in the
27 Northeast Kingdom by 82,324 MM BTUs from 2014 to 2016. (Table 2.9).

Table 2.9: Electricity Savings Achieved in the NEK, in MWh

Sector	2014	2015	2016	Total
Residential	2,951	3,569	3,286	9,806
Commercial & Industrial	3,953	5,178	4,990	14,122
Total	6,904	8,748	8,276	23,928

Source: Vermont Energy Investment Corporation


III. GENERATION AND DISTRIBUTION

Electric systems are part of large regional networks that extend beyond state boundaries. Vermont
belongs to a network that encompasses the six states of New England. These regional networks are
responsible for the general organization and operation of the electric businesses and market territory.
However, the vast diversity in state-to-state infrastructure can influence the energy climate in
surrounding network states. For Vermont, this translates into major effects on the affordability, cost,
and reliability of electrical systems.

Regional Utilities

The Northeast Kingdom is served by seven electric utilities. Figure 2.4 depicts the coverage areas of
the region's utilities and the subtransmission lines. Vermont Electric Co-Op serves the largest area,
covering over 19 towns in Northern Essex and Orleans Counties. Green Mountain Power also
covers a large area in Caledonia and Southern Essex Counties, with the remainder of the region
served by Washington Electric Co-Op, and four municipal-owned electric companies. The NEK's

1 municipal electric utilities include Barton Electric, Orleans Electric, Lyndonville Electric, and
2 Hardwick Electric. Together the municipal utilities provide service to 19 different towns and villages
3 (Figure 2.4⁹).



4

⁹ Latest version of mapped Utility Service Territories (VCGI ArcGIS) data available.

1 All the municipally owned utilities throughout the state are represented by the Vermont Public
2 Power Supply Authority (VPPSA). VPPSA acts on behalf of the utilities in the regional buying and
3 selling of power and provides rate studies, central computer services, load forecasting, tax-free
4 financing of certain capital projects, and exploration of new generation options. VPPSA is a part
5 owner in the McNeil Station in Burlington, a 50 MW generator that primarily uses wood, as well as
6 the Highgate Interconnection facility, which is used to bring in power from Hydro Quebec. In 2010,
7 VPPSA completed a 40MW peaking facility in Swanton, Vermont. The facility runs during peak price
8 times to mitigate price spikes that typically occur in the summer and winter.

9 The region's utility power supply portfolios are made up of a mixture of generation resources, long-
10 term contracts, and short-term contracts. Three of the municipal utilities generate some of their own
11 power through hydro (Hardwick has a facility in Wolcott, just outside of the region.) Orleans
12 Electric's portfolio also includes long-term and short-term contracts; however, it is without
13 generation resources of its own. Figure 2.4 demonstrates the aggregated power supply by fuel type
14 for all utilities serving the Northeast Kingdom. (This power supply mix will vary among each
15 member utility of VPPSA.)

Table 2.10: 2016 Fuel Mix (Before Sales of Renewable Energy Certificates)							
VPPSA*		Washington Electric Coop		Vermont Electric Coop		Green Mountain Power	
%	Source	%	Source	%	Source	%	Source
40	Market Purchases	66	Coventry Landfill	59.6	Hydro	34.7	Large Hydro
33	Hydro	13	NYPA (Large Hydro)	19.4	Wind/Solar/Farm Methane/Wood	27.4	Market Purchases
15	Biomass	10	Sheffield (Wind)	17.9	Nuclear	13.8	Nuclear
7	Landfill Gas	5	Small Hydro	3.2	Natural Gas/Oil	5.6	Existing VT Hydro
2	Solar	3	Ryegate (Wood)			8.2	Wind
2	Standard Offer	3	Market Purchase			4.9	Hydro
1	Fossil	<1	GMP System			2.6	Wood
						2.1	Solar
						0.3	Methane
						0.4	Oil & Natural Gas

Source: Integrated Resource Plans, Utility reports, and web sites
*Fuel mix will vary among municipal utility members.

16
17 Until it shut down in 2014, Vermont Yankee supplied roughly one-third of Vermont's electric supply.
18 Central Vermont Public Service and Green Mountain Power were the lead owners of the facility.
19 (GMP and CVPS merged in 2012.) . While a large share of this replacement power has come from
20 Hydro Quebec GMP, there is still some nuclear power in the mix from Seabrook, NH. While much
21 of the utilities' power originates from Hydro Quebec, there are other sources from New York Power
22 Authority, as well as smaller facilities throughout the state. Market purchase are power contracts
23 purchased without any known environmental attributes and the fuel mix may change over time.

1 Green Mountain Power estimates that as of 2016, the market purchase mix is more than half natural
2 gas, followed by nuclear, and oil.¹⁰

3 Although the NEK is a net exporter of energy, Vermont has traditionally been a net importer.
4 Technically, the state produces enough generation; however, due to the performance characteristics
5 of the in-state generation, Vermont has relied heavily on its transmission network to import power
6 from neighboring states. When Vermont Yankee shut down, Vermont's net import rate rose
7 significantly, making the state a net importer of power at virtually all hours from New York, New
8 Hampshire, Massachusetts and Canada in order to meet the state's load requirements. Without
9 significant new in-state generation, this situation will be a long-term operating condition.¹¹

10 **Purchase & Distribution**

11 The state of Vermont belongs to the ISO-New England Regional Transmission Organization (RTO).
12 The ISO-New England RTO operates all of New England's bulk electric power system and works in
13 coordination with the New England Power Pool (NEPOOL). NEPOOL is Vermont's regional
14 representative of the electric power businesses, including utilities, independent power producers
15 (IPP), suppliers, end-users, and transmission providers. In 1997, the RTO was developed as a means
16 to create competitive wholesale electricity markets. Their responsibilities include developing,
17 overseeing and operating the New England wholesale electric market, as well as managing and
18 planning for regional electric needs.

19 The RTO wholesale electric market operates on a per-hour bid system that incorporates some short-
20 term and long-term contracts. The bid system requires generation units to bid into the system based
21 on what it costs them to produce for that hour. The hourly price is then set based on the most
22 expensive facility needed to meet demand. As demand increases, the higher-priced facilities are pulled
23 online to meet the increasing load. In Vermont, many of the "peaking" plants utilize diesel fuel. New
24 England is also heavily dependent on natural gas generation facilities, which set the hourly price 85%
25 of the time. Even though natural gas prices have dropped recently, New England households retain
26 the highest electric costs in the country. As part of the RTO, Vermont is subject to these higher
27 electric costs, even though there is only one natural gas generation facility in the state. According to
28 the Public Service Department, the higher pricing is caused by existing long-term contracts and
29 restrictive pipeline infrastructure. In other words, New England is still paying natural gas pricing that
30 was set in a multi-year contract, plus its limited pipeline capacity means it cannot access additional
31 volumes of natural gas outside of those contracts. Massachusetts is currently pursuing the expansion
32 of a major pipeline to be able to utilize larger volumes of natural gas.

33 **Transmission**

34 A majority of Vermont's electric transmission system is operated by the Vermont Electric Power
35 Company (VELCO), which was established by Vermont's utilities in 1956. VELCO is responsible for
36 bulk transmission lines with a voltage rating of 115kV and above. Lines with a rating of 34.5kV,
37 46kV, and 69kV are considered sub-transmission lines. The Northeast Kingdom has roughly 325
38 miles of transmission and sub-transmission lines (Figure 2.3) and serves as an important gateway for
39 electricity coming from both Canada and New Hampshire.

40 VELCO is responsible for planning and constructing upgrades that ensure system reliability and
41 maintain the grid. Several upgrades in recent years should significantly increase transmission capacity

¹⁰ Green Mountain Power: Our 2016 Fuel Mix Information
<http://www.greenmountainpower.com/2016/12/01/fuel-mix/>

¹¹ VELCO: 2015 Long-Range Transmission Plan
https://www.velco.com/assets/documents/2015Plan_Final_toPSB.pdf

1 on existing lines: new lines between Irasburg and Newport; upgrades to the St. Johnsbury, Irasburg,
2 and Newport substations; and the reconfiguration of the Hydro Quebec interconnection at Highgate.
3 In 2010 VELCO upgraded the Hill Street substation in Lyndonville, which provided a secondary
4 connection between Lyndonville Electric's grid and the larger VELCO transmission lines. In 2011, a
5 new substation in Jay established redundancy in transmission paths and increased capacity to delivery
6 power to the Jay area.

7 VELCO maintains a long-range transmission plan that must be updated every three years for the
8 PUC. The plan and subsequent updates are vetted through a stakeholder group called the Vermont
9 System Planning Committee (VSPC), which is made up of VELCO, electric distribution utilities, the
10 Department of Public Services, representatives of demand and supply resources, and representatives
11 of the general public. The most recent Long-Range Transmission Plan (June 2015) acknowledges that
12 a profound transformation of the electric grid is already underway. The grid must become more agile
13 and diverse by retiring traditional base load generation, increasing distributed renewable generation,
14 and investing in demand-side resources, such as energy efficiency and demand response. Emerging
15 technologies, such as heat pumps and electric vehicles, are reflected in the load forecast of the 2015
16 Plan, but their full impact cannot yet be quantified with confidence.

17 One ongoing VSPC initiative of particular concern to the Northeast Kingdom is grid congestion in
18 the Sheffield Highgate Export Interface (SHEI), the northwestern area of our region where
19 generation exceeds load. (Figure 2.4) In essence, the region generates far more power than it
20 consumes, causing generation to exceed the capacity of the export line. The continued addition of
21 new sources of generation, like solar, forces existing resources, like Kingdom Community Wind and
22 Sheffield Wind to curtail their output due to the lack of capacity to export power. Adding more
23 renewables to an already full grid at this point can simply mean replacing other renewables. While
24 modest transmission upgrades may help to alleviate some congestion in the short-term, the situation
25 will require robust, long-term solutions that are complex and possibly costly.¹² Utilities, clean energy
26 advocates, regulators and other stakeholders are currently discussing ways that the SHEI limitations
27 can be addressed to reduce or eliminate curtailments of generation located within the interface.

28 **Regional Generation Facilities**

29 *(Note: For municipal-level generation estimates, see Appendix B.)*

30 The Northeast Kingdom has a very large share of generation resources compared to other regions of
31 the state. (Table 2.11) The region is home to four major renewable generation facilities: the Ryegate
32 Wood-Chip Plant, the Coventry Landfill methane-generator, the Sheffield Wind Farm, and Kingdom
33 Community Wind in Lowell. Collectively, these facilities produced 80% of the region's total
34 electricity generation that is not net-metered (i.e. grid-tied). 2005 saw the first major jump in regional
35 generation growth with the development of the Coventry Landfill methane generator, which doubled
36 its output in 2009. The region also produces a significant amount of hydro power. Collectively, hydro
37 power (excluding Connecticut River production, which is technically in New Hampshire), the
38 Northeast Kingdom's hydro resources account for 18% of regional generation.

39
40

¹² Frank Ettori, SHEI Overview, VSPC, July 12, 2017 v. 2

Table 2.11: Generation Facilities in the Northeast Kingdom

Owner/Operator – Facility Name	Location	Utility	Facility Type	kW Capacity	Annual Output MWh
Kingdom Community Wind	Lowell	GMP	Commercial Wind	63,000	191,174
Sheffield Wind	Sheffield	WEC	Commercial Wind	40,000	121,380
Passumpsic Hydro	Barnet	GMP	Hydro	700	3,851
East Barnet Hydro	Barnet	GMP	Hydro	2,200	7,442
Barnet Hydro	Barnet	GMP	Hydro	490	1,814
Great Bay Hydro Corp. (IPP) – West Charleston (Standard Offer)	Charleston	VEC	Hydro	675	2,655
Barton Village Hydro	Charleston	Barton Village Electric	Hydro	1,400	4,210
Fairbanks Mill	Danville	GMP	Hydro	18	73
West Danville #15	Danville	GMP	Hydro	1,000	3,700
Ampersand Gilman Hydro	Lunenburg	GMP	Hydro	4,850	28,000
Great Falls	Lyndonville	LED	Hydro	1,900	9,600
Vail	Lyndonville	LED	Hydro	350	1,850
Newport 1, 2, 3	Newport	VEC	Hydro	4,000	15,735
Dodge Falls	Ryegate	GMP	Hydro	5,000	27,000
Emerson Falls	St. Johnsbury	GMP	Hydro	230	700
Arnold Falls	St. Johnsbury	GMP	Hydro	350	1,588
Gage	St. Johnsbury	GMP	Hydro	700	2,878
Pierce Mills	St. Johnsbury	GMP	Hydro	250	1,544
North Troy	Troy	VEC	Hydro	460	2,600
Troy Mills Hydroelectric (Standard Offer)	Troy	VEC	Hydro	816	3,210
Maxwell's Neighborhood Energy, LLC (IPP) (Stanard Offer)	Coventry	VEC	Methane	225	1,508
WEC – Coventry Landfill	Coventry	WEC	Methane	8,000	50,506
Maplehurst Farm (Standard Offer)	Greensboro	HED	Methane	150	1,005
Chaput Family Farms (Standard Offer)	Troy	VEC	Methane	300	2,010
Sun CSA 73 (Community Solar)	Barnet	GMP	Solar	150	184
Sun CSA 59 (Community Solar)	Barnet	GMP	Solar	150	184
Barton Solar LLC (Standard Offer)	Barton	VEC	Solar	1,890	2,401
SolarSense VT (Community Solar)	Concord	GMP	Solar	500	613
Coventry Solar (Standard Offer)	Coventry	VEC	Solar	2,200	2,794
Sun CSA 27 (Community Solar)	Lowell	VEC	Solar	150	184
Solaflect Community Solar Park	Lunenburg	GMP	Solar	150	235
Sun CSA 53 (Community Solar)	Lunenburg	GMP	Solar	150	184
Ira Rentals (Standard Offer)	Newport	VEC	Solar	37	47
Bobbin Mill (Standard Offer)	Newport	VEC	Solar	50	64
Ryegate Power Station (IPP)	Ryegate		Wood Chip	167,627	154,785

TOTAL	310,118	647,708
Source: VEPP, Vermont Renewable Energy Atlas. Some outputs were calculated because actual output was not available, including KCW and Sheffield Wind, which are curtailed due to grid congestion.		

1
2 There are also three very large generation assets located on the border of the region that deserve to
3 be mentioned. The Comerford Dam, McIndoe Falls Dam, and the Moore Dam are all located on the
4 Connecticut River, which is owned by New Hampshire. Table 2.12 presents their generation figures.
5 According to the Department of Public Service, they are not considered Vermont generation assets,
6 but their mere proximity to the region may pose a future benefit to our area.

Table 2.12: State-Line Generation Facilities (Technically located in New Hampshire) in MWhs/year			
TransCanada - Moore Dam	Hydro	271,000.00	Waterford, VT & Littleton, NH
TransCanada - Comerford Dam	Hydro	315,000.00	Barnet, VT & Monroe, NH
TransCanada - McIndoe Falls Dam	Hydro	52,000.00	Barnet, VT & Monroe, NH
Total			638,000.00

7
8 **SPEED and Standard Offer**
9 In June 2005, Vermont enacted the Sustainably Priced Energy Enterprise Development (SPEED)
10 Program and Renewable Portfolio Goal to provide financial incentives for the development of new
11 renewable generation facilities under 2.2 MW. The program encourages development by providing
12 feed-in tariffs, which pay a set incentive rate/kWh above current market retail prices for power that
13 meets program criteria and agrees to long-term contracts. Specific types of renewable generation
14 were initially assigned different tariff amounts, and the program had a total cap of 50 MW. In the
15 2012, the legislature increased the cap to a total of 127.5MW that will be rolled out in set allotments
16 over the course of 10 years to limit the impact on rate payers. Changes to the program also addressed
17 how tariff rates are established, with the legislature promoting a reverse auction process to ensure
18 competitive rates. Northeast Kingdom renewable energy development projects with standard offer
19 contracts are noted in Table 2.13 and include all the farm methane generators, as well as hydro and
20 solar, producing in excess of 15,000 MWh a year. In 2015, VPPSA was awarded two Standard Offer
21 contracts for two solar projects (475 kW and 500 kW) to be located in Lyndonville. A contract has
22 also been awarded to Dairy Air, a large wind project in Holland, although that project is still under
23 review by the Public Service Board. Act 56, which established the renewable energy standard for
24 electric utilities (see below), eliminated the SPEED Program, except for the standard offer
25 component.

26 **Net-Metering**
27 In 1998 the Vermont State legislature passed a bill allowing the practice of net-metering. Net-
28 metering requires electric utilities to permit customers to interconnect on-site renewable electricity
29 systems with the grid (e.g. a photovoltaic system with proper DC-AC conversion equipment) and to
30 be billed only for the net amount of power they consume. This effectively creates an incentive equal
31 to the customer's electric rate for the kWh of renewable electricity that they create. There have been
32 several revisions to the net-metering rules over the past several years, including expanding
33 production limits, simplifying permitting, and increasing peak load capacity, making it easier to
34 establish individual and group run net-metered systems.

35 Although it is approved for a variety of systems -- solar, small wind, combined heat and power, farm
36 methane, and bio-gasification facilities generating up to 500 kW – net metering has been most

1 popular with solar. This has been largely due to the “solar adder,” which increased the average price
2 per kWh of solar net-metered generation.

3 Act 99, which became effective in January of 2017, raised the cap on Vermont’s utilities from 4% to
4 15%, meaning that the utilities have to take on net-metered systems on a first-come, first-served basis
5 to all its customers until the cumulative generating capacity of all net-metered systems equal 15% of
6 the utility’s peak demand. New net-metering customers will be compensated at a reduced rate,
7 although the rate is still well above retail electric rates. Instead of applying a solar adder, the new net-
8 metering rule applies a series of adjustments for siting solar on statewide **preferred** sites that have
9 already been disturbed: rooftops, parking lot canopies, brownfields, and gravel pits. There is no site
10 adjustment for installations of 150 kW or more, so the new net metering has the potential – at least
11 in theory – to site small developments away from open fields and other undeveloped areas. To date,
12 utilities serving the Northeast Kingdom have reported a sharp uptick in the number of net metering
13 applications, and in some instances, at double the rate of previous years. In testimony to the Senate
14 Natural Resources and Energy Committee, VEC has noted that since January of 2017 66% of the
15 net metering capacity is for projects greater than 150kW. This service area (the SHEI) already
16 has significant system constraints, so new net-metered generation will displace existing generation
17 which is less expensive.¹³

18 The region currently generates nearly 13,000 MWh through net metering. (Table 2.13). There has also
19 been growth in group net metering and community solar programs, which allow individual customers
20 within one utility service territory to invest in a solar project and receive distributed net metering
21 credits. This off-site option can be cost-effective for residents, particularly renters and home owners
22 where solar installations are not possible. Currently, such net metering projects in the area generate
23 11,792 MWh annually. Utility customers are also able to “sponsor” solar panels in community solar
24 projects outside of the region.

25
26 **Renewable**
27 **Energy**
28 **Standard**
29 Until 2015,
30 Vermont had a
31 renewable energy
32 portfolio goal for
33 its utilities to meet

Table 2.13: Annual Output Net metering in the Northeast Kingdom (MWh)				
	Caledonia	Essex	Orleans	NEK
Solar Net-Metering	5,415	452	3015	8,882
Group Net Metered	836	275	209	1320
Community Solar Array	368	1032	184	1584
Small Wind	489	8	613	1,110
Total	7,108	1767	4021	12,896

Source: Vermont Renewable Energy Atlas

34 growth in electricity demand by using energy efficiency and new renewable generation sources. When
35 Act 56 was passed in 2015, this goal was replaced by a mandatory Renewable Energy Standard (RES)
36 for the portfolios of Vermont’s electric utilities. The RES has three tiers:

37 **Tier I:** 55% starting in 2017, existing total renewables will rise 4% every three years to reach 75% in
38 2032. A utility can meet this requirement by owning renewable energy or renewable energy
39 certificates (RECs) from any plant, as long as the plant’s energy can be delivered in New England.

40 **Tier II:** A subset of Tier I RECs, utilities now have a distributed generator requirement connected to
41 Vermont’s electric grid. Starting in 2017, 1% of the utility’s portfolio must be *distributed renewable*
42 *generation*, rising .6% each year to reach 10% in 2032. (Unlike energy produced in a large power plant,
43 *distributed* energy is produced on-site or in a decentralized manner, such as district generation,

¹³ Vermont Electric Cooperative: Testimony to the Senate Natural Resources and Energy Committee-March 23, 2017

1 through smaller grid-tied devices.) Utilities can meet this requirement by through the production of
2 distributed renewable energy or through RECs that have come into service after June 30, 2015, are 5
3 MW or less, and are directly connected to Vermont's grid (i.e. in state generation.)

4 **Tier III:** This is an energy *transformation* requirement that starts from 2% in 2017 and rises to 12% in
5 2032. Utilities meet this requirement either through additional distributed renewable generation or
6 "transformation projects" that replace or reduce fossil fuel consumption. Such projects include home
7 weatherization, installation of heat pumps, the use of biofuels, or incentives to purchase EVs. The
8 municipal utility members of VPPSA are exempted from this requirement until 2019, but VPPSA's
9 program will likely include weatherization and heat pumps, biofuels, energy storage, and EVs and
10 charging infrastructure.

11 **Renewable Energy Certificates (RECs)**

12 Tiers 1 and 2 of the Renewable Energy Standard require utilities to hold Renewable Energy
13 Certificates (RECs) to satisfy their requirements. RECs track how much renewable energy is
14 produced from a project, and they have been a major supporting factor in the development of
15 renewable energy. Because Vermont did not have mandatory renewable energy portfolio standards
16 prior to the passage of Act 56, RECs were less likely to be "retired" (used) in state. Rather, they were
17 often sold to Massachusetts, Connecticut, Rhode Island, Maine, and New York, which already had
18 mandatory standards. Utilities and generators buy and sell RECs on an open regional market. Utilities
19 cannot claim electricity is renewable if the REC from that electricity has been sold. Conversely, a
20 utility can claim 100% renewability if it holds sufficient RECs to offset retail sales, even if it generates
21 with fossil fuel. Act 99 affects the sale of RECs from small and mid-size generation. Under the new
22 net metering rule, customers who keep their RECs (either to sell out of state or to keep for
23 themselves) will be subject to a \$0.03 penalty per kilowatt-hour (kWh). By contrast, customers who
24 transfer their RECs to the utility will receive a \$0.03 incentive per kWh for the first ten years of their
25 operation. Even for a small residential-scale system, this penalty can amount to thousands of dollars.
26 Although the law is intended to help Vermont utilities meet their renewable energy goals, critics of
27 the legislation argue that it could stymie new solar development once utilities have met their 10%
28 Tier II goals. Also, because energy consumers cannot claim to use renewable energy unless they
29 retain the RECs, it does not support energy consumers who have made a conscious decision to avoid
30 the use of fossil fuel and nuclear power.

31 **Incentives and Subsidies**

32 There are considerable federal incentives that support the market for renewable energy development
33 in Vermont. Without the tax credits and Renewable Energy Credits (RECs), some renewable
34 technologies, such as utility-scale wind, would not be an economically viable resource. There are
35 currently three major federal tax credits supporting the development of renewable energy facilities.
36 Table 2.14 below lists the current federal subsidies and their eligible renewable technologies:
37

Table 2.14 Federal Subsidies for Renewable Energy Development

Program Name	Applicable Technology
Business Investment Tax Credit (ITC)	Solar Water Heat, Solar Space Heat, Solar Thermal Electric, Solar Thermal Process Heat, Photovoltaics, Wind, Biomass, Geothermal Electric, Fuel Cells, Geothermal Heat Pumps, CHP/Cogeneration, Solar Hybrid Lighting, Fuel Cells using Renewable Fuels, Microturbines, Geothermal Direct-Use. This credit has been amended several times, most notably in 2015 in the Consolidated Appropriations Act, when the expiration date for these technologies was extended with a gradual step-down of the credits between 2019 and 2022. An investment tax credit is also available to home owners (such as for solar installations) through 2021.

Modified Accelerated Cost-Recovery System (MARCS)	Solar Water Heat, Solar Space Heat, Solar Thermal Electric, Solar Thermal Process Heat, Photovoltaics, Landfill Gas, Wind, Biomass, Geothermal Electric, Fuel Cells, Geothermal Heat Pumps, Municipal Solid Waste, CHP/Cogeneration, Solar Hybrid Lighting, Anaerobic Digestion, Fuel Cells using Renewable Fuels, Microturbines, Geothermal Direct-Use. Also amended in the Consolidated Appropriations Act, the "placed in service" deadline for bonus depreciation was extended to January 2018.
Renewable Energy Production Tax Credit (PTC)	Landfill Gas, Wind, Biomass, Hydroelectric, Geothermal Electric, Municipal Solid Waste, Hydrokinetic Power (i.e., Flowing Water), Anaerobic Digestion, Small Hydroelectric, Tidal Energy, Wave Energy, Ocean Thermal. This credit phases down for wind commencing construction after December 2016 and expires for other technologies.

1
2 Vermont provides a tax credit that investors can claim in addition to the federal credit. Efficiency
3 Vermont provides a link to rebates and incentives for small-scale renewables and efficiency
4 improvements. <https://www.efficiencyvermont.com/rebates>). With regards to municipal tax,
5 Vermont law allows municipalities to waive the property taxes for solar facilities and any land, not to
6 exceed one-half acre, on which it is built.
7 Property-Assessed Clean Energy (PACE) Districts allow property owners to borrow money to pay
8 for such things as energy efficient water heaters, lighting, furnaces, boilers, windows, programmable
9 thermostats, and insulation, as well as solar heating, PV, wind and biomass systems. The amount
10 borrowed is typically repaid via a special assessment on the property over a period of up to 20 years.
11 In Vermont, local governments are authorized to create PACE Districts to provide financing.
12 Participating property owners must agree to a special assessment and lien on the property and pay a
13 one-time, non-refundable fee to support the reserve fund created to cover losses in the event of
14 foreclosure of participating properties. The district may release a lien on a property once the property
15 owner has met the terms of the loan. At this time only a few towns are implementing PACE
16 Districts. Municipalities may have been slow to adopt PACE because of a perceived administrative
17 burden. Since 2011, VEIC has received funding to provide most of the administrative support to
18 town. More outreach and education about PACE may be necessary.

19 Other Energy Facilities

20 The electricity system is the major energy network in the region. However, it is important to mention
21 the Northeast Kingdom's other major energy infrastructure. The Portland Pipeline is a major crude
22 oil pipeline that stretches from Portland, Maine into Canada. In our region, the pipeline runs from
23 Guildhall northwest to Jay before crossing into Canada. While Vermont doesn't tap into the pipeline,
24 its existence in our region as major transporter of oil is important for potential future use.

25 The Portland Natural Gas Transmission system also just touches the region. The transmission line
26 also runs from Portland, Maine into Canada and is owned by TransCanada, a major Canadian energy
27 supplier. The line just barely passes through the state in Canaan, Vermont before reaching Canada. A
28 spur has recently been created from this line, but only serves the Ethan Allen Manufacturing Plant in
29 Beecher Falls. Future potential to expand this transmission system into the region remains possible.

1

2 **Granite State Power Link (GSPL)**

3 Plans have been announced for the development of a new electric transmission line in Vermont and
4 New Hampshire that will deliver up to 1,200 MW of hydro power to southern New England. The
5 infrastructure will consist of two converter stations (one in Vermont), 59 miles of high-voltage direct
6 current line (used for transmitting large amounts of power over great distances), 109 miles of
7 alternating-current line, and a switching station
8 in New Hampshire. The line is proposed to be
9 built adjacent to an existing VELCO
10 transmission corridor and will require a 150
11 foot expansion. About 53 miles of GSPL will
12 be high-voltage direct current line running
13 through the towns of the Essex County. (Table
14 2.15) Because the NEK portion of the line is
15 direct-current only, the line will not expand the
16 region's transmission capacity to host new
17 energy development (like wind or solar). The
18 project is located alongside an existing
19 transmission corridor, so visual impacts are
20 expected to be minimal. Project developers are
21 currently working with Vermont Association
22 of Snow Travelers (VAST) to explore recreation opportunities, and the project will bring revenues
23 and other financial benefits into the region and affected communities. The project has been found to
24 be in conformance with NVDA's regional plan

25

Table 2.15: Vermont Communities in the GSPL

Community	Approximate miles
Norton	4.6
Avery's Gore	0.7
Averill	1
Lewis	6.7
Bloomfield	5.1
Brunswick	3
Ferdinand	5.7
Granby	8.5
Victory	2.4
Lunenburg	3.8
Concord	8.8
Waterford	2.1

1 **IV. FUTURE ENERGY USE AND 2050 PROJECTIONS**

2 (*Note: for municipal targets in support of these goals, see Appendix A.*)

3 NVDA's Regional Energy Plan was developed in support of [Vermont's 2016 Comprehensive Energy](#)
4 [Plan](#) (CEP), which contains the following goals:

- 5 • Reduce total energy consumption per capita by 15% by 2025, and by more than one third by
6 2050.
- 7 • Meet 25% of the remaining energy need from renewable sources by 2025, 40% by 2035, and
8 90% by 2050.
- 9 • Achieve three renewable end-use sector goals for 2025: 10% transportation, 30% buildings,
10 and 67% electric power.

11 What follows below is one possible strategy, developed by Vermont Energy Investment Corporation,
12 which uses a regionalized scenario of the statewide Long-Range Energy Alternatives Planning
13 (LEAP) model. Historic information was primarily drawn from the Public Service Department's
14 Utility Facts 2013 and U.S. Energy Information Administration data. Projections came from the
15 Vermont Public Service Department's Total Energy Study (TES), and Integrated Resource Plans
16 from the utility companies.

17 The “90x2050” approach has two major underlying concepts:

18 **1. Reducing energy use:** Aggressive weatherization, efficiency, and conservation measures are
19 critical in reducing total energy demand to the point where it can be primarily met through renewable
20 sources. Conservation involves reducing or eliminating unnecessary energy use and waste (e.g.
21 lowering thermostats, limiting hours of operation, etc.). Efficiency also involves reducing the total
22 amount of energy consumed, but the reduction comes from improving equipment or operating
23 processes that use energy. Weatherization improvements are energy efficiency measures such things
24 as insulating walls and ceilings, installing programmable thermostats, and replacing inefficient
25 machinery. The net result is that less energy is used, while the overall costs needed for energy are
26 reduced as well. Energy efficiency improvements typically have a cost, but the payback periods will
27 vary depending upon the cost of the improvement and the amount of energy that is saved.

28 **2. Replacing traditional fuel sources:** The 90x205 model replaces traditional fossil-fuels with
29 electricity, which can come from clean renewable sources like hydro and solar. Fuel switching
30 primarily occurs by providing residential heating units with heat pumps, but efficient wood burning
31 systems (like wood pellet furnaces) and bio fuels play an important role as well. Fuel switching also
32 occurs by gradually replacing fossil-fuel burning automobiles with EVs. Electrification of heating and
33 transportation has a large effect on the total demand because the electric end uses are three to four
34 times more efficient than the combustion versions they replace. Even if the region's population
35 grows and the economy expands, overall energy use declines because of efficiency and
36 electrification.¹⁴

37 Regional end-use models (Figures 2.5 through 2.8) are derived from two scenarios:


38 1. The “**reference**” scenario assumes a business-as-usual continuation of today's energy use patterns
39 but does not reflect the Vermont's renewable portfolio standard or renewable energy or greenhouse
40 gas emissions goals. The main changes over time in the reference scenario are more fuel-efficient cars
41 because of CAFE standards.


¹⁴ Vermont Energy Investment Corporation: NVDA Modeling, Summary Results and Methodology

1 2. The “**90% x 2050 scenario**” is designed to achieve the goal of meeting 90% of Vermont’s total
2 energy demand with renewable sources.

3 What follows below shows 2015 usage according to the reference scenario, and then displays energy
4 use from subsequent years based on the 90x2050 scenarios. “Avoidance” is the energy that is no
5 longer needed because of aggressive weatherization, efficiency upgrades, and fuel switching.

6 **Residential and Commercial Heating by 2050**





Residential demand was based on counts of housing units from American Community Survey and assumed a constant population growth rate of 0.21%, based on calculations from Vermont Population Projections 2010-2030. Residential demand also assumed that household size would decrease from 2.4 in 2010 to 2.17 in 2050. (More about the declining household size can be found in NVDA's Housing Plan.)

Projected change in the energy demand from the commercial sector was based on commercial sector data in the Total Energy Study, which showed commercial building square footage growing by almost 17% from 2010 to 2050.

In these scenarios, the use of electricity for residential heating nearly doubles. This increase offsets a slight decrease in electricity for the commercial sector, where wood and wood scraps and biofuels play a more significant role. Neither estimate accounts for the use of solar in water heating. According to the Vermont Renewable Energy Atlas, there are nearly 40 solar powered water heating systems in the Northeast Kingdom.

Table 2.16 establishes weatherization and fuel switching targets in support of the 90x2050 targets for residential and commercial heating in the Northeast Kingdom. These targets were developed with assistance from the Department of Public Service using the assumptions from the regionalized model from VEIC.

Table 2.16: Weatherization and Fuel Switching Targets for the Northeast Kingdom			
By Year	2025	2035	2050
Estimated number of households	28,050	30,044	32,180
% of households to be weatherized	22%	35%	60%
# of households to be weatherized	6,073	10,568	19,323
Estimated number of commercial establishments	1,571	1,692	1,822

% of commercial establishments to be weatherized	5%	8%	14%
# of commercial establishments to be weatherized	75	130	248
% of households with efficient wood heat systems (e.g. pellet furnaces, stoves)	56%	43%	31%
# of households with efficient wood heat systems	15,648	12,863	9,992
% of households with heat pumps	17%	14%	31%
# of households with heat pumps	4,642	9,814	13,352
% of commercial establishments with efficient wood heat systems	15%	17%	22%
# of commercial establishments with efficient wood heat systems	229	291	401
% of commercial establishments with heat pumps	6%	10%	13%
# of commercial establishments with heat pumps	87	162	239

1
2 These projections assume a constant increase in the number of housing units and commercial
3 establishments of about 0.6% and a weighted average heat load derived from existing municipal-level
4 energy consumption estimates from by NVDA. (See Appendix B for a full explanation of municipal
5 estimates.) Weatherization targets assume an average savings of 25% for residential heat load and
6 20% for commercial heat load.

7 Targets in Table 2.16 use methodology from the Department of Public service. Overall efficiencies
8 achieved through the use of heat pumps (particularly in the residential sector) will reduce the use of
9 supplemental heat. Nevertheless, we anticipate a continued need for efficient wood heating systems,
10 particularly in older structures with multiple heating zones. The commercial sector is less likely to see
11 a reliance on heat pumps, partly due to the relative lack of commercial development pressure in the
12 region, not to mention the fact that a number of commercial establishments are already using
13 efficient biomass systems.

14 Electricity use is expected to increase dramatically by 2050 so demand-side management and
15 upgrades, such as hardwiring, lighting fixtures, and appliances is also an important part of this
16 scenario, especially since electricity is replacing other fuel-burning thermal applications. Table 2.17
17 establishes targets for electrical equipment upgrades.

18

Table 2.17: Electrical Equipment Upgrade Targets for the Northeast Kingdom			
By Year	2025	2035	2050
Estimated number of customers	41,551	44,055	46,487
# of customers to upgrade equipment	10,769	16,923	24,808
% of customers to upgrade equipment	26%	38%	53%

19
20 This estimate assumes an average savings of 400 kWh per project and assumes a projected number of
21 customers by multiplying the number of housing units by 1.5 (to account for multi-units and non-
22 residential customers).

23

Table 2.18 provides some historical data on weatherization, fuel-switching, and equipment upgrades accomplished to date. Measures that achieve thermal savings and electrical efficiency are often inextricably linked because they have *interactive* effects. For example, the installation of a cold climate heat pump may produce thermal savings, but it may also increase electrical use because it is replacing a fuel-oil system (thus making demand-side management critical). Also, in industrial settings a switch from incandescent bulbs (which emit a substantial amount of heat) to LED bulbs (which emit very little heat) can actually require additional energy to heat the space. A heat pump water heater in a finished basement collects heat from the space and delivers the heat to the water, meaning the basement requires additional heat.

Individuals and businesses can access a variety of resources, both public and private, for services ranging from energy audits to financing to contracting. Local energy committees have led successful campaigns to replace lighting with LED bulbs, encourage the purchase of Energy Star appliances, and educate consumers about incentives for more efficient options such as heat pumps. Additionally, improvements to battery storage may reduce peak demand. The development and use of real-time monitoring technology will also make customers more efficient users of electricity.



	Table 2.18: Efficiency Measures by Count in the Northeast Kingdom							
	2014		2015		2016		Total	
	Res.	C & I	Res.	C&I	Res.	C&I	Res.	C&I
Air Conditioning Efficiency	63	81	90	196	71	28	224	305
Compressed Air	0	57	0	10	0	12	0	79
Cooking and Laundry	323	1	265	76	244	0	832	77
Design Assistance	0	29	0	12	0	9	0	50
Health and Safety	9	0	12	0	8	0	29	0
Hot Water Efficiency	1,059	9	696	4	617	8	2,372	21
Hot Water Fuel Switch	1	0	0	0	0	0	1	0
Hot Water Replacement	2	0	2	2	2	0	6	2
Industrial Process Efficiency	0	40	0	8	0	15	0	63
Light Bulb/Lamp	70,113	14,115	61,755	17,859	51,767	16,837	183,635	48,811
Lighting Efficiency/Controls	38	800	2	722	20	144	60	1,666
Lighting Hardwired Fixture	3,886	4,185	5,030	6,764	4,484	7,139	13,400	18,088
Motor Controls	3	21	0	57	1	22	4	100
Motors	229	0	243	3	387	1	859	4
Office Equipment, Electronics	1,773	34	1,492	0	751	1	4,016	35
Other Fuel Switch	0	0	0	5	0	0	0	5
Refrigeration	461	129	320	317	238	83	1,019	529
Space Heat Efficiency	162	9	116	14	129	7	407	30
Space Heat Fuel Switch	27	1	27	6	19	5	73	12
Space Heat Replacement	4	10	43	38	113	9	160	57
Thermal Shell	225	1	152	11	156	7	533	19
Ventilation	194	93	66	88	32		292	181
Water conservation	0	0	0	1	0	1	0	2

Source: Vermont Energy Investment Corporation

16

17

1 **Transportation Energy Use by 2050**



8 Biodiesel, which is currently being sourced from oilseed grown in the Northeast Kingdom, is the
9 most significant agent of change in use among heavy-duty vehicles and farm equipment. Among
10 light-duty vehicles (LDVs), the gradual conversion from fossil fuel to EVs is expected to have a
11 dramatic impact on electricity use in the Northeast Kingdom. These estimates assume gradual gains
12 in fuel efficiencies from 3 miles per kWh to 4 miles per kWh, which helps to reduce total energy use
13 by more than two-thirds from 2015 levels, even though the number of light duty vehicles on the road
14 increase. In 2050, end-use electricity consumption in LDVs increases by more than 153 times, or
more than 15,000%.

15 Clearly, the switch to EVs in the rugged Northeast Kingdom is a tall order, requiring significant
investment in charging infrastructure, not to mention performance improvements on steep terrains

1 and in cold temperatures, battery storage, and affordability. Table 2.19 uses vehicle counts from
2 American Community Survey to identify targets for achieving fuel switching goals for LDVs.

Table 2.19: Fuel Switching Targets for Light-Duty Vehicles in the Northeast Kingdom			
By Year	2025	2035	2050
Estimated number of light-duty vehicles	53,153	56,874	60,855
# of EVs	5,618	17,937	38,603
% of LDVs	11%	32%	63%

3
4 **V. ENERGY RESOURCE ANALYSIS AND RECOMMENDATIONS**
5 The 90x2050 projections – which will nearly eliminate the use of fossil fuels—will require
6 transferring many of our uses to electricity. Therefore, even while electrical systems, appliances, and
7 vehicles will likely continue to increase in efficiency, more electricity will need to be produced. Some
8 of that will come from imported sources, such as hydroelectricity from Hydro Quebec and other
9 providers, but much of it will also need to be generated by in-state renewable facilities as well.
10 90x2050 projections indicate that residential non-thermal electrical use alone could exceed 614,000
11 MWh by 2050. Additionally, conversion to light-duty EVs could require more than 135,000 MWh
12 over that same period. Understandably, these projections counter earlier regional estimates, which
13 showed only modest increases in regional electrical consumption to 462,353 MWh by 2020.¹⁵ It is
14 important to remember that the 90x2050 projections incorporate sweeping and long-range changes
15 to the way we live and work.
16 Where – and how -- would energy generation occur? In support of the 90x2050 goals, each region
17 has a set of generation targets. Because our region already generates a disproportionate share of
18 energy relative to our low population, the Northeast Kingdom’s new generation targets are the lowest
19 in the state. (Table 2.19) While generation targets can be met through a variety of renewable
20 technologies, the Northeast Kingdom does not have any generation targets specific to wind.
21 Nevertheless, great care and consideration shall be given to the siting of new generation.

22 **Policy Statements**

23 This region has a responsibility to plan for adequate
24 supply of energy to meet local energy demand. Planning
25 activities may include the production, storage, siting, and
26 distribution of energy. Individuals, businesses,
27 organizations, and communities are encouraged to
28 explore emerging energy supply, efficiency, and net-
29 metering opportunities that meet accepted environmental
30 standards in order to satisfy their power demand.

31 New industrial/utility energy development shall meet the
32 highest standards required by law. Permitting authorities
33 shall first consider current and historical land use and the
34 culture of the region, community opinion, economic
35 benefit, as well as the land owner’s rights. Any
36 development shall to the extent possible be done so as to mitigate adverse impacts to the region. Any
37 utility-scale energy generation project deemed acceptable by the Public Utility Commission shall

Table 2.19: In-state Generation Targets	
Regional	New MWh
Addison	172,978
Bennington	293,182
Central Vermont	418,530
Chittenden	845,236
Lamoille	185,927
Northeastern	18,680
Northwest	260,438
Rutland	439,276
Southern Windsor	194,612
Two Rivers	396,631
Windham	97,716

¹⁵ NVDA Wind Study Report, March 26, 2015

1 include a plan for distributing benefits to the towns in the region proportional to the adverse effects
2 experienced by that town. Long term maintenance, safety issues, decommissioning, and land
3 reclamation procedures required at the end of the energy project's life must also be included in the
4 project plan.

5 This plan aims to balance environmental quality and important natural resources with energy
6 production. Significant local and regional support and clearly demonstrated benefits should exist in
7 any energy proposal. This is especially relevant when siting commercial- or utility-scale wind facilities,
8 which could have impacts on neighboring communities. "Commercial" and "utility" are defined in
9 this plan as:

10 **Commercial-scale:** facilities with a capacity of more than 10 kW (which would be considered
11 residential), but less than 100 kW. These structures typically have a height of just over 120 feet. (The
12 wind tower at Burke Mountain is 123 feet high.) These structures are referred to as "business-scale"
13 in the Vermont Renewable Energy Atlas.

14 **Utility-scale:** Wind turbines with a capacity of 1MW or more. These structures are referred to
15 "commercial scale" in the Vermont Renewable Energy Atlas.

16 The region has recently experienced a sharp increase in the number of renewable energy applications
17 which will worsen already congested transmission, particularly in the Sheffield-Highgate Export
18 Interface (SHEI), where several existing generators are frequently curtailed by the ISO. While NVDA
19 encourages appropriately scaled renewable energy development, NVDA has a commitment to ensure
20 that such development is sustainable and feasible and does not merely substitute one renewable
21 resource with another. NVDA supports energy development that will not exacerbate curtailment at
22 issue within the SHEI. It is unlikely that any single solution will solve congestion within the SHEI
23 and, as such, it is anticipated that incremental progress will be achieved as partial solutions are
24 implemented. In the meantime, NVDA will support projects that are consistent with the land use
25 and conservation measures in this plan and in duly adopted plans of impacted municipalities.
26 Additionally, we will expect project developers to work with utilities and other stakeholders to
27 explore innovative strategies that shift generation away from the hours when generation exceeds load
28 within the SHEI area or otherwise avoids exacerbating congestion on the grid. An example of such a
29 project would pair a battery with a solar facility to control when the project's power is exported to
30 the grid. In determining support for such a measure, NVDA will seek guidance from the long-range
31 Transmission Plan and Integrated Resource Plans in the region and will consult with utilities,
32 VELCO, and other stakeholders.

33 **Siting Potential**

34 This plan is accompanied by a series of maps (Appendix C) that can assist in the process of
35 identifying potential areas for siting and quantifying generation output. Underlying assumptions were
36 made about suitability factors, such as slope and direction of land, elevation and wind speeds, and
37 access to three-phase power. Additional statewide layers identified *known* constraints and *possible*
38 constraints, and a third layer has identified *regional* constraints:

39 Known constraints are areas not likely to be developed for renewable energy because they contain
40 one or more of the following: vernal pools; river corridors; FEMA floodways; significant natural
41 communities; rare, threatened and endangered species, national wilderness areas, wetlands (Class 1
42 and Class 2).

43 Possible constraints are areas that would likely require mitigation because they contain the one or
44 more of the following: agricultural soils; special flood hazard areas (outside of the floodway);
45 protected (conserved) lands; deer wintering areas; Act 250 mitigated agricultural soils; hydric soils,
46 and highest priority forest blocks.

1 **Regional constraint:** NVDA's regional plan has long held that rural areas should receive very little
2 commercial or industrial development unless it occurs in an established industrial park, or in an area
3 specifically designated in the local bylaw or plan as being well suited to such uses. Lands with an
4 elevation of 2,000 feet or more merit consideration as a special class of rural lands that should be
5 protected from any large-scale commercial or industrial development characterized by a constructed
6 height of 100' or more, and an acre or more of permanent site disturbance, such as clear-cutting.
7 These lands, as indicated on attached siting potential maps, contain one or a combination of factors
8 that make them unsuitable to such development – contiguous forest cover; sensitive wildlife and
9 plant habitat; conservation lands and recreational assets; managed forestland; and headwaters and
10 ephemeral surface waters, which are highly vulnerable to erosion and man-made disturbance. This
11 high-elevation forest cover must be kept unfragmented for the attenuation of flood flows, the benefit
12 of wildlife habitat and linkage, and public enjoyment through passive recreation.

13 The maps accompanying this plan do not carry the weight of zoning, and the siting of renewables on
14 prime acreages (i.e. without known constraints) is not a foregone conclusion. Rather regional maps
15 should be viewed as a starting point for our member municipalities to determine suitable and
16 unsuitable locations for renewable energy development. This plan's siting considerations for each
17 specific energy technology on the following pages should not be considered exclusive. They too
18 should be seen as a starting point for creating effective local specification and constraints.

19 Our estimates for potential generation outputs are therefore deliberately conservative to account for
20 the designation of local siting constraints. In most instances, only ***prime*** acreage (areas with no
21 constraints at all) were used to calculate output potential. Even with a highly conservative estimate,
22 potential generation vastly exceeds the regional generation target. This plan strongly encourages
23 municipalities to conduct additional site investigations to identify local constraints (as well as
24 preferred sites in addition to existing statewide preferred sites) in order to address the environmental,
25 aesthetic, civic, economic, and cultural concerns unique to each community.

Table 2.20: Estimated Potential Energy Generation in the Northeast Kingdom

	MW	MWh
Residential rooftop solar generation	15.0	18,412.2
Small commercial rooftop solar generation	3.0	3,343.2
Large commercial rooftop solar generation	5.9	7,225.9
Ground mounted solar	652.6	800,340.3
Wind (residential scale only)	13.6	23,405.2
Methane Digesters	430.0	2,260,080.0
Hydro	2.9	10,238.6
Total Generation	1,123.0	3,123,045.4

26

27 Solar

Total output potential:	829,321.6 MWh
Rooftop assumptions:	NVDA assumed one out of every 10 residential structures (including seasonal, many of which are inhabited part-time year-round). The region has relatively few commercial structures, so NVDA determined small commercial suitable for solar (less than 40,000 sq. ft.) for solar to be 10% of all commercial structures, and large commercial

1 2 Overall solar resources in 3 Vermont are quite good, 4 and solar energy can be 5 harnessed effectively for 6 primary and secondary 7 energy needs. The two main 8 types of solar energy 9 systems are photovoltaic 10 (PV), which generates 11 electricity, and solar thermal, 12 which generates hot air or 13 hot water for water and/or 14 space heating. For some	structures suitable for solar (more than 40,000 sq. ft.) to be just 3% of all commercial structures. The number of commercial structures was determined with NAICS classification counts used for determining commercial thermal energy use. (See Appendix B.)
	Ground mounted assumptions: Approximately eight acres of land are required to produce one MW of solar energy. In order to account for contingencies (property owners not interested in leasing their land, interconnection costs that may be too high, and unsuitability of specific sites) NVDA estimated only 1MW for every 60 prime solar acres. Acres with possible constraints were not included in the calculation.
15 homeowners in our region, solar electricity systems have proven more cost effective than extending power lines to the home. A typical off-grid system consists of photovoltaic (PV) modules that convert solar energy to electricity, batteries that store the electricity (if off-grid), and an inverter that converts DC power to AC for use in conventional electric appliances. As a rough rule of thumb, a 1	
16 kilowatt photovoltaic system can be expected to produce 3-3.5 kWh/day on average in Vermont. 17 Solar water heating systems typically utilize collectors to capture the sun's energy, a pump to circulate 18 a solution through the collectors to extract heat energy, and a well-insulated storage tank to hold the 19 heated water for use as needed (this can be integrated with an existing water-heating system). An 20 appropriate size solar water-heating system can provide one-half to two-thirds of a household's 21 annual hot water needs – typically 100% in summer, but as little as 25% in winter. In Vermont, these 22 types of systems tend to pay themselves off in less than two decades.	
23 Solar energy can also be harnessed through passive solar design (day-lighting and space heating) with 24 Green Building Design. This includes orienting buildings close to true south, as well as using 25 appropriate windows on the south wall, installing thermal mass (brick, concrete, or water) to store the sun's energy, and using appropriate levels of insulation. Through these designs, as much as 60% 30 of a building's space heat can be derived from the sun. This type of heating is termed "passive solar" 31 because no moving parts are needed, the collection and storage system is built into the structure. 32 Green Building Design principles also attempt to maximize the amount of natural light a building 33 receives, in order to reduce the energy costs associated with daytime lighting.	
34 Active and passive solar systems are custom built based on the building site, building and purpose of 35 the solar system. There are many factors that bear on siting solar systems. Many homes and 36 businesses have good rooftop sites, or good sites nearby for ground mounted systems. 37 Unfortunately, some do not, such as properties where there is limited southern exposure. One way to 38 address this situation is through the development of "community-sized" PV projects or co-operative 39 systems on the order of a few hundred kilowatts up to a few megawatts. There are a number of 40 community solar sites in our region, which also allow renters and homeowners where rooftop solar 41 will not work to take advantage of solar by "sponsoring" an off-site panel. Utility-scale PV 42 developments are also becoming popular in other areas of the U.S. Often referred to as solar parks, 43 farms, or ranches, these utility-scale PV installations are designed for the sale of merchant power 44 (MWh) into the electric grid and can utilize several acres of land. Public concerns surrounding solar 45 installations of this size usually focus on aesthetics and transmission line development.	

46 **Siting policies for solar:**

- 47 • NVDA has determined that the following types of locations in the region should be
48 prioritized for future solar generation. Even though these locations are not shown on the

1 regional solar maps due to a lack of GIS data, these sites should be considered “preferred
2 locations” for siting solar:

- 3 ○ Rooftops of structures, residential and commercial. (Our conservative estimates
4 show the region’s total potential output from rooftop solar alone could amount to
5 23.9 MW, or 6.3% of the high end of the LEAP model projections for solar for
6 2050 of 377.2 MW).
- 7 ○ Brownfield sites not located in a designated downtown or village center
- 8 ○ Earth extraction sites (e.g. gravel pits, quarries), active or abandoned
- 9 ○ Parking lot canopies and surface parking lots
- 10 ○ Farms, where more than 50% of the power generated is used by the farm
- 11 ○ Industrial parks, where more than 50% of the power generated is used by the
12 tenants of the industrial park
- 13 ○ Undersized lots and otherwise undevelopable land in existing industrial parks
- 14 ● The Northeast Kingdom has a robust agricultural economy, and NVDA discourages siting
15 ground-mounted solar in a manner that fragments productive agricultural soils, effectively
16 removing farmland from production for decades. To this end, NVDA encourages
17 municipalities to explore and identify local constraints that minimize farmland
18 fragmentation. These measures may include agricultural overlays (regulatory), as well as
19 conservation easements (non-regulatory). A number of land exploration tools, such as land
20 evaluation and site analyses (LESA) can help municipalities prioritize agricultural lands for
21 protection. NVDA will assist local planning commissions to identify local constraints as
22 appropriate.
- 23 ● Notwithstanding the above concern, NVDA recognizes that successful integration of solar
24 into active agricultural uses can help farms reduce expense, generate extra income, and
25 remain viable. NVDA encourages on-farm solar that, to every extent feasible, uses existing
26 farm structures, or is sited in a manner that supports grazing, the establishment of pollinator
27 crops, or simply to create buffers between organic and non-organic production areas.
28 NVDA will showcase best on-farm generation practices in the region and will cite “[Guide to
29 Farming Friendly Solar](#),” produced by the Two Rivers Ottauquechee Regional Planning
30 Commission, as a vital resource.

31 Wind

Total output potential:	23,405.2 MWh
Assumptions:	In accordance with Act 174 guidelines published in March of 2017, regional plans are allowed to submit plans to the Department of Public Service that do not establish targets for utility scale wind. This is especially important for the Northeast Kingdom, which has no targets for wind generation due to the existing level of production. When accounting for NVDA's regional constraint, the balance of prime wind acreages is just over 38,000. We estimate that new generation will be primarily farm- and residential-scaled. Even though no significant acreage is required for a farm- or residential scaled turbine, NVDA's estimate

1 Wind energy has recently
 2 been on the forefront of
 3 the renewable energy
 4 movement. The U.S.
 5 Department of
 6 Energy has announced a
 7 goal of obtaining 5% of
 8 U.S. electricity from wind
 9 by 2020, a goal consistent
 10 with the current rate of growth of wind energy nationwide. Vermont is currently ranked 34th out of
 11 the lower 48 states for wind energy potential.

assumed a contingency of 1 turbine for every 25 prime acres, with an average capacity of 9.5 kW. Some towns have no prime acres. For these towns, we assumed a broader contingency of 1 turbine every 75 acres.

The purpose of the contingency was similar to that of solar: to account for property owners not interested in leasing their land, prohibitive interconnection costs, and unsuitability of specific sites (including neighbor objections).

</div

1 troubled by the state's energy policies, the state's permitting process, and the ease with which the public
2 good as expressed in our municipal and regional plans can be overridden by people who may never have
3 even visited our region.

4 **It is the position of the NVDA that no further development of industrial-scale**
5 **(sic¹⁶) wind turbines should take place in the Northeast Kingdom.**

- 6 • Existing small turbines in the region are sited in very low-density areas and on farmland.
7 NVDA strongly urges municipalities to consider density in their specifications, as even small
8 wind turbines can produce noise that is incompatible with many residential areas. This can
9 be established through the use of noise ordinances or through required distances from
10 nearby residential uses, as specified in a locally adopted municipal plan with Substantial
11 Deference.
- 12 • The Northeast Kingdom has no new generation targets for wind due to the large amount of
13 energy generation currently coming out of the region. In keeping with the policies and
14 recommendations in the Land Use Plan, the regional wind generation maps in Appendix C
15 do not show many wind generation areas with high generation potential. This is due to the
16 existence of known constraints, including upland areas of 2,000 ft or more, headwaters,
17 forest coverage of site class 1, 2, or 3, priority forest habitat blocks, and state natural areas
18 and fragile areas.

19 **Hydro**

<p>20 Existing hydro-power 21 facilities in the Northeast 22 Kingdom collectively 23 produce more than 24 118,000 MWh annually, 25 accounting for more than 26 18% of our regional generation. (Table 2.13) The three Connecticut River Dams, though not 27 considered part of our regional generation, are three of the largest hydro facilities in the Northeastern 28 U.S. Together the Moore, Comerford, and McIndoe Falls Dams produce an additional 638,000 MWh 29 of electricity annually (double what the region consumes).</p>	<p>30 Total output potential: 10,238.7 MWh</p> <p>31 Assumptions: NVDA's analysis takes into account only existing dams 32 not being accessed for hydropower. Generation 33 information comes from a 2008 Agency of Natural 34 Resource study of small hydropower resources.</p>
---	---

31 Hydro facilities can be a good source of base-load power when regular rainfall is received. For river-
32 run facilities, power generation is dependent upon continuous levels of rainfall and must run when
33 the flow is at optimum levels. This can mean producing electricity when it might not be needed.
34 Dams, on the other hand, have the advantage of storing their resource for later use. Unfortunately,
35 drought can severely limit the production capacity of dams as well. Hydro power facilities can also
36 alter the ecosystem of a waterway. Both reservoir and river-run systems can increase water
37 temperature, decrease water speed, limit oxygen and increase nitrogen levels, and alter riparian areas.
38 These changes to the ecosystem cause stress to fish populations and riparian-habitat wildlife¹⁷.
39 Today, new hydro facility design and upgrades are engineered to mitigate or lessen negative impacts
40 on the ecosystem.

41 Overall hydro-power is considered a long-term resource and is relatively secure and stable.
42 Generation costs for hydropower vary considerably between facilities. Many of the facilities in the

¹⁶ The language regarding "scale" of renewable energy development has since evolved. For all intents and purposes the preferred term is "utility-scale," although in context of the 2012 wind study, the terms "industrial" and "utility" may be used interchangeably.

¹⁷ Foundation for Water Energy and Education

1 region were built in the early 1900's and have needed significant upgrades over the years. Upgrading
2 existing hydro and permitting new hydro can prove to be very costly and consequently raises the
3 production costs for the facility.

4 **Siting policies for hydro:**

- 5 • While this energy source is renewable, the ability to create new hydro-power generation is
6 limited. Some of the best hydro resources in the region are already generating, while
7 permitting new facilities has been a long and difficult process. At this time, facilities in other
8 regions of the state are facing some significant challenges in relicensing. Our focus for
9 regional hydro-power should be focused on maintaining our existing generation
10 infrastructure, upgrading aging infrastructure, and improving safety standards. The
11 development of new facilities should be pursued where practical.

12 **Methane**

<p>13 Methane, a common gas 14 found in the environment, 15 can be burned to produce 16 electricity. Large amounts 17 of methane are produced 18 through the anaerobic 19 digestion of manure, 20 agricultural wastes, and 21 other organic wastes. Both 22 large farms and landfills</p>	<p>23 offer the best potential to utilize this resource. The only large-scale landfill in the region is already 24 being utilized for methane generation, but there are at least 20 dairy farms with enough capacity to 25 sustain a manure-methane generation facility. In agricultural practices, manure is collected in various 26 containment systems, where it can be heated up for methane gas production and collection. The 27 remaining manure by-product can be spread on fields as fertilizer, the dry solids can be used for 28 animal bedding, and the excess heat can be used for other purposes such as greenhouse heating. 29</p> <p>30 In agricultural practices, the procedure also destroys harmful pathogens, reduces water quality 31 impacts, reduces manure odors, and provides a new source of income to local farmers. The Blue 32 Spruce Farm in Bridport, Vermont was the first farm in the state to develop a manure-methane 33 generation system. In the Northeast Kingdom the Maplehurst Farm, Maxwell Farm, and Chaput 34 Family Farms have installed anaerobic digester systems and collectively produce more than 4,500 35 MWh annually. All three are enrolled in the Standard Offer program, which offers long-term fixed 36 prices for generation without having to go through the program's reverse auction process. 37 Food scraps and food residuals (byproducts from processing) can also be used to produce energy in a 38 similar manner. The expansion of the region's agricultural processing sector, paired with Act 148's 39 mandatory diversion of food scraps from the waste stream, creates additional opportunity to generate 40 energy. Research with food waste is already underway at Vermont Technical College, but additional 41 exploration is needed to make this feasible here in the NEK.</p>
---	--

42 **Siting policies for methane:**

- 43 • Manure methane generation should be expanded in the region's energy mix. As with farm-
44 friendly solar generation, manure methane generation may protect the viability of working
45 farms by reducing production expense and generating extra income for the farmer. NVDA

1 encourages municipalities to identify potential production sites in their plans and provide
2 appropriate guidance for siting with regard to screening, noise, and odors.

- 3
- 4 • Existing on-site technologies are costly and only make economic sense for larger farms. (In
5 Europe, central methane digestion systems do allow smaller farmers to process animal
6 wastes, but trucking is involved.) Emerging technologies in Europe may prove to be more
7 cost-effective for smaller farms. NVDA encourage the ongoing use state and federal grants,
8 tax credits, incentives, and technical assistance to combat the high start-up costs of methane
generation for the region's farmers.
 - 9
 - 10 • NVDA should work with the region's food system leadership group, as well as other
11 proponents of the Regional Food System Plan, to ensure that the region's agricultural
12 producers have access to technical services, grants, and other incentives to refine and
maximize digester technologies.
 - 13
 - 14 • Food scraps and residuals may play a role in the region's energy generation portfolio as well.
15 NVDA supports energy recovery that supports the highest and best use of waste materials,
16 namely the food recovery hierarchy that prioritizes the reduction of waste. This policy is
consistent with NVDA's Utility and Facilities Plan.

17 **Biomass**

18 Biomass has significant potential to reduce the region's fossil fuel consumption. The majority of our
19 fossil fuel consumption is for transportation and home heating uses, only a small portion of fossil
20 fuels are used in electricity generation for the region. Wood chips, wood pellets, and biodiesel hold
21 the greatest potential for Vermont to transition these uses towards renewable energy. The expansion
22 of these resources will also offer strong support for our traditional economy (forestry and
23 agriculture) and stabilize regional fuel costs. In the next few years, biomass usage should be
24 promoted and expanded as a significant resource to diversify the region's energy portfolio and meet
25 future energy needs.

26 The region already supports a large-scale wood-chip fueled electric generation facility. The Ryegate
27 Power Station is the second largest electric generation facility in the region. Capable of generating
28 172,367 MWh annually; the plant operated at 100% capacity in 2009, but was idle in the spring of
29 2012. New power purchase agreements have been drafted and the plant resumed production in June
30 2012. Ryegate Power Station is a good example of the difficulties in making an electric-only wood
31 generation plant profitable and competitive. Overall, the ease of handling, local availability, low
32 emissions, and general low-costs of wood resources will allow the region an opportunity to expand
33 this resource if fossil fuel prices climb.

34 One of the most efficient uses for wood-fuels is co-generation, the simultaneous production of both
35 heat and power, such as the system in North Country Regional Hospital that generates a third of its
36 electric needs and heats the entire hospital. Recent studies looking at co-generation opportunities in
37 the region indicate that it works best when there is an equal need for heat and power¹⁸. Balanced heat
38 and power loads are easier to provide for on the small scale, such as for an individual business but
39 larger plants are more desirable, since they can secure more renewable energy incentives and the
40 capital cost/kWh improves. Large co-gen applications (10+MW) may make sense if an equally large
41 heat user can be found, such as a manufacturer that requires tremendous heat loads. Some engineers
42 propose developing district heating systems along with co-gen plants in areas where a considerable
43 industrial heat user is not available. District heating systems are utilized throughout Europe and one
44 will soon come on-line in Montpelier. Unfortunately most of Vermont's communities do not have

¹⁸ *Town of Sutton - Burke Lumber Site Redevelopment: Wood Supply Assessment & Wood Pellet Manufacturing Facility Feasibility Study/Business Plan* (June 2009, Innovative Natural Resource Solutions for NVDA), St. Johnsbury-Lyndon Industrial Park Energy Study (2007).

1 the density to support nor afford the \$400/linear foot installation cost district heating requires for
2 distribution. In addition, the average connection cost for district heating is around \$5,000 per
3 homeowner. In other words, district heating is not an easy sell to tax payers.

4 **Siting policies for biomass:**

- 5 • Siting wood-generation and co-generation facilities can be fraught with challenges. Noise,
6 emissions, truck traffic, and unsightly smoke stacks are concerns when siting facilities near
7 residential neighborhoods. Municipalities are strongly encouraged to develop performance
8 standards for industrial uses.
- 9 • These facilities use a renewable fuel that grows at a specific rate, so overharvesting of the
10 regional woodshed is a concern. The plan strongly urges a commitment to responsible
11 stewardship of the region's forestry resources, accomplished through the use of forestry
12 overlays that minimize fragmentation (regulatory), or enrollment in Vermont's Current Use
13 Program and conservation easements (non-regulatory). A number of planning tools are
14 available to municipalities, including forestry land evaluation and site analyses (FLESAs), that
15 can help municipalities prioritize lands for protection. NVDA encourages local planning
16 commissions to seek technical assistance.


17 **Geothermal**

18 Geothermal has great potential for expansion in the Northeast Kingdom, with the most promising
19 systems being open-loop well systems. This technology is also one of few renewable resources that
20 can directly reduce fuel oil consumption used for space heating and should be encouraged in both
21 existing and new construction in the region. There are numerous sites throughout the region where
22 geothermal can be used. (Figure 2.4)

Geothermal Heating & Cooling High Potential Wells in the Northeast Kingdom

Figure 2.4

June 2015



1 A Healthy and Sustainable Regional Food System

2 The food we eat has a profound impact on our region's energy use and carbon footprint. The
3 complexity of processes and practices along every point in our food system -- from production, to
4 processing, to distribution, to waste -- has significant environmental and ecological implications,
5 making food the number one cause of global warming.¹⁹ Fortunately, the region's vibrant agriculture
6 sector has helped to make Vermont a leader in access to local food. The Northeast Kingdom is the
7 only region of Vermont to adopt a comprehensive Food System Plan, one that is built on a "soil to
8 soil" model that seeks to localize the production, processing, distribution, consumption, and
9 composting of our region's agricultural resources. The emerging Food System Leadership Group, is
10 responsible for overseeing the implementation of the five-year plan. Their work can intersect with
11 regional energy planning efforts in a number of ways, including:

12 **The reduction of food waste:** There has been a concerted effort to divert discarded food and food
13 scraps from landfilling, as evidenced by the many schools, institutions, and municipalities that have
14 established programs for collecting and composting food scraps. However, perfectly edible food
15 often gets discarded as well. Food waste is a serious economic and environmental problem that
16 persists, even in the face of rising food insecurity. Food waste is any food product that gets
17 discarded, at any point along the supply chain: from produce left to rot in the fields, from expired
18 foods discarded by the retailer, to leftovers scraped from dinner plates into the garbage bin.
19 Anywhere from 25% to 40% of our nation's food ultimately goes to waste, nearly all of which ends
20 up in landfills, where it produces methane that is 21 times more potent than CO₂ as a greenhouse
21 gas. Food waste contributes 4.4 gigatons of carbon dioxide equivalent into the atmosphere every
22 year. If food waste were a country, it would be ranked just behind the U.S. and China as the third
23 largest emitter of greenhouse gas emissions.²⁰ The NEK Food System Plan is focused on redirecting
24 waste, both edible food to food secure populations, and food scraps and residuals to appropriate
25 composting facilities and to digesters. The region has limited infrastructure for handling organic
26 wastes, so a successful and efficient system will likely be a combination of trucking/hauling and on-
27 site management.

28 **Shared distribution and warehousing:** In theory, a more localized food system reduces energy
29 because it entails fewer "food miles" in getting the food from farm to table. Unfortunately, much of
30 the region's agricultural product is currently distributed in and out of the region in a less-than-
31 truckload capacity. Among the smallest of producers, the distribution system could be a Subaru. The
32 NEK Food System Plan has identified a number of opportunities for shared distribution and storage,
33 all of which can reduce transportation miles and greenhouse gas emissions. Coordination and
34 oversight of these shared opportunities is needed to make this distribution system efficient.

35 **Conservation and Regenerative Agricultural Practices:** An array of practices that feed the soil
36 can also increase the rate of carbon sequestration. While there is no single blueprint for success, a
37 number of farmers in the region are implementing techniques such as diversified cover cropping and
38 conservation tillage to mitigate the loss of topsoil and stem erosion. Grass farming and rotational
39 grazing can reduce energy inputs, reduce erosion, and improve water quality as well. The NEK Food
40 System Plan seeks to promote practices that improve environmental stewardship and overall soil
41 health. It is imperative that farmers can access the technical assistance and resources that will help
42 them achieve this.

43
44
45

¹⁹ Paul Hawken. *Drawdown: The Most Comprehensive Plan Ever Proposed to Reduce Global Warming*, Penguin (2017)

²⁰ Ibid.

1

2 REGIONAL ENERGY GOALS & STRATEGIES

3 An adequate, reliable, diverse, and secure energy supply will benefit the region.

- 4 Promote a diversified energy portfolio for the region.
- 5 Support the upgrade of regional transmission systems to continue to reduce constraints.
- 6 Support the maintenance and upgrade of existing energy generation facilities and related
7 infrastructure.
- 8 Encourage local responders to plan for emergency energy resources (VEM Emergency
9 Generator Grant Program generators).

10 Affordable energy alternatives will be available for the region's users that decrease
11 the region's reliance on fossil fuel.

- 12 Assist in the development of businesses that support alternative energy use.
- 13 Work with Tier 3 energy service providers to promote the installation of cold climate heat
14 pumps and geothermal systems by facilitating outreach and education on their benefits.
- 15 Partner with Efficiency Vermont and Tier 3 energy service providers to increase the use of
16 efficient wood heat and biomass systems.
- 17 Support the development of small-scale renewable resources, such as wind and solar, and the
18 use of supplemental sources (wood) to stabilize energy costs.
- 19 Promote and support rail infrastructure as a cost-effective transportation resource for the
20 energy industry.
- 21 Encourage and support agricultural production of biofuels and oilseed crops and explore
22 ways to broaden access to processing infrastructure.
- 23 Identify potential users of district heating and wood heating systems and provide assistance
24 to communities seeking to develop them.
- 25 Encourage the legislature to increase incentives and rebates for efficient wood heat systems.
- 26 Provide outreach and education among vendors, contractors, and the general public through
27 venues such as tradeshows and workshops.
- 28 Provide communities with an analysis of potential areas that are suitable for ground source
29 heat pumps.
- 30 Support upgrade and trade-out programs and incentives for older, higher emission wood
31 burning stoves and boilers.

32 Decrease the region's reliance on single occupancy vehicle trips and gas/diesel
33 powered vehicles.

- 34 Continue to advocate for better telecommunications infrastructure so employees can work
35 from home.
- 36 Encourage local employers to reduce VMTs through programs such as ride sharing and Go
37 Vermont.

- Support and expand access to liquid biofuels for use in commercial vehicles and heavy equipment.
- Support and expand the use of electric powered busses and vans among the public transportation providers serving the region.
- Work with cycling advocacy groups such as Local Motion by hosting safe on-road cycling workshops.
- Provide training to local zoning and development review boards to consider infrastructure for alternative transportation in their review of site plans.
- Provide technical and grant writing assistance to local planning commissions who plan for multi-modal circulation and better connectivity with alternative transportation modes.
- Promote the use of the region's cycling infrastructure such as the Cross Vermont Trail and the Lamoille Valley Rail Trail and support the efforts of local groups who work to maintain them.
- Support municipalities and local businesses to install EV charging stations at convenient locations, such as in front of restaurants, stores, businesses, or entertainment or recreational facilities, where users would want to park for periods of two to four hours. Explore and pursue incentives to defray the cost of installation and administration so that users pay only for electricity.

Net-metering capacity in the region will be maximized.

- Encourage municipalities to become "clean energy districts" and participate in the PACE program (Property Assessed Clean Energy). This would provide consumers with options to more affordably implement grid tied renewable energy systems.
- Support solar panel safety training programs for fire fighters and first responders.

Energy efficiency and weatherization will be an integral part of the energy portfolio.

- Assist municipalities in reducing their energy costs through conservation, efficiency, and weatherization programs.
- Support and promote the Energy Action Network (EAN) energy dashboard and educate communities about its use and benefits. Support crowdsourcing on efficiency and weatherization efforts at the local level (e.g. Vermont Community Energy Dashboard).
- Support Local Energy Committee/Coordinator efforts to reduce energy consumption, improve efficiency and weatherization, and develop new generation resources.
- Encourage municipalities to conduct energy audits and weatherization programs.
- Encourage businesses to make energy efficiency investments and develop energy efficient production methods.
- Promote energy efficient building design and construction methods (e.g. Green Building Design, LEED certification, and Passive Design).
- Promote Energy Efficiency Utility program resources by making web links available on municipal/regional web sites.

- Work with partner organizations and Energy Efficiency Utilities EEU's to offer workshops and educational opportunities to businesses on efficiency in new construction, retrofits, and conservation practices.
- Identify large energy usage customers (including large businesses, manufacturing facilities, and schools) as a target audience and encourage participation in commercial and industrial EEU programs.
- Facilitate strategic tree planting to maximize energy benefits by encouraging communities to participate in the [ArborDay Energy Saving Trees Program](#).
- Support local zoning initiatives that incent the development of small and/or net-zero homes.
- Ensure that developments subject to Act 250 consider new energy requirements by encouraging the compliance with commercial energy stretch codes, particularly among proposed commercial uses that are high energy consumers.
- Showcase the cutting-edge work of local architects and contractors who incorporate green building practices through NVDA's web site and newsletters.
- Promote the use of the [Vermont Home Energy Profile](#) among prospective buyers and sellers of homes. Work with local contractors to become BPI certified in energy-efficient retrofit work in order to assist with these profiles.
- Ensure that local zoning administrators have information on Residential Building Energy Standards and Commercial Building Energy Standards (RBES and CBES). Host and facilitate training sessions for local officials. Encourage communities with zoning to require Certificates of Occupancy. Encourage the local adoption of "stretch codes".
- Work with local affordable housing organizations to promote and improve the supply of the region's net-zero and near-net zero housing supply, such as Vermod homes.
- Review local zoning bylaws and offer technical assistance to development review boards when evaluating the energy efficiency implications of site plans for proposed developments.

Weatherize at least 25% of the region's housing stock by 2020.

- Actively advocate for the continuation and expansion of funding programs that support thermal efficiency and renewable energy improvements, especially programs that are targeted to middle- and low-income households.
- Coordinate with and promote efficiency programs and weatherization assistance programs (such as Efficiency Vermont, NE TO, 3E Thermal, and Heat Squad) for low-income households and apartment buildings.
- Cosponsor and organize weatherization workshops for home and businesses with EEU's.
- Facilitate or sponsor a workshop for owners of rental housing (including farm labor housing) to encourage implementation of energy efficiency.
- Encourage residents to hire Efficiency Excellence Network (EEN) contractors when completing energy efficiency projects by including links to the EEN on municipal/regional websites.
- Make information available about lending programs that can improve the efficiency of older housing stock, such as Efficiency Vermont's "Heat Saver" loan and USDA Direct and Guaranteed Loan Programs, for single homes and multi-family homes.

1 Energy generation that provides the best cost-benefit to the region will be
2 promoted.

- 3 • Promote wood-based energy generation to support the region's forest industry.
- 4 • Encourage the development of energy facilities and resources that help sustain local
5 agriculture and forestry (i.e. grass/wood-pellets, small-wind, solar, farm-methane, wood-
6 chip, biodiesel).

7 Environmental and aesthetic impacts of energy generation and usage will be
8 considered.

9 There will be broad public participation in the decision-making process.

- 10 • Encourage the Vermont Legislature to develop policies that support the development of
11 solar, small-wind, hydro-electric, farm methane, biodiesel and biomass generation facilities,
12 while respecting current local land use and the culture of the region.
- 13 • Encourage the PUC to examine the long-term sustainability of proposed facilities.

14 **Assessment of local needs and values on new energy development will be
15 encouraged.**

- 16 • Encourage towns to address energy development in town planning and zoning.
- 17 • Provide assistance to businesses/municipalities to develop cogeneration and other
18 alternative energy strategies.

19 Reduce the region's carbon footprint through the expansion of a closed loop soil-to-
20 soil regional food system that sustains and feeds the people of the Northeast
21 Kingdom.

- 22 • Coordinate movement and storage of goods to achieve maximum efficiency.
- 23 • Redirect food scraps and other organics from the waste stream in a manner that maximizes
24 efficiency and minimizes hauling.
- 25 • Support and further the goals and strategies of the NEK Food System Plan through its
26 Leadership Group.
- 27 • Identify and publicize opportunities for shared truck space among existing growers and
28 producers.
- 29 • Generate better awareness of existing distribution resources, such as freight service.
- 30 • Identify and publicize opportunities for shared storage space among existing growers and
31 producers.
- 32 • Explore the feasibility of establishing a leased storage facility.
- 33 • Assess market demand for products and existing shippers and distributors already moving to
34 external (New York and Boston) markets (including opportunities for backhauling).
- 35 • Identify infrastructure needed to maximize inbound, outbound, and internal freight
36 movement.
- 37 • Promote the use of and increase the amount of on-farm power and community energy
38 generation and the use of renewable energy for farming and food production (such as

1 anaerobic digesters, solar, wind, biomass, and biodiesel, in accordance with local and regional
2 planning priorities).

- 3 • Support local incentives for siting solar installations away from most productive agricultural
4 soils.
- 5 • Explore the use of compost heat recovery; identify challenges, opportunities, and funding
6 sources.
- 7 • Provide and increase opportunities for onsite and commercial composting training and
8 education, sustainable farming methods focused on reduction and reuse of wastes (closed-
9 loop nutrient systems), and shared facilities and infrastructure to transfer and store compost.
- 10 • Establish a coordinated marketing campaign that dispels the perceptions around local food
11 costing more and extols the long-range benefits of staying local (e.g. dollars re-circulated into
12 the economy, food miles travelled).
- 13 • Explore the feasibility of developing a “food miles” measurement that can be used in
14 marketing local foods.


15

Vermont Public Power Supply Authority 2019 Tier 3 Annual Plan

In accordance with the Public Utility Commission's ("PUC") *Final Order in Docket 8550*, Vermont Public Power Supply Authority ("VPPSA") is filing this Annual Plan describing its proposed 2019 Energy Transformation programs. Vermont's Renewable Energy Standard ("RES"), enacted through Act 56 in 2015, requires electric distribution utilities to either generate fossil fuel savings by encouraging Energy Transformation projects or purchase additional Renewable Energy Credits from small, distributed renewable generators ("Tier 2"). Utilities' Energy Transformation ("Tier 3") requirements are established by 30 V.S.A. § 8005(a)(3)(B), which states that "in the case of a provider that is a municipal electric utility serving not more than 6,000 customers, the required amount shall be two percent of the provider's annual retail sales beginning on January 1, 2019."¹ The 12 municipal Members of VPPSA are each eligible to have their obligation begin in 2019 under this provision. In addition, under 30 V.S.A. § 8004 (e) "[i]n the case of members of the Vermont Public Power Supply Authority, the requirements of this chapter may be met in the aggregate." The VPPSA Member utilities plan to meet Tier 3 requirements in aggregate in 2019.

VPPSA Tier 3 Obligation

In 2019, VPPSA's aggregate requirement is estimated to be 6,917 MWh or MWh equivalent in savings. Obligations increase rapidly, doubling within three years.



¹ 30 V.S.A. § 8005(a)(3)(B)

Prescriptive Programs

VPPSA plans to meet these challenging requirements through a mix of programs and measures that meet each statutory goal for Tier 3 while mitigating costs that could put upward pressure on rates.

VPPSA Electric Vehicle Program

Despite lower operating and maintenance costs associated with Electric Vehicle (“EV”) and plug-in hybrid electric vehicles (“PHEVs”), the upfront cost continues to be a major barrier to greater EV penetration in the state. EVs and PHEVs remain a relatively low percentage of overall vehicle sales in the state. According to Drive Electric Vermont, the number of plug-in vehicles (EVs and PHEVs) in the state increased by 844 vehicles, or 48%, over the past year and these vehicles comprised 3.4% of new passenger vehicle registrations over the past quarter. Nonetheless, there were only 2,612 plug-in vehicles registered in Vermont as of July 2018. VPPSA and other utilities are working to raise awareness of the benefits of plug-in vehicles and help alleviate the financial barriers to EV and PHEV adoption. VPPSA will continue to offer customer rebates for the purchase or lease of EVs and PHEVs. The customer incentive for purchasing or leasing an electric vehicle will be \$800 and the customer incentive for purchasing or leasing a plug-in hybrid electric vehicle will be \$400. Low-income customers² will receive an additional \$200 towards the purchase or lease of an EV or PHEV.

The VPPSA utilities offered an EV Pilot Program on a voluntary basis in 2018. The Pilot enabled VPPSA to develop the necessary infrastructure to implement programs across utility service territories and determine how its Members can best benefit from Tier 3 aggregation. The structure put in place to track Tier 3 costs and benefits under the EV Pilot Program will be replicated as 2019 Tier 3 programs are rolled out. Savings accrued during the 2018 Pilot Program will be banked for use to meet 2019 or future compliance obligations, consistent with 30 V.S.A. § 8005(a)(3)(F)(iv).³

VPPSA Cold Climate Heat Pump Program

In 2019, VPPSA will offer customer rebates for the purchase of cold climate heat pumps (“CCHP”) in the amount of \$300. For customers that can demonstrate a defined level of building performance, the CCHP rebate will be increased to \$400. The additional incentive, even if it isn’t utilized, serves to highlight the importance of overall building performance. Because heat pumps in high-performing buildings will have less impact on peaks, this also serves to assist in

² According to the PUC’s *Order Implementing the Renewable Energy Standard* dated 6/28/2016, “A low-income customer shall be defined as a customer whose household income is at or below 80% of Vermont statewide median income.

³Act 56 requires the Public Utility Commission to adopt rules: “... (iv) To allow a provider who has met its required amount under this subdivision (3) in a given year to apply excess net reduction in fossil fuel consumption, expressed as a MWH equivalent, from its energy transformation project or projects during that year toward the provider’s required amount in a future year.”

managing demand during those high cost times. In order to be eligible for the higher incentive amount, customers will need to demonstrate that their homes were “weatherized” according to a list of standards developed and circulated by the Department of Public Service (“DPS”) during the CCHP measure characterization by the Technical Advisory Group (“TAG”).

VPPSA Heat Pump Water Heater Program

VPPSA intends to provide rebates to customers that install heat pump water heaters (“HPWH”) to replace fossil-fuel fired water heaters. These incentives will be provided in conjunction with Efficiency Vermont (“EVT”) HPWH rebates. VPPSA and EVT are currently negotiating a Memorandum of Understanding (“MOU”) to implement this joint program and define the “savings split” between the VPPSA utilities and EVT.

Savings from Heat Pump Water Heaters, Cold Climate Heat Pumps, and Plug-in and Electric Vehicles will be estimated using measure characterizations created by the Tier 3 TAG. VPPSA’s budget and estimated savings for prescriptive Tier 3 Programs is summarized below.

VPPSA Tier 3 Prescriptive Program Expected Costs and Savings

<i>Measure</i>	<i>Savings/unit (MWH)</i>	<i>Incentive Amount</i>	<i>Admin Cost</i>	<i>Total Cost</i>	<i>Volume</i>	<i>Cost/MWH</i>	<i>Total Credit (MWH)</i>	<i>Budget</i>
EV	24.6	\$800	\$148	\$948	15	\$38.52	369	\$14,215
PHEV	13.7	\$400	\$148	\$548	30	\$39.98	411	\$16,431
CCHP	12.8	\$300	\$148	\$448	80	\$35.09	1021	\$35,815
CCHP (wz)	15.8	\$400	\$148	\$548	20	\$34.75	315	\$10,954
HPWH*	5.69	\$300	\$148	\$448	5	\$78.68	28	\$2,238
TOTAL					150	\$37.14	2144	\$79,653

*reflects expected savings split with EVT

Other Tier 3 Measures

Incentives for Electric Vehicle Supply Equipment

Several VPPSA members have identified possible locations for the installation of electric vehicle charging stations within their territories. These utilities are working with potential charging station hosts to apply for funding from the Volkswagen Mitigation Trust Fund for public EV chargers. Should these installations move forward, VPPSA members may provide financial contributions and/or technical assistance in addition to that already provided in support of the application to facilitate the installation of electric vehicle charging infrastructure.

Fork Lifts and Golf Carts

In addition to the prescriptive rebate programs described above, VPPSA is actively seeking out opportunities for fuel switching golf carts and fork lifts to electricity. Both of these measures were recently characterized by the TAG and together provide substantial potential for fossil fuel savings. VPPSA anticipates working with businesses that may wish to replace fossil fuel equipment with electric-powered equipment and is exploring what level of incentive would be needed for these conversions.

Commercial and Industrial Customers

Commercial and industrial (“C&I”) customers will be served on an individual, custom basis in 2019. VPPSA continues to explore cost-effective Tier 3 custom projects, including converting utility customers from diesel generators to electric service. In addition, C&I customers that have potential Tier 3 projects are being identified by Efficiency Vermont through a joint arrangement with VPPSA to ensure that these customers receive comprehensive efficiency services. To date, opportunities have been identified at a ski resort, a furniture maker, a quarry, and a candy manufacturer. VPPSA has and will continue to work with the Department on custom projects to ensure savings claims are valid and able to be evaluated.

Equitable Opportunity

The Tier 3 incentives offered by VPPSA will be available to all of the VPPSA Members' customers. Discussions with vehicle dealerships around the electric vehicle rebate program indicated that many low- to moderate-income customers take advantage of PHEV leases. By providing additional incentives for income-eligible customers, as well as by making the incentives available for both vehicle leases and vehicle purchases, VPPSA's EV rebate program is designed to be accessible to low-income customers.

The ability to bring financial benefits to all customers, rather than just participating customers, makes electrification an attractive Tier 3 option from an equity perspective. All of a host utility's customers have the potential to benefit from the increased electric sales that accompany electrification programs such as VPPSA's electric vehicle, heat pump, and heat pump water heater programs. If additional kWh can be procured at costs at or below the costs embedded in a utility's rates, increasing the number of kWh delivered through the utility's system allows the fixed costs of operating the utility to be recovered over a larger number of units, driving the per kWh rate down. VPPSA's analysis shows that the incentive dollars paid to customers in rebates for electrification measures are expected to be recovered through increased sales over the life of the measures, making these programs revenue neutral or, more likely, economically beneficial for non-participating ratepayers.

Collaboration/Exclusive Delivery

Strategic electrification of the transportation and heating sectors is an appropriate responsibility of the Vermont's distribution utilities, who are charged with procuring electric supply and managing the distribution grids across the state. Strategic electrification is outside of the purview of the state's energy efficiency utilities, whose mandate is to achieve cost-effective electric and thermal efficiency savings (where the presumption is that reductions in load do not have the possibility for adverse distribution/transmission system impacts/costs). Distribution utilities are uniquely positioned to promote heating and transportation electrification while assessing and mitigating grid impacts. If electrification is going to deliver its potential climate and economic benefits to Vermonters, it must be carried out in a way that does not disproportionately increase utility costs.

VPPSA and Efficiency Vermont are working together to define how the two entities can provide holistic efficiency services to residential, commercial, and industrial customers. A Memorandum of Understanding to govern this engagement and interaction is under development. In many cases, this partnership will involve VPPSA providing incentives for electrification measures, which can provide benefits to all utility ratepayers, while EVT provides incentives for thermal and electric efficiency measures.

Currently, VPPSA and EVT are engaged in a targeted community effort in Northfield that will continue through early 2019. This initiative involves enhanced outreach to customers regarding VPPSA and EVT incentives, in-person communication with small businesses, and educational workshops on a series of energy efficiency topics. VPPSA and EVT will evaluate whether such joint targeted efforts have the potential to generate greater savings and/or better align with a community's specific energy efficiency needs. If successful, this model may be adapted and deployed in other VPPSA municipalities.

VPPSA has also been working with NeighborWorks of Western Vermont, a comprehensive weatherization service provider that recently expanded its service territory to include the Northeast Kingdom. VPPSA has provided marketing support in the form of utility bill stuffers to NeighborWorks to promote awareness of this new service offering. NeighborWorks, in turn, will be making customers aware of VPPSA's incentives. The collaboration with NeighborWorks is ongoing, and VPPSA sees the thermal efficiency services offered by NeighborWorks as complementary to the electrification measures promoted by VPPSA.

Regarding VPPSA's EV program, the natural partners are vehicle dealers located throughout the VPPSA Members' service territories. VPPSA has done direct outreach to local dealers that sell EVs to ensure they are aware of the VPPSA rebate program. VPPSA is not aware of other energy service providers currently offering electric vehicle incentives in the VPPSA utilities' service territories, as transportation electrification is outside of the purview of Efficiency Vermont. Another partner in VPPSA's EV program is Drive Electric Vermont, who has been consulted regarding program design considerations and also engaged in helping develop customer educational materials.

Best Practices and Minimum Standards

Over the long-term, electric vehicles and heat pumps have the potential to significantly increase loads for Vermont utilities. Through ongoing distribution planning efforts, the VPPSA members have identified that their systems remain robust, and the expected growth in annual and local peak demand associated with proposed measures can generally be sustained if monitored and deployed carefully. According to the load forecast developed by VELCO and the Vermont System Planning Committee in conjunction with VELCO's Long-Range Transmission Plan, load growth associated with strategic electrification is not expected to impact the transmission grid for the next eight to ten years. In the short-term, VPPSA's strategy for managing increased load will rely largely on customer education. The VPPSA member utilities will continue to monitor load impacts of the electrification of home heating, water heating, and EV charging to determine when more active load management will be necessary.

With regards to EVs, it is expected that the majority of home charging will occur during overnight, off-peak hours. Through VPPSA's EV Pilot Program, informational materials about the ideal time to charge vehicles will be provided to customers that receive rebates.

Under VPPSA's heat pump program, customers that can demonstrate that their homes have been weatherized will receive a higher incentive for the installation of a heat pump. This increased incentive will encourage customers to improve the thermal performance of their homes, thus allowing heat pumps to operate more effectively. Customers will be informed of the benefits of weatherization and provided with resources for increasing the performance of their homes. Heat pumps installed in well-insulated homes have the potential to mitigate the grid impacts of heating electrification as compared with heat pumps installed in poorly insulated buildings.

Ultimately, in the long term VPPSA expects that active load control will be necessary to manage EV charging and, to some extent, heat pump usage. Managing when the increased load from strategic electrification occurs will enable utilities to collect added revenue from increased electric sales without significant increases in the costs associated with higher peak loads. Effective load control requires a combination of rate offerings and technology that either provide active control or verify customer adherence to desired goals. These technologies have historically been challenging to implement in rural areas of Vermont where communication systems are lacking and the cost of the required back-office systems is often prohibitive. Some form of interval metering is needed for most types of load control rate offerings. The VPPSA Members are currently exploring the viability of installing advanced metering ("AMI") technology within their territories and expect to have consultant recommendations on whether to move forward with AMI deployment by early 2019. In addition, VPPSA is in discussions with VELCO about the viability of extending VELCO's fiber optic network into VPPSA member distribution systems to both facilitate AMI technology and provide a platform for expanded broadband coverage in areas of the state that do not currently have access. AMI and/or broadband technology will facilitate the implementation of demand response and load control programs that will allow utilities to manage increased electrification load in the most cost-effective manner.

VPPSA Tier 3 Strategy

VPPSA intends to deploy Energy Transformation programs, with a focus on electrification measures, to residential and commercial and industrial customers to satisfy the VPPSA Members' Tier 3 obligations. VPPSA is ramping up Tier 3 programs at an aggressive yet considered pace in its first Tier 3 compliance year. To the extent that there is a shortfall in savings from Energy Transformation programs, VPPSA will employ alternative strategies for meeting Tier 3 requirements in a cost-effective manner. One component of VPPSA's Tier 3 strategy is to purchase Tier 2 RECs when prices are low as a hedge against a shortfall in savings from Tier 3 programs. To the extent that Tier 2 RECs are less expensive than implementing Tier 3 programs, VPPSA will exercise this strategy to benefit its Members. In addition, for VPPSA members that own Tier 2 eligible generating resources, Tier 2 RECs may be the primary strategy for Tier 3 compliance. VPPSA's Tier 3 strategy may also include providing incremental support to the state's Weatherization Assistance Program. Since the RES was enacted, VPPSA has explored developing a Tier 3 program focusing on weatherization but found that program to be cost-prohibitive. Given the PUC's August 24, 2018 Order in Case 17-4632 regarding Washington Electric Cooperative's Tier 3 savings claim for weatherization work, it may be prudent for VPPSA to implement the same type of Tier 3 program at a cost significantly lower than the Tier 3 Alternative Compliance Payment.